

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月02日

報表日期: 114年07月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.35	6.69	55.85	1.95	17.31	11.51	1.28	81249.67
1	4.81	5.50	58.33	2.35	17.34	11.70	1.27	79762.63
2	6.33	8.43	62.70	1.98	17.39	11.87	1.28	78386.75
3	13.72	8.35	60.70	3.34	16.76	11.80	1.29	79317.09
4	11.13	8.56	60.68	3.27	17.35	11.52	1.28	82034.69
5	2.28	9.79	53.33	2.40	18.46	11.44	1.29	82679.47
6	6.91	8.33	58.66	2.04	17.54	11.61	1.29	81552.36
7	5.77	7.41	61.23	2.04	17.54	11.48	1.31	82315.02
8	7.37	9.73	56.34	1.97	17.43	11.56	1.30	81245.32
9	8.45	12.20	56.21	2.80	16.85	11.86	1.30	79642.91
10	6.38	8.96	59.79	3.34	15.84	12.13	1.30	79290.88
11	1.19	10.92	53.60	3.70	14.18	12.59	1.29	75150.67
12	2.62	10.44	62.42	2.37	16.51	11.93	1.29	78260.73
13	1.05	9.26	56.02	3.09	14.91	12.14	1.31	78126.76
14	1.62	9.50	49.61	2.21	16.41	12.08	1.32	77109.08
15	5.99	9.30	62.19	2.61	16.53	11.79	1.31	78761.70
16	5.13	11.09	50.05	3.50	15.77	11.77	1.30	80558.23
17	1.73	8.79	59.58	2.64	16.85	11.70	1.30	79762.88
18	3.05	8.63	67.45	2.76	16.27	11.58	1.30	81925.94
19	13.58	9.08	54.62	3.27	14.74	11.94	1.29	79098.70
20	9.42	8.72	52.86	1.44	14.98	11.89	1.29	77958.66
21	10.56	10.89	56.86	2.16	16.61	11.68	1.29	80554.59
22	12.99	9.51	57.93	2.62	16.57	11.82	1.29	79769.40
23	9.66	9.95	56.41	2.56	15.46	12.22	1.29	77806.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.59	9.17	57.64	2.60	16.48	11.82	1.29	79680.01
最 大 值	13.72	12.20	67.45	3.70	18.46	12.59	1.32	82679.47
發生時間	3	9	18	11	5	11		5
最 小 值	1.05	5.50	49.61	1.44	14.18	11.44	1.26	75150.67
發生時間	13	1	14	20	11	5		11
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.00 %		-0.08		0.20 %
全幅偏移(率)	0.00 %	0.00 %	0.00 %	0.00 %		-0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

