

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月05日

報表日期: 114年10月05日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.62	12.01	54.17	0.30	18.46	11.07	0.94	80133.31
1	2.60	12.73	49.14	1.04	18.88	10.78	0.94	80819.31
2	2.63	12.82	51.98	1.07	17.62	11.08	0.94	81191.09
3	2.90	12.47	50.88	0.92	18.02	10.74	0.94	84544.16
4	2.54	13.77	54.01	1.02	17.36	11.06	0.94	83371.52
5	2.23	14.16	50.80	1.30	17.32	10.99	0.94	81921.74
6	3.05	12.17	50.55	1.23	17.18	10.79	0.94	87123.29
7	2.84	12.48	53.79	1.37	17.00	11.07	0.95	82772.73
8	2.71	12.27	52.43	0.91	17.77	10.76	0.97	84152.70
9	2.89	12.31	55.36	0.57	18.52	10.73	0.96	83518.25
10	2.60	13.07	48.67	0.95	17.22	10.96	0.95	83194.51
11	2.72	12.66	53.21	1.24	16.79	11.09	0.95	82687.30
12	2.67	12.48	51.29	1.19	17.10	10.99	0.94	82099.20
13	2.77	15.03	52.13	1.57	16.99	11.00	0.94	82327.54
14	2.87	12.44	53.56	0.55	17.88	10.93	0.94	82235.67
15	2.74	13.28	53.12	0.69	17.67	10.84	0.94	80661.62
16	2.67	12.65	50.83	0.36	18.36	10.62	0.94	82438.57
17	2.62	12.14	49.61	0.33	18.21	10.62	0.94	84717.24
18	3.82	12.40	45.79	0.59	17.80	10.88	0.94	82786.95
19	3.78	12.27	52.49	0.42	18.65	10.66	0.94	84111.85
20	3.29	12.60	51.79	0.33	18.93	10.81	0.94	80688.84
21	2.87	12.87	48.06	1.19	17.08	10.85	0.94	83263.92
22	2.86	13.00	55.11	0.37	18.12	10.50	0.94	85950.91
23	3.52	13.25	61.80	0.21	19.08	10.25	0.94	86620.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.87	12.81	52.11	0.82	17.83	10.84	0.94	83055.53
最 大 值	3.82	15.03	61.80	1.57	19.08	11.09	0.97	87123.29
發生時間	18	13	23	13	23	11		6
最 小 值	2.23	12.01	45.79	0.21	16.79	10.25	0.93	80133.31
發生時間	5	0	18	23	11	23		0
零點偏移(率)	-0.06 %	-0.00 %	-0.02 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	0.62 %	-0.13 %	0.06 %	0.24 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月05日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.06	12.83	54.01	0.40	17.70	10.32	1.35	79475.70
1	7.80	13.82	57.82	0.70	18.41	10.78	1.35	77366.56
2	9.54	13.30	56.68	0.78	17.32	10.49	1.37	80124.22
3	7.65	13.41	59.43	0.97	16.77	10.69	1.41	79439.81
4	9.62	14.28	61.34	0.99	16.53	10.86	1.41	78857.93
5	7.53	14.22	56.34	1.05	16.10	10.58	1.38	78615.11
6	9.57	14.57	59.47	1.27	15.89	10.79	1.38	78479.69
7	8.31	12.30	52.27	1.77	14.45	10.96	1.40	72564.79
8	10.62	11.92	50.00	1.50	15.95	10.31	1.37	75463.54
9	8.65	11.89	53.34	0.77	18.01	9.79	1.39	80478.76
10	9.65	12.39	53.72	0.86	16.53	10.50	1.38	77893.84
11	9.46	13.04	52.33	1.28	16.16	10.48	1.36	78374.95
12	10.39	12.88	45.43	1.36	17.09	9.45	1.36	76697.19
13	7.91	11.34	50.06	0.90	16.16	9.76	1.36	76665.68
14	12.62	12.47	57.49	1.41	17.11	9.96	1.36	80180.42
15	9.08	12.29	50.72	1.04	16.97	9.87	1.36	78507.92
16	6.68	13.75	52.15	0.47	18.10	9.65	1.33	79506.12
17	10.20	12.88	53.31	0.85	17.50	9.77	1.37	82621.19
18	8.01	12.15	55.40	0.80	18.43	9.53	1.36	84390.86
19	10.74	12.47	56.74	0.91	17.60	9.76	1.35	82817.78
20	7.76	12.01	57.45	0.68	18.04	9.46	1.38	81399.77
21	8.26	12.53	50.40	0.90	16.76	9.80	1.39	79711.98
22	8.48	13.72	52.28	0.70	17.94	9.57	1.37	81759.93
23	8.71	14.20	58.83	0.88	17.17	10.01	1.36	81014.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.85	12.94	54.46	0.97	17.03	10.13	1.37	79266.99
最 大 值	12.62	14.57	61.34	1.77	18.43	10.96	1.43	84390.86
發生時間	14	6	4	7	18	7		18
最 小 值	5.06	11.34	45.43	0.40	14.45	9.45	1.31	72564.79
發生時間	0	13	12	0	7	12		7
零點偏移(率)	-0.07 %	-0.08 %	-0.04 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	-0.25 %	0.61 %	0.21 %	0.91 %		0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								