

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.50	11.10	55.76	0.64	18.63	11.15	1.05	76010.97
1	7.48	21.47	48.37	1.51	18.00	11.46	1.05	73121.56
2	8.21	5.75	56.41	1.64	17.30	11.90	1.05	70531.08
3	6.76	2.06	56.01	0.84	19.12	11.22	1.05	74932.75
4	6.62	3.58	60.38	0.75	19.09	11.58	1.05	72508.46
5	13.01	4.66	53.34	2.11	18.61	11.09	1.03	72886.11
6	8.92	3.74	59.47	1.30	19.01	11.08	1.03	76137.37
7	5.55	4.80	70.60	0.80	19.08	11.86	1.05	70302.22
8	6.68	4.61	62.13	0.77	19.23	11.08	1.07	75636.91
9	8.81	4.51	56.75	1.13	19.36	11.19	1.06	74678.95
10	9.09	3.85	55.67	1.19	18.97	11.18	1.03	74932.96
11	8.52	3.68	60.45	0.87	19.86	10.92	1.03	76083.47
12	8.04	4.71	55.05	0.79	19.60	10.60	1.03	78500.49
13	5.05	7.86	59.78	0.54	19.81	9.98	1.05	83254.65
14	9.72	7.04	33.41	1.73	18.63	10.53	1.03	78768.19
15	9.01	8.64	42.79	1.65	17.56	11.24	1.02	73867.52
16	9.67	11.65	42.42	1.10	18.58	10.96	1.02	75534.28
17	9.00	10.14	46.64	0.65	19.19	10.88	1.02	76944.55
18	6.71	9.87	51.62	0.89	18.57	11.25	1.03	75006.47
19	8.16	7.97	42.45	0.86	19.34	10.57	1.02	79003.66
20	9.57	6.67	34.83	1.56	18.26	10.59	1.02	78121.01
21	9.00	12.06	44.95	1.23	17.45	11.62	1.02	71698.75
22	9.88	7.51	50.08	1.15	18.68	11.01	1.04	76322.85
23	8.30	6.98	44.19	1.58	17.77	11.02	1.03	76534.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.34	7.29	51.81	1.14	18.74	11.08	1.04	75471.66
最大值	13.01	21.47	70.60	2.11	19.86	11.90	1.10	83254.65
發生時間	5	1	7	5	11	2		13
最小值	5.05	2.06	33.41	0.54	17.30	9.98	1.02	70302.22
發生時間	13	3	14	13	2	13		7
零點偏移(率)	-0.04 %	-0.01 %	-0.01 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.41 %	-0.69 %	0.00 %		0.06		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.94	7.45	55.02	1.66	18.43	10.13	0.97	86225.44
1	1.82	7.86	57.72	2.38	17.89	10.57	0.98	83270.19
2	3.31	4.48	56.03	1.31	19.46	10.15	0.99	84486.83
3	4.86	9.27	43.11	1.56	19.45	9.79	0.99	86999.59
4	2.53	4.17	54.82	1.83	17.86	10.26	0.98	85219.18
5	4.38	3.72	57.35	1.53	18.77	9.90	0.99	86696.96
6	4.33	4.90	45.93	2.44	18.09	9.84	0.97	82891.28
7	1.22	5.77	51.52	2.34	17.23	10.44	0.97	82883.32
8	2.67	2.91	51.66	1.68	18.63	10.06	0.97	86467.54
9	8.69	3.59	47.62	2.84	16.77	10.25	0.97	86877.67
10	7.19	5.26	52.64	2.75	17.28	10.36	0.97	85120.13
11	7.23	2.48	63.52	1.62	18.35	10.60	0.97	82036.67
12	6.72	3.18	55.15	1.81	17.66	10.11	0.97	86566.86
13	10.02	4.31	55.64	2.66	15.99	10.49	0.97	85455.53
14	8.61	6.59	62.26	2.98	15.27	10.74	0.98	83726.33
15	10.36	5.27	58.12	2.64	16.04	10.69	0.97	83301.70
16	8.61	9.85	56.99	2.06	16.78	10.61	0.97	83180.59
17	9.06	2.98	48.06	2.52	16.06	10.65	0.97	84101.85
18	11.37	2.67	50.78	3.18	15.01	10.74	0.97	84311.15
19	9.18	4.02	53.46	2.65	14.90	10.60	0.97	85955.61
20	9.24	6.21	59.26	2.07	15.61	10.49	0.97	85884.15
21	8.90	6.43	50.66	2.40	14.93	10.91	0.97	82812.21
22	6.79	7.71	50.82	1.63	16.25	10.78	0.98	82787.43
23	6.54	9.11	55.37	1.71	16.57	10.84	0.98	81931.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.44	5.42	53.90	2.18	17.05	10.42	0.97	84549.58
最大值	11.37	9.85	63.52	3.18	19.46	10.91	0.99	86999.59
發生時間	18	16	11	18	2	21		3
最小值	0.94	2.48	43.11	1.31	14.90	9.79	0.97	81931.68
發生時間	0	11	3	2	19	3		23
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	0.00 %		0.04		-0.20 %
全幅偏移(率)	0.57 %	0.03 %	-0.23 %	0.03 %		-0.22		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.94	12.17	50.62	1.16	15.99	10.95	0.97	76403.05
1	1.11	18.06	52.18	1.15	16.26	11.16	0.97	78294.77
2	2.51	6.65	51.46	1.53	15.52	11.27	0.97	77716.96
3	1.84	3.56	41.79	1.03	16.20	10.76	0.96	78934.04
4	2.17	3.60	46.64	1.16	15.59	11.05	0.97	75243.87
5	5.34	2.98	54.45	1.28	16.49	10.96	0.97	79931.60
6	5.68	3.25	51.96	1.18	18.14	10.38	0.97	82285.60
7	8.08	5.82	44.50	1.11	16.56	11.10	0.93	74073.07
8	6.48	5.59	41.58	1.23	16.90	10.51	0.92	79560.19
9	7.48	3.16	47.98	1.59	15.86	10.85	0.92	78373.51
10	6.14	2.52	43.88	1.67	15.20	10.97	0.93	75891.36
11	8.78	2.36	51.19	2.02	15.08	11.12	0.94	77901.35
12	6.96	2.52	50.90	1.35	16.03	10.91	0.94	79782.13
13	6.80	5.15	49.59	1.49	16.14	10.66	0.94	81247.68
14	7.79	4.77	55.26	2.31	14.02	11.41	0.94	76942.29
15	4.88	6.82	49.50	1.92	14.34	11.06	0.95	77832.10
16	10.41	5.84	56.30	2.93	14.00	11.19	0.94	76274.80
17	6.44	6.78	58.07	1.00	17.24	10.79	0.94	80066.97
18	6.25	4.70	43.27	1.06	16.80	10.41	0.93	80081.79
19	8.11	8.33	32.18	1.09	15.76	10.33	0.92	77265.57
20	7.14	4.07	52.29	1.03	16.82	10.71	0.94	77781.77
21	3.82	9.85	42.32	0.97	16.01	10.73	0.94	79296.17
22	8.50	6.89	46.26	1.91	15.08	10.92	0.94	79377.86
23	9.97	7.20	43.79	2.32	14.52	10.62	0.92	77750.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.07	5.94	48.25	1.48	15.86	10.87	0.94	78262.87
最大值	10.41	18.06	58.07	2.93	18.14	11.41	0.98	82285.60
發生時間	16	1	17	16	6	14		6
最小值	1.11	2.36	32.18	0.97	14.00	10.33	0.91	74073.07
發生時間	1	11	19	21	16	19		7
零點偏移(率)	-0.01 %	-0.06 %	-0.06 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.04 %	-0.87 %	-0.03 %		0.02		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								