

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.96	11.92	56.73	1.23	18.44	11.20	0.99	80745.66
1	9.32	12.33	51.44	2.23	17.39	11.93	0.99	75319.37
2	7.12	11.02	61.46	1.46	18.34	11.47	1.00	78197.20
3	9.56	12.87	52.85	2.13	16.89	11.56	0.99	79202.69
4	9.02	12.46	48.63	2.57	17.24	11.47	0.99	78462.24
5	8.18	12.67	47.93	2.11	17.16	11.56	1.03	78551.12
6	8.74	12.61	44.26	2.57	16.04	11.49	1.03	77209.98
7	9.62	14.85	46.63	2.97	16.12	11.67	1.03	74094.20
8	8.32	11.45	55.27	2.06	17.90	11.49	1.03	78604.55
9	8.71	7.07	52.21	2.27	16.73	11.77	1.02	77506.95
10	9.10	7.05	54.16	2.57	16.34	11.79	1.02	77680.45
11	7.27	6.39	47.59	2.76	16.49	11.64	1.01	78449.21
12	5.05	5.69	61.65	1.56	18.36	11.54	1.02	78264.57
13	4.55	7.18	66.75	0.94	18.56	11.52	1.02	77973.42
14	8.85	7.28	46.76	1.85	17.47	11.66	1.02	77585.98
15	7.79	7.11	53.26	1.43	19.75	11.04	1.02	81205.85
16	7.26	10.04	45.02	1.68	17.34	11.66	1.01	77915.29
17	5.78	8.88	46.38	1.62	16.88	11.85	1.01	75983.96
18	7.32	7.52	50.23	2.21	16.25	11.89	1.01	74864.57
19	8.76	6.32	50.28	1.91	17.05	11.36	1.02	76472.14
20	7.50	9.84	49.99	1.90	17.75	11.62	1.05	75157.88
21	4.52	9.26	59.92	0.74	20.00	11.02	1.05	81091.56
22	8.20	8.93	52.05	1.58	17.33	11.72	1.02	77140.54
23	9.79	14.76	49.69	2.11	17.89	11.49	1.02	78373.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.89	9.81	52.13	1.94	17.49	11.56	1.02	77752.19
最大值	9.79	14.85	66.75	2.97	20.00	11.93	1.07	81205.85
發生時間	23	7	13	7	21	1		15
最小值	4.52	5.69	44.26	0.74	16.04	11.02	0.99	74094.20
發生時間	21	12	6	21	6	21		7
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	0.14 %	-0.03 %	0.30 %		-0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.05	5.83	48.25	2.33	17.01	10.53	1.02	83895.99
1	3.40	7.12	67.82	1.42	18.54	11.10	1.02	79065.30
2	5.36	8.39	49.69	2.13	16.87	10.66	1.02	84298.06
3	5.33	6.74	52.43	2.87	17.08	10.63	1.02	84071.77
4	3.14	5.83	54.66	2.10	16.98	10.58	1.02	84288.55
5	7.05	7.65	55.64	2.95	15.70	10.85	1.02	82441.15
6	11.64	8.04	45.14	4.12	15.22	10.49	0.99	77449.85
7	8.72	12.73	44.12	3.22	14.96	10.34	1.00	80776.91
8	6.98	19.23	41.45	2.96	16.02	9.93	1.00	81044.54
9	9.55	4.19	44.77	2.61	16.30	10.33	0.99	83497.62
10	8.07	5.76	45.49	3.22	14.85	10.54	1.00	79332.56
11	6.59	10.31	50.64	1.94	18.12	9.74	0.99	84085.49
12	3.73	8.89	38.84	1.97	16.99	9.69	0.99	81470.91
13	4.41	1.95	29.95	2.07	17.70	9.30	1.02	82887.41
14	10.33	3.39	46.72	3.01	17.10	9.81	1.02	82990.35
15	6.45	3.43	56.29	1.95	16.81	9.89	1.02	83281.83
16	7.30	4.65	52.88	2.20	15.99	10.33	1.02	84354.42
17	8.07	12.19	51.24	2.36	16.22	10.53	1.02	83952.19
18	5.70	6.98	55.78	1.96	16.56	10.67	1.02	83953.19
19	3.00	3.99	61.75	1.36	17.12	10.95	0.99	81493.06
20	2.38	5.41	56.54	1.85	17.25	10.43	1.00	85477.11
21	0.64	7.12	55.72	2.08	16.32	10.84	0.99	82448.64
22	3.61	5.29	58.34	1.41	17.06	10.67	0.99	83887.56
23	4.68	4.64	52.97	2.84	15.35	10.87	1.01	83157.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.88	7.07	50.71	2.37	16.59	10.40	1.01	82650.10
最大值	11.64	19.23	67.82	4.12	18.54	11.10	1.03	85477.11
發生時間	6	8	1	6	1	1		20
最小值	0.64	1.95	29.95	1.36	14.85	9.30	0.99	77449.85
發生時間	21	13	13	19	10	13		6
零點偏移(率)	-0.20 %	-0.01 %	-0.05 %	-0.06 %		0.00		-0.20 %
全幅偏移(率)	-0.22 %	-0.04 %	-0.83 %	0.07 %		-0.31		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.47	7.70	57.12	1.81	15.82	11.03	0.93	76890.19
1	4.05	9.55	53.85	1.96	16.85	10.89	0.95	79139.60
2	8.41	12.46	57.08	2.79	15.12	11.13	0.94	79834.65
3	9.13	11.33	54.60	2.67	15.41	10.95	0.94	78136.13
4	9.96	12.82	54.13	3.58	14.26	11.12	0.93	76940.61
5	6.55	9.51	57.86	3.33	13.34	11.28	0.97	75628.58
6	6.27	9.55	52.94	2.75	14.44	10.99	0.98	76539.82
7	8.90	7.98	45.78	3.52	13.45	11.07	0.96	72057.44
8	4.71	12.97	49.28	2.72	14.02	10.88	0.93	70223.05
9	7.48	4.36	40.74	2.73	15.23	10.34	0.92	71466.81
10	8.68	3.62	46.18	3.08	14.84	10.59	0.91	71040.84
11	6.00	5.02	45.10	1.99	16.68	10.11	0.91	72994.13
12	6.86	3.48	44.59	2.54	16.98	9.84	0.90	75570.40
13	7.55	5.26	42.22	3.17	14.71	10.56	0.93	73791.63
14	4.39	4.67	51.56	2.29	14.87	11.34	0.94	69239.90
15	7.43	8.17	47.38	2.49	15.09	10.59	0.94	75621.99
16	9.83	4.86	52.52	2.34	16.36	10.39	0.91	75616.92
17	6.28	6.36	58.54	2.43	16.17	9.68	0.91	77899.44
18	6.21	10.07	49.47	2.97	13.93	10.70	0.92	75147.00
19	4.20	7.56	40.86	2.14	15.01	10.83	0.93	71784.60
20	7.30	5.81	55.00	2.58	15.17	10.68	0.95	74061.87
21	6.50	6.99	55.64	2.32	15.30	10.86	0.97	75247.53
22	1.31	6.05	54.99	1.70	15.89	10.74	0.97	77200.05
23	1.63	11.85	48.66	1.99	15.14	10.89	0.94	74481.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	7.83	50.67	2.58	15.17	10.73	0.94	74856.45
最大值	9.96	12.97	58.54	3.58	16.98	11.34	1.00	79834.65
發生時間	4	8	17	4	12	14		2
最小值	1.31	3.48	40.74	1.70	13.34	9.68	0.89	69239.90
發生時間	22	12	9	22	5	17		14
零點偏移(率)	0.00 %	-0.01 %	-0.14 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.15 %	-0.71 %	0.08 %		0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								