

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.56	6.19	62.71	1.54	19.10	11.11	1.02	80887.64
1	8.58	8.30	56.89	1.91	18.42	11.63	1.02	77123.49
2	7.68	7.87	62.29	1.74	17.67	11.72	1.02	77261.08
3	8.93	8.49	60.74	2.54	16.40	12.12	1.03	74750.33
4	7.76	8.18	56.91	1.59	18.04	12.05	1.05	74238.77
5	10.23	7.94	55.88	2.41	18.07	11.12	1.02	85983.52
6	8.33	5.89	54.81	2.27	17.24	11.65	1.02	77689.95
7	8.59	6.84	61.38	1.76	18.06	11.48	1.05	78439.34
8	9.43	7.01	53.49	2.19	16.87	11.50	1.01	77780.93
9	7.86	7.39	64.66	1.71	17.62	11.68	1.04	75053.67
10	8.80	3.57	50.60	2.23	16.97	10.80	1.01	81370.07
11	7.59	8.61	50.22	3.24	14.99	12.04	1.00	71843.28
12	9.99	4.70	55.69	2.55	16.39	11.50	1.04	76623.02
13	9.81	5.23	51.61	2.80	15.75	11.53	1.02	74482.28
14	10.09	5.65	54.31	2.24	16.67	11.42	1.02	74883.81
15	8.40	5.20	62.63	1.63	17.27	11.50	1.03	76813.79
16	9.90	6.15	47.71	2.47	17.47	11.39	1.03	79074.88
17	8.37	6.41	63.48	1.91	17.60	11.87	1.05	75578.08
18	10.06	7.24	50.20	1.56	17.44	11.74	1.01	77126.89
19	8.15	6.19	63.87	1.31	18.70	11.46	1.01	78061.08
20	9.70	5.89	56.91	1.62	19.38	11.00	1.03	81431.73
21	10.04	10.28	55.57	1.86	17.95	11.42	1.03	78517.90
22	10.14	6.49	63.73	1.59	18.51	11.34	1.04	78979.42
23	9.73	8.48	45.38	2.64	17.49	11.46	1.02	79233.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.03	6.84	56.74	2.05	17.50	11.52	1.03	77634.52
最大值	10.23	10.28	64.66	3.24	19.38	12.12	1.05	85983.52
發生時間	5	21	9	11	20	3		5
最小值	7.59	3.57	45.38	1.31	14.99	10.80	0.99	71843.28
發生時間	11	10	23	19	11	10		11
零點偏移(率)	-0.02 %	-0.04 %	-0.18 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.87 %	0.03 %	0.35 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.90	3.77	60.27	1.02	19.12	10.33	0.99	83871.04
1	5.97	3.98	54.46	1.91	18.69	10.13	0.99	86210.54
2	9.41	4.11	56.03	1.77	18.02	10.50	0.99	83991.40
3	7.40	6.35	50.78	1.69	18.08	10.11	0.99	87200.39
4	3.90	4.08	54.57	1.33	18.18	10.21	0.99	85907.41
5	3.64	4.94	52.36	1.62	18.07	10.32	0.99	85568.56
6	8.20	6.85	54.16	2.83	16.49	10.76	1.00	88739.33
7	6.81	3.50	53.10	2.08	17.99	10.35	1.01	84996.45
8	5.77	3.49	54.34	1.87	17.19	10.64	1.01	82371.06
9	7.59	10.16	53.07	2.11	17.20	10.18	1.00	84850.83
10	8.24	4.89	55.11	2.43	15.19	10.70	1.01	79529.61
11	9.19	4.54	50.03	2.19	16.69	10.22	1.05	83713.54
12	8.91	6.53	52.32	2.08	16.65	10.37	1.04	83657.90
13	15.22	5.19	60.16	3.17	15.62	10.50	1.02	82364.07
14	10.46	6.90	49.25	2.02	17.19	10.11	1.02	83804.59
15	9.62	1.75	53.51	2.35	16.69	10.11	1.02	84721.48
16	9.45	4.88	51.82	1.66	17.74	10.04	1.02	85739.10
17	10.04	2.43	42.74	2.78	16.61	10.48	1.02	85153.58
18	7.20	4.53	50.56	1.94	17.23	10.46	1.01	84466.52
19	6.57	5.23	51.33	1.61	18.13	10.43	0.99	83619.76
20	10.22	5.29	57.40	2.29	18.17	10.20	1.01	85398.01
21	8.61	5.68	47.19	1.71	18.82	10.12	1.01	84556.07
22	8.29	6.77	44.09	2.02	18.04	10.30	1.00	85102.53
23	6.49	14.65	47.82	2.50	17.29	10.54	0.99	83396.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.05	5.44	52.35	2.04	17.46	10.34	1.01	84538.75
最大值	15.22	14.65	60.27	3.17	19.12	10.76	1.07	88739.33
發生時間	13	23	0	13	0	6		6
最小值	3.64	1.75	42.74	1.02	15.19	10.04	0.99	79529.61
發生時間	5	15	17	0	10	16		10
零點偏移(率)	-0.12 %	0.00 %	-0.02 %	0.00 %		0.00		-0.20 %
全幅偏移(率)	0.12 %	0.87 %	0.21 %	0.10 %		-0.17		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	4.70	65.55	2.04	17.55	11.05	0.94	77163.40
1	7.74	4.80	59.08	2.34	17.67	10.94	0.94	77830.24
2	6.46	7.05	52.97	2.44	16.17	10.65	0.95	80317.32
3	6.90	4.77	57.49	2.63	15.75	10.99	0.96	76755.37
4	6.39	5.43	56.64	2.48	15.63	11.13	0.97	77496.18
5	4.12	9.45	56.74	2.31	15.70	10.97	0.97	78861.01
6	5.27	5.90	60.56	2.42	15.30	11.23	0.98	76393.19
7	8.99	4.39	59.00	2.45	15.87	11.22	0.97	74987.63
8	8.98	3.98	58.94	2.36	15.79	11.04	0.98	79005.41
9	9.70	4.36	48.27	2.24	16.94	10.52	0.97	78946.19
10	9.08	5.38	51.51	2.66	16.73	9.97	0.98	76704.48
11	9.28	4.08	56.62	3.37	14.43	10.87	0.99	71609.14
12	8.59	8.50	55.91	2.41	15.62	10.47	0.96	75240.01
13	8.67	4.44	54.46	2.48	15.73	10.49	0.94	73862.41
14	10.21	5.85	46.45	3.29	15.47	10.11	0.92	73661.36
15	9.22	2.32	58.22	2.46	15.97	10.65	0.92	72590.58
16	6.59	12.12	50.44	1.87	16.53	10.87	0.93	72863.39
17	8.91	5.03	51.18	2.62	15.03	10.65	0.97	75082.44
18	8.31	4.86	60.56	2.16	15.75	11.29	0.95	73505.22
19	5.81	5.61	53.78	1.88	16.27	11.14	0.93	76215.60
20	7.94	12.14	50.45	2.51	15.20	11.04	0.94	74960.30
21	9.15	4.68	55.05	2.12	16.53	10.93	0.97	75472.63
22	9.73	7.05	59.41	2.41	16.95	10.53	0.97	78198.91
23	9.04	7.97	47.90	2.38	15.80	10.75	0.97	77940.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.05	6.04	55.30	2.43	16.02	10.81	0.96	76069.30
最大值	10.21	12.14	65.55	3.37	17.67	11.29	1.02	80317.32
發生時間	14	20	0	11	1	18		2
最小值	4.12	2.32	46.45	1.87	14.43	9.97	0.91	71609.14
發生時間	5	15	14	16	11	10		11
零點偏移(率)	-0.04 %	-0.01 %	-0.23 %	-0.06 %		0.00		0.00 %
全幅偏移(率)	-0.75 %	-0.03 %	-0.10 %	0.25 %		0.39		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								