

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.32	7.69	57.36	1.17	19.38	11.19	1.02	75258.36
1	8.09	8.05	55.17	1.49	19.15	11.40	1.02	73733.26
2	9.63	8.88	56.22	1.06	20.08	10.67	1.03	78371.61
3	9.44	6.59	57.08	1.45	19.34	10.96	1.03	76761.77
4	10.43	7.72	47.31	1.62	18.80	10.70	1.03	79046.59
5	9.38	9.88	58.50	1.01	19.35	11.02	1.02	75329.45
6	9.20	8.02	58.62	1.32	18.46	11.20	1.02	75844.26
7	8.81	8.40	50.88	1.62	17.42	11.53	1.02	74092.29
8	6.93	7.68	54.51	1.13	18.99	11.24	1.01	74754.64
9	8.93	7.79	57.80	1.56	18.10	11.39	0.99	74646.42
10	8.64	7.26	57.42	1.55	17.14	11.63	0.99	73869.89
11	8.90	7.67	61.68	1.65	16.19	12.02	0.99	71351.30
12	6.86	9.10	57.41	1.45	16.49	12.05	1.00	71298.22
13	5.98	6.09	55.29	1.64	16.94	11.79	1.00	73829.23
14	5.72	5.21	58.10	1.32	17.52	11.80	0.99	73820.58
15	5.65	4.97	58.88	1.01	17.06	11.68	0.99	74369.75
16	8.65	5.38	59.35	1.72	15.72	11.95	0.99	72697.89
17	7.82	5.62	58.82	0.92	17.62	11.52	1.01	74273.81
18	7.22	5.54	62.41	1.09	17.74	11.53	1.02	73393.23
19	1.64	5.21	61.49	0.51	19.52	11.00	1.05	75970.60
20	4.30	5.32	49.37	1.08	18.51	11.08	1.02	76106.74
21	8.75	5.90	44.29	1.59	17.70	11.55	1.02	73177.48
22	8.79	5.54	50.57	1.08	18.40	11.28	1.02	74782.00
23	7.82	6.21	56.49	0.93	18.86	11.62	1.03	71108.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.79	6.91	56.04	1.29	18.10	11.41	1.01	74495.33
最大值	10.43	9.88	62.41	1.72	20.08	12.05	1.08	79046.59
發生時間	4	5	18	16	2	12		4
最小值	1.64	4.97	44.29	0.51	15.72	10.67	0.99	71108.48
發生時間	19	15	21	19	16	2		23
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	-0.53 %	1.26 %	-0.18 %	0.19 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.95	5.26	60.82	1.56	18.71	10.23	1.00	85209.64
1	2.11	6.18	52.42	2.07	17.46	10.55	0.99	84283.24
2	4.41	6.51	58.62	2.06	17.33	10.34	1.01	86236.62
3	7.87	5.63	50.51	1.77	17.93	9.91	1.02	88294.62
4	7.74	6.13	59.96	1.49	18.69	10.19	1.02	85799.02
5	9.23	6.92	50.77	2.25	17.80	10.17	1.01	86756.85
6	9.75	4.72	55.20	2.22	17.16	10.50	1.05	86427.22
7	8.89	5.65	54.16	1.70	18.04	9.96	1.05	87488.27
8	9.40	6.18	45.98	1.72	18.11	9.98	1.05	87185.43
9	9.44	5.52	57.95	1.79	17.68	9.95	1.05	88158.12
10	8.98	6.77	51.87	2.36	15.66	10.38	1.05	86682.97
11	7.49	8.42	66.90	2.14	15.62	11.29	1.05	79571.55
12	7.13	6.72	56.10	1.72	16.58	10.67	1.05	84167.65
13	3.93	4.61	50.16	1.38	17.44	10.30	1.05	85349.90
14	4.00	2.89	64.02	1.30	17.64	10.19	1.06	86324.79
15	3.31	2.99	50.13	2.25	15.86	10.45	1.06	85848.86
16	3.07	3.11	61.09	2.03	16.03	10.88	1.08	82409.23
17	2.91	3.41	55.90	1.98	16.22	10.91	1.06	82215.43
18	0.87	2.93	62.39	0.69	18.68	10.18	1.05	85388.07
19	1.58	4.10	57.66	0.88	18.76	10.15	1.05	85179.99
20	7.69	4.96	47.88	2.14	16.95	10.05	1.05	87856.64
21	6.94	8.65	55.28	1.26	18.99	9.64	1.05	88204.75
22	5.70	4.83	38.73	0.80	19.59	9.92	1.05	86066.78
23	13.49	4.64	42.33	1.48	20.75	9.32	1.06	89374.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.33	5.32	54.45	1.71	17.65	10.25	1.04	85853.33
最大值	13.49	8.65	66.90	2.36	20.75	11.29	1.10	89374.27
發生時間	23	21	11	10	23	11		23
最小值	0.87	2.89	38.73	0.69	15.62	9.32	0.99	79571.55
發生時間	18	14	22	18	11	23		11
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.02 %		0.04		-0.20 %
全幅偏移(率)	0.37 %	0.36 %	-0.62 %	0.14 %		0.25		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.51	6.36	45.06	1.30	18.31	10.00	0.99	83992.45
1	5.67	6.27	40.62	1.23	17.63	10.69	0.98	78618.45
2	5.48	5.35	55.05	1.14	18.20	10.63	0.99	80923.37
3	10.27	12.09	51.25	1.55	16.60	10.71	0.99	82218.24
4	8.76	5.24	49.51	1.59	17.43	10.64	0.99	82415.96
5	9.30	5.11	48.61	1.61	18.16	10.30	0.99	84686.05
6	8.68	5.26	54.09	1.43	18.24	10.49	1.00	81122.74
7	2.99	4.19	41.25	1.14	16.83	10.85	0.98	85622.03
8	9.01	3.22	55.49	1.66	18.69	9.98	0.98	84116.82
9	5.95	8.26	46.34	1.37	19.79	9.20	0.95	84774.65
10	9.48	9.84	58.04	1.69	17.81	10.01	0.97	84022.89
11	9.23	3.57	40.44	1.48	17.05	10.32	0.97	82160.96
12	7.49	1.93	50.36	1.33	17.53	10.49	0.97	80202.35
13	4.02	5.42	46.77	1.36	15.69	10.85	0.97	76844.83
14	1.66	6.76	48.97	1.05	16.28	10.55	0.97	75800.63
15	1.72	2.63	49.71	2.02	14.47	11.31	0.97	73720.51
16	0.52	4.48	53.85	1.10	16.41	10.78	0.97	78223.64
17	1.35	5.13	48.52	1.47	15.02	10.99	0.97	75633.90
18	1.44	4.15	55.58	0.96	17.45	10.52	0.98	80310.50
19	3.10	4.66	50.65	1.24	16.51	10.56	0.99	81647.54
20	8.42	4.94	53.67	1.59	16.09	10.84	0.99	79309.85
21	7.23	4.57	51.15	1.22	17.49	10.31	0.98	83689.99
22	8.97	4.39	58.66	1.30	17.62	10.50	0.97	82723.53
23	8.90	5.22	47.37	1.33	17.66	10.32	0.98	86084.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	5.38	50.04	1.38	17.21	10.49	0.98	81202.77
最大值	10.27	12.09	58.66	2.02	19.79	11.31	1.01	86084.64
發生時間	3	3	22	15	9	15		23
最小值	0.52	1.93	40.44	0.96	14.47	9.20	0.94	73720.51
發生時間	16	12	11	18	15	9		15
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	-0.04 %	0.04 %	-0.47 %	0.03 %		0.42		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								