

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月29日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.67	2.06	50.56	0.07	17.32	10.82	1.23	85228.68
1	8.69	5.74	62.00	2.02	18.03	11.41	1.24	79859.00
2	9.62	12.83	55.48	2.58	17.44	11.23	1.24	82166.73
3	9.78	12.86	58.69	2.47	17.04	11.39	1.24	81917.69
4	6.91	12.71	62.27	2.36	17.04	11.27	1.25	82443.35
5	5.60	12.87	54.91	3.33	16.88	11.41	1.25	80521.16
6	12.01	12.89	59.04	3.00	17.14	11.24	1.25	82148.63
7	7.34	7.66	58.59	1.89	17.53	11.31	1.25	81377.30
8	10.08	11.40	44.95	1.70	17.80	11.25	1.25	81439.20
9	9.02	11.53	47.18	1.67	16.91	11.47	1.25	80218.68
10	9.51	11.63	50.12	1.70	16.67	11.58	1.25	79394.17
11	9.96	11.71	48.00	2.01	16.20	11.71	1.25	78795.63
12	8.31	12.13	47.34	2.14	15.16	11.83	1.25	79129.91
13	9.61	11.77	50.50	2.09	15.64	11.59	1.25	80133.05
14	10.85	11.96	50.52	2.57	15.05	11.48	1.24	81783.01
15	15.06	12.71	56.29	3.16	14.53	11.91	1.24	78736.19
16	8.19	11.80	51.50	2.17	15.99	11.42	1.25	82177.12
17	8.86	11.63	47.88	2.19	17.59	10.98	1.25	83893.91
18	10.43	11.37	44.48	1.63	18.25	10.66	1.25	86026.77
19	8.15	11.54	49.00	2.46	16.69	11.07	1.25	84089.82
20	10.22	11.26	49.80	3.14	17.00	10.92	1.25	84774.22
21	9.33	11.58	51.68	2.71	18.15	10.74	1.25	84988.91
22	8.57	11.48	46.63	2.69	16.98	10.81	1.25	85692.27
23	8.67	11.94	44.75	1.85	18.51	10.98	1.25	82932.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.35	11.13	51.76	2.23	16.90	11.27	1.25	82077.84
最 大 值	15.06	12.89	62.27	3.33	18.51	11.91	1.26	86026.77
發生時間	15	6	4	5	23	15		18
最 小 值	5.60	2.06	44.48	0.07	14.53	10.66	1.22	78736.19
發生時間	5	0	18	0	15	18		15
零點偏移(率)	-0.03 %	0.01 %	-0.03 %	-0.01 %		0.02	-0.01	0.10 %
全幅偏移(率)	0.34 %	0.11 %	0.19 %	-0.25 %		0.23	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年07月29日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.39	13.19	44.16	0.24	15.71	11.79	0.90	77243.27
1	6.33	13.24	48.62	2.17	16.42	11.82	0.90	76623.94
2	2.56	14.63	60.19	1.86	15.34	12.73	0.94	70218.42
3	6.68	12.06	42.32	2.68	16.66	10.82	0.91	85072.99
4	8.02	12.41	45.47	2.89	15.59	10.92	0.90	84270.83
5	7.87	13.18	51.83	2.59	14.71	11.94	0.91	76743.22
6	7.88	12.59	55.66	1.63	16.25	11.38	0.94	78759.75
7	11.39	12.23	60.38	2.10	17.78	10.89	0.94	82614.85
8	8.05	12.12	56.42	1.97	17.67	10.82	0.94	82856.05
9	6.45	12.21	61.80	1.17	18.85	10.56	0.94	84412.33
10	5.97	12.62	50.19	1.56	17.44	10.83	0.94	83455.07
11	4.31	13.06	61.71	1.67	15.65	11.58	0.97	78713.66
12	5.72	14.12	57.32	2.31	14.56	11.93	0.94	76634.04
13	9.63	13.52	55.66	2.04	15.59	11.90	0.94	75860.44
14	10.56	12.77	52.64	1.71	16.44	11.33	0.94	79968.48
15	12.07	13.38	52.57	2.65	15.75	11.36	0.93	80510.18
16	13.13	12.91	58.19	2.13	15.80	11.66	0.94	77709.98
17	10.18	12.70	56.28	1.17	17.66	11.08	0.94	81138.60
18	8.64	13.08	50.77	1.32	17.93	10.66	0.94	84056.66
19	17.47	12.71	59.52	2.26	16.78	11.08	0.94	81722.08
20	7.02	12.49	62.93	1.31	17.48	11.08	0.94	81153.41
21	15.29	12.88	41.00	3.09	16.97	11.11	0.94	80723.22
22	6.53	12.65	55.54	1.75	18.18	10.87	0.94	81384.41
23	8.23	13.19	49.83	0.84	18.64	11.27	0.95	78627.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.60	12.91	53.79	1.88	16.66	11.31	0.93	80019.71
最 大 值	17.47	14.63	62.93	3.09	18.85	12.73	1.00	85072.99
發生時間	19	2	20	21	9	2		3
最 小 值	2.56	12.06	41.00	0.24	14.56	10.56	0.90	70218.42
發生時間	2	3	21	0	12	9		2
零點偏移(率)	-0.09 %	-0.08 %	-0.01 %	-0.01 %		0.01	-0.01	-0.10 %
全幅偏移(率)	0.57 %	-0.06 %	0.47 %	-0.67 %		0.16	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

