

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.81	1.03	64.09	3.26	19.15	11.39	1.52	76395.70
1	5.02	0.83	57.00	3.00	20.04	11.28	1.51	76037.47
2	7.40	0.78	64.82	2.84	20.64	11.20	1.48	76194.69
3	8.69	2.11	57.02	3.27	19.38	11.24	1.45	76470.63
4	10.45	2.97	60.11	2.90	20.63	10.75	1.45	79430.77
5	11.59	2.24	60.35	3.28	19.65	10.81	1.46	77903.81
6	7.64	3.68	60.76	3.42	18.94	11.47	1.45	75523.12
7	10.30	4.08	54.14	3.35	19.17	11.15	1.43	77315.89
8	10.15	1.89	54.64	3.59	18.28	11.35	1.45	76463.15
9	11.24	1.53	61.50	3.71	18.02	11.59	1.46	75507.24
10	9.66	1.08	57.19	3.47	18.98	11.21	1.42	77636.02
11	10.30	1.75	60.09	3.55	18.62	11.42	1.42	76239.65
12	10.02	2.60	54.49	3.66	17.64	11.61	1.46	75280.13
13	10.51	1.41	57.15	3.45	19.02	11.36	1.46	75480.49
14	10.42	1.21	62.45	3.06	20.61	10.85	1.45	77780.95
15	11.66	4.47	47.72	3.92	18.54	11.21	1.46	76996.58
16	10.75	2.55	59.98	3.69	18.57	11.59	1.46	73667.39
17	8.52	2.25	58.39	3.66	18.41	11.83	1.46	72715.87
18	9.84	1.72	64.06	3.29	19.56	11.09	1.46	76899.76
19	9.67	1.37	60.49	3.30	19.02	11.26	1.45	76541.12
20	9.90	1.16	59.26	3.26	19.69	11.13	1.44	77220.63
21	8.32	1.03	65.56	3.16	20.25	11.07	1.43	77043.65
22	9.77	1.30	59.35	3.38	19.90	11.34	1.41	75413.10
23	7.96	4.07	65.69	3.52	19.23	11.75	1.41	73201.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.44	2.05	59.43	3.37	19.25	11.29	1.45	76223.31
最大值	11.66	4.47	65.69	3.92	20.64	11.83	1.55	79430.77
發生時間	15	15	23	15	2	17		4
最小值	5.02	0.78	47.72	2.84	17.64	10.75	1.40	72715.87
發生時間	1	2	15	2	12	4		17
零點偏移(率)	-0.02 %	-0.02 %	-0.00 %	0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	3.04 %	0.25 %	-0.54 %	0.37 %		0.39	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.20	1.51	51.34	2.03	17.24	10.09	1.44	64820.89
1	9.00	3.80	63.68	1.92	18.08	10.32	1.42	66893.64
2	9.08	1.51	60.43	1.95	17.27	10.72	1.40	63805.47
3	9.04	1.43	59.20	1.86	16.25	10.92	1.39	64351.65
4	4.99	1.22	65.81	1.96	15.57	11.32	1.38	62212.78
5	4.45	1.51	60.82	1.82	16.80	11.20	1.41	62893.79
6	7.52	6.98	58.29	2.25	14.61	11.12	1.43	74809.51
7	8.81	5.39	64.57	2.15	15.72	10.84	1.44	65500.24
8	10.68	2.33	58.16	2.51	14.99	10.88	1.43	64175.58
9	9.77	1.85	61.27	2.56	14.58	11.18	1.38	63142.64
10	10.10	0.78	56.91	2.22	15.74	10.92	1.38	65635.60
11	11.43	2.45	64.44	2.57	14.98	11.25	1.40	63599.84
12	9.91	1.13	60.65	2.29	15.74	11.07	1.42	64427.93
13	10.06	1.41	62.06	2.30	15.75	11.07	1.37	62758.94
14	10.29	2.11	61.47	2.30	15.82	11.13	1.36	62799.80
15	7.07	3.75	61.97	2.10	15.79	11.04	1.37	63546.09
16	10.97	6.28	58.66	2.63	14.69	11.02	1.38	62498.75
17	7.96	0.77	64.92	1.93	17.01	10.37	1.39	64573.80
18	10.89	1.07	52.69	1.89	19.03	9.73	1.41	69770.13
19	9.38	1.91	65.05	2.20	16.43	10.69	1.43	65184.48
20	8.23	2.44	56.56	2.28	15.66	10.80	1.42	63990.28
21	10.43	1.80	61.54	2.21	16.57	10.83	1.41	64916.31
22	10.63	1.58	53.38	2.18	17.54	10.34	1.38	67933.23
23	9.29	3.49	59.45	1.64	18.48	10.41	1.38	66737.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.09	2.44	60.14	2.16	16.26	10.80	1.40	65040.79
最大值	11.43	6.98	65.81	2.63	19.03	11.32	1.45	74809.51
發生時間	11	6	4	16	18	4		6
最小值	4.45	0.77	51.34	1.64	14.58	9.73	1.36	62212.78
發生時間	5	17	0	23	9	18		4
零點偏移(率)	0.00 %	0.00 %	-0.00 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	2.44 %	0.07 %	-0.38 %	0.32 %		0.23	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.96	1.15	64.22	2.59	14.38	10.84	1.73	80318.21
1	7.21	1.82	61.47	1.93	16.80	10.46	1.74	84333.56
2	6.25	1.74	54.75	1.92	16.29	10.44	1.73	81228.34
3	5.62	1.23	67.33	1.92	16.02	10.37	1.75	83560.98
4	7.77	3.74	61.22	2.57	13.92	11.10	1.76	80442.82
5	10.21	1.09	66.94	2.17	15.91	10.71	1.76	87389.73
6	10.98	1.50	57.94	2.26	15.08	10.76	1.74	84706.59
7	13.23	2.27	64.27	2.36	16.02	10.37	1.73	92230.06
8	8.85	1.24	65.13	2.62	14.79	10.94	1.75	81909.11
9	10.45	1.29	65.41	2.59	15.23	10.77	1.77	85201.82
10	8.08	5.59	56.71	2.52	14.38	10.69	1.77	82810.75
11	16.42	2.85	63.65	3.38	13.75	10.82	1.77	81120.34
12	9.97	1.22	64.77	2.47	16.11	10.40	1.77	84220.03
13	11.00	1.86	55.07	2.45	14.76	10.63	1.80	81899.15
14	8.15	1.34	67.47	2.49	15.15	10.64	1.80	80472.99
15	7.88	2.65	59.93	2.39	15.47	10.51	1.80	82797.77
16	6.57	4.06	57.27	2.59	14.51	10.67	1.79	80715.62
17	5.61	1.41	63.62	2.67	14.64	10.84	1.77	79364.73
18	6.62	1.19	69.19	2.43	16.10	10.92	1.77	81930.83
19	9.27	1.84	65.03	2.19	16.71	10.51	1.77	87302.77
20	10.63	8.01	61.64	2.55	14.96	10.81	1.77	83785.09
21	8.58	4.32	60.16	2.62	14.89	10.76	1.74	80490.89
22	10.34	2.16	59.99	2.28	15.94	10.60	1.74	82153.50
23	7.97	3.15	63.38	2.16	16.22	10.42	1.73	85421.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.07	2.45	62.36	2.42	15.33	10.67	1.76	83158.64
最大值	16.42	8.01	69.19	3.38	16.80	11.10	1.81	92230.06
發生時間	11	20	18	11	1	4		7
最小值	5.61	1.09	54.75	1.92	13.75	10.37	1.72	79364.73
發生時間	17	5	2	2	11	3		17
零點偏移(率)	-0.01 %	-0.01 %	0.00 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.40 %	0.21 %	-0.38 %	0.17 %		0.37	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								