

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.66	12.77	70.32	3.30	15.29	11.43	1.20	81506.71
1	5.95	13.92	57.36	3.07	16.31	11.24	1.21	81451.55
2	9.95	12.65	63.77	3.81	15.53	11.29	1.20	80291.81
3	12.51	13.03	48.15	4.37	14.26	11.41	1.22	80687.23
4	10.18	13.22	46.94	4.06	14.82	11.06	1.22	83304.39
5	7.73	13.74	59.08	3.56	15.10	12.11	1.20	75468.81
6	7.48	14.41	58.43	2.65	15.43	11.57	1.20	79970.82
7	12.06	12.71	58.95	3.40	15.32	11.01	1.20	82882.13
8	12.25	11.74	66.83	3.82	14.02	11.52	1.19	79365.66
9	9.18	11.80	48.37	3.50	13.66	11.62	1.19	77684.57
10	7.21	12.59	48.57	3.13	14.23	11.76	1.19	75703.18
11	6.31	14.14	44.95	3.28	13.45	11.86	1.18	75373.15
12	2.94	12.69	51.18	2.82	13.68	12.00	1.19	73103.17
13	5.63	13.46	60.45	3.02	13.26	12.00	1.20	75164.45
14	10.89	13.53	62.06	2.95	14.08	12.25	1.19	73382.16
15	10.07	13.61	60.26	2.74	14.23	12.28	1.19	74446.36
16	8.51	12.82	60.13	2.39	14.60	11.52	1.19	82090.96
17	11.98	12.12	53.83	2.53	15.69	11.34	1.19	82729.34
18	8.33	12.46	48.16	3.40	16.04	11.27	1.19	83145.98
19	9.31	13.40	55.80	2.35	15.81	11.46	1.18	81552.39
20	8.76	13.01	60.56	3.37	15.49	11.48	1.18	80888.40
21	10.01	12.97	52.48	3.96	14.21	11.49	1.19	80540.68
22	11.19	13.13	52.00	3.03	14.60	11.60	1.19	79312.98
23	4.61	13.18	55.44	2.64	16.08	11.55	1.19	80521.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.95	13.05	56.00	3.21	14.80	11.59	1.19	79190.35
最 大 值	12.51	14.41	70.32	4.37	16.31	12.28	1.23	83304.39
發生時間	3	6	0	3	1	15		4
最 小 值	2.94	11.74	44.95	2.35	13.26	11.01	1.18	73103.17
發生時間	12	8	11	19	13	7		12
零點偏移(率)	-0.02 %	-0.01 %	-0.21 %	-0.02 %		0.00		0.10 %
全幅偏移(率)	1.40 %	-1.76 %	0.07 %	-0.69 %		0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月18日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.40	11.23	62.24	2.95	17.30	9.02	1.33	81442.72
1	7.01	15.10	55.84	2.00	19.29	8.39	1.33	78680.31
2	6.31	9.99	58.21	3.44	18.06	8.19	1.34	79775.24
3	6.28	12.15	64.09	3.06	16.74	8.93	1.31	76662.35
4	9.33	13.67	48.96	3.17	16.63	9.04	1.29	75858.29
5	16.37	14.08	56.01	4.12	16.26	9.15	1.31	78290.96
6	4.76	14.36	53.47	1.23	17.28	8.89	1.31	77511.35
7	3.97	17.28	55.17	3.28	16.41	9.89	1.32	78509.74
8	3.27	11.61	54.35	3.59	17.28	9.27	1.35	78396.54
9	10.49	11.82	56.20	4.42	16.87	9.27	1.34	79124.31
10	12.31	12.19	70.30	2.57	16.94	10.01	1.33	80012.24
11	9.00	12.30	50.64	2.24	15.33	10.20	1.31	79210.04
12	7.48	12.06	51.11	2.02	17.65	9.43	1.34	77160.07
13	9.74	12.33	49.58	2.11	16.31	9.83	1.34	79648.59
14	7.28	13.04	53.58	2.14	16.04	10.70	1.34	78524.25
15	6.25	12.91	49.47	3.71	18.15	9.23	1.33	76692.35
16	10.52	13.10	44.76	3.89	19.76	7.59	1.29	77706.09
17	5.34	12.33	46.44	2.19	19.77	7.58	1.33	76957.87
18	3.30	12.64	46.35	3.07	19.40	7.68	1.34	75902.27
19	4.57	12.33	46.30	3.78	19.28	7.85	1.33	76585.93
20	4.91	12.44	46.27	2.16	18.94	7.69	1.32	75304.50
21	8.34	10.49	58.46	1.55	17.72	8.25	1.33	75024.17
22	11.29	11.30	61.99	2.21	17.62	9.61	1.35	81539.73
23	9.56	10.97	56.92	2.45	19.36	8.94	1.33	84013.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.75	12.57	54.03	2.81	17.68	8.94	1.33	78272.21
最 大 值	16.37	17.28	70.30	4.42	19.77	10.70	1.36	84013.10
發生時間	5	7	10	9	17	14		23
最 小 值	3.27	9.99	44.76	1.23	15.33	7.58	1.27	75024.17
發生時間	8	2	16	6	11	17		21
零點偏移(率)	-0.09 %	-0.01 %	-0.23 %	-0.02 %		-0.01		0.20 %
全幅偏移(率)	1.67 %	-1.33 %	0.20 %	-0.85 %		0.24		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								