

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.26	13.05	55.58	0.90	18.67	11.46	1.25	79111.79
1	9.05	12.78	45.69	0.93	20.21	10.83	1.26	82811.58
2	10.22	12.67	46.48	1.58	17.46	11.03	1.25	83581.13
3	10.04	12.71	58.20	1.58	16.21	11.42	1.26	81486.07
4	9.36	12.68	52.84	1.48	17.14	11.14	1.26	83043.02
5	5.99	12.94	67.25	2.08	18.64	11.32	1.21	81745.79
6	9.91	12.95	55.34	3.08	18.54	10.85	1.19	84474.51
7	9.04	12.02	58.27	2.85	17.81	10.71	1.20	85730.73
8	9.45	12.13	60.94	2.37	18.48	10.76	1.20	84918.39
9	9.68	11.76	61.61	2.70	18.37	10.39	1.21	87398.74
10	9.92	12.98	50.54	3.17	16.58	11.46	1.22	80006.09
11	9.64	12.84	57.57	3.35	16.23	11.32	1.25	82352.94
12	15.12	13.03	51.84	3.45	16.55	11.38	1.25	78357.53
13	9.65	13.38	53.84	3.22	16.37	11.51	1.24	71826.41
14	10.44	13.07	66.75	1.77	19.48	11.31	1.24	70841.96
15	9.01	12.52	40.38	3.04	18.45	10.84	1.21	74368.77
16	11.04	12.57	53.88	2.71	17.66	11.19	1.20	73208.54
17	8.49	12.22	51.77	2.67	17.88	10.88	1.19	75195.15
18	9.08	12.29	49.40	3.12	17.58	10.96	1.19	75063.11
19	10.08	12.23	53.77	2.47	18.14	10.83	1.21	75563.00
20	9.67	12.77	51.55	3.29	17.32	11.00	1.21	74834.71
21	8.27	12.89	54.59	4.00	17.51	10.97	1.24	74915.09
22	8.19	12.77	56.54	1.07	18.05	10.90	1.23	75054.95
23	9.69	12.21	51.57	2.64	16.55	11.40	1.20	73169.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.60	12.64	54.42	2.48	17.75	11.08	1.22	78710.82
最大值	15.12	13.38	67.25	4.00	20.21	11.51	1.27	87398.74
發生時間	12	13	5	21	1	13		9
最小值	5.99	11.76	40.38	0.90	16.21	10.39	1.18	70841.96
發生時間	5	9	15	0	3	9		14
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.00 %		-0.06	-0.01	0.30 %
全幅偏移(率)	-1.48 %	-1.91 %	-0.48 %	-0.33 %		0.34	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	19.32	11.73	49.47	1.13	20.13	9.73	0.95	83276.60
1	9.70	10.88	47.80	1.11	21.40	9.24	0.97	81704.46
2	11.47	11.99	45.93	0.80	20.41	9.30	0.97	80084.82
3	12.80	12.32	35.12	1.32	18.09	9.85	0.97	79532.09
4	10.03	11.48	50.86	0.74	18.69	9.71	0.99	78877.87
5	10.92	11.69	32.97	0.88	19.59	9.51	0.95	77717.94
6	6.37	16.48	36.08	1.57	18.10	10.49	0.92	77094.40
7	11.71	9.20	43.00	1.63	17.69	10.17	0.92	75961.69
8	9.46	12.50	60.03	1.70	17.15	11.13	0.92	70627.70
9	10.41	12.58	64.01	1.02	18.12	11.11	0.92	70784.22
10	9.60	12.15	59.77	2.00	16.64	12.09	0.93	63839.21
11	15.97	11.76	37.08	1.67	18.24	10.44	0.94	78905.85
12	17.08	11.61	49.27	1.50	18.13	10.23	0.95	81601.86
13	9.41	12.16	56.63	1.61	18.08	10.53	0.94	78198.91
14	8.29	11.84	41.56	0.84	20.18	9.98	0.95	77637.23
15	9.78	11.76	44.72	1.48	20.10	9.62	0.96	81433.71
16	8.37	11.76	41.78	1.49	19.15	10.14	0.98	78533.52
17	10.00	12.13	48.49	1.69	20.12	9.85	0.98	80631.54
18	9.64	11.67	40.27	0.85	21.26	9.47	0.97	78599.04
19	9.31	11.89	28.53	1.71	19.97	9.27	0.94	83680.17
20	11.21	12.26	56.63	2.44	19.93	9.70	0.95	82672.51
21	9.80	10.97	52.98	1.66	20.15	9.42	0.94	79458.45
22	9.31	11.81	57.99	1.85	19.37	9.66	0.95	78712.94
23	9.37	14.36	50.81	1.78	19.95	9.63	0.94	81999.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.81	12.04	47.16	1.44	19.19	10.01	0.95	78398.60
最大值	19.32	16.48	64.01	2.44	21.40	12.09	0.99	83680.17
發生時間	0	6	9	20	1	10		19
最小值	6.37	9.20	28.53	0.74	16.64	9.24	0.90	63839.21
發生時間	6	7	19	4	10	1		10
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.03 %		-0.11	-0.01	0.00 %
全幅偏移(率)	-1.05 %	-0.05 %	0.15 %	0.10 %		-0.30	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.22	11.09	53.70	2.86	19.70	9.50	1.36	77537.64
1	7.23	11.23	54.10	2.84	20.01	9.67	1.36	76580.32
2	9.37	11.06	50.34	3.16	18.79	9.50	1.38	77108.36
3	8.35	11.23	53.61	3.18	18.08	9.84	1.37	75895.48
4	8.67	11.18	52.89	2.97	18.74	9.80	1.36	77335.77
5	9.38	11.33	51.12	3.21	18.13	9.76	1.36	75996.06
6	8.66	11.34	51.01	3.04	18.11	9.74	1.36	76942.66
7	10.42	12.23	51.58	3.74	17.53	10.02	1.36	79068.63
8	8.99	11.51	60.22	3.22	18.14	10.09	1.35	77408.25
9	9.84	11.57	53.77	3.49	17.70	10.09	1.35	76944.16
10	7.83	11.40	53.59	2.97	17.67	9.82	1.35	76736.57
11	8.65	11.37	55.06	2.99	18.10	9.78	1.34	76147.95
12	10.35	12.81	57.69	3.88	17.55	10.00	1.34	75319.82
13	8.93	11.26	54.14	0.59	17.71	9.83	1.36	76457.58
14	8.59	11.45	56.75	0.62	18.29	9.81	1.35	76343.88
15	9.19	11.31	55.08	0.62	18.98	9.76	1.33	77061.04
16	9.54	11.41	57.18	0.68	19.33	9.45	1.35	79060.84
17	8.91	11.24	56.80	0.61	18.22	9.82	1.35	77732.67
18	9.10	12.51	55.37	0.60	18.47	9.77	1.32	76398.92
19	10.92	14.62	65.29	0.70	19.62	10.48	1.32	76579.39
20	8.63	13.87	53.28	0.61	18.47	9.76	1.31	81507.41
21	8.97	14.21	56.98	0.63	17.69	10.20	1.33	77524.93
22	7.75	14.49	57.60	0.67	17.75	10.14	1.34	74585.21
23	9.64	13.97	50.41	0.63	16.95	9.91	1.32	76037.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.01	12.07	54.90	2.02	18.32	9.86	1.35	77012.98
最大值	10.92	14.62	65.29	3.88	20.01	10.48	1.39	81507.41
發生時間	19	19	19	12	1	19		20
最小值	7.23	11.06	50.34	0.59	16.95	9.45	1.31	74585.21
發生時間	1	2	2	13	23	16		22
零點偏移(率)	-0.10 %	-0.01 %	-0.04 %	0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	-0.70 %	0.72 %	0.07 %	0.49 %		0.27	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								