

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.97	12.80	51.07	1.60	17.52	11.50	1.34	80871.42
1	6.56	12.06	53.89	1.67	17.52	11.52	1.34	81719.80
2	6.50	11.87	37.77	2.49	15.66	11.62	1.34	82473.58
3	6.53	11.87	49.55	2.11	15.46	11.72	1.34	81223.10
4	6.63	11.98	49.15	2.85	14.59	11.91	1.34	80442.50
5	6.23	11.79	42.69	1.44	16.92	11.39	1.34	83564.45
6	6.81	11.89	49.44	2.60	15.55	11.68	1.34	81531.52
7	7.16	11.88	50.13	2.60	15.87	11.61	1.34	82037.46
8	6.78	12.30	53.63	2.25	16.04	11.92	1.34	78883.01
9	6.48	12.08	54.15	1.55	16.55	11.54	1.34	81884.00
10	8.68	12.12	51.79	2.14	15.04	11.88	1.34	79803.14
11	9.18	12.06	57.57	1.37	16.34	11.71	1.33	80682.82
12	8.95	11.82	50.48	1.85	16.41	11.47	1.32	82153.22
13	9.84	12.39	47.70	2.48	15.45	11.95	1.33	79315.42
14	9.51	12.17	59.04	1.77	16.16	11.72	1.34	80537.07
15	13.43	12.08	52.43	3.06	15.81	11.54	1.34	81755.42
16	7.61	13.47	43.28	3.51	15.81	11.42	1.34	82854.64
17	5.40	12.88	45.11	2.29	17.32	11.23	1.34	83086.90
18	7.09	12.02	51.84	1.88	17.21	11.22	1.33	83332.84
19	7.35	12.87	58.43	1.71	16.50	12.07	1.31	77577.26
20	6.95	11.59	63.87	1.08	18.53	10.90	1.31	85483.96
21	7.64	12.11	41.47	2.07	17.23	11.20	1.31	84286.09
22	7.80	13.23	45.47	1.82	17.25	11.32	1.31	82899.89
23	7.81	12.00	67.81	1.34	16.89	11.57	1.31	81511.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.54	12.22	51.16	2.06	16.40	11.57	1.33	81662.95
最大值	13.43	13.47	67.81	3.51	18.53	12.07	1.35	85483.96
發生時間	15	16	23	16	20	19		20
最小值	3.97	11.59	37.77	1.08	14.59	10.90	1.30	77577.26
發生時間	0	20	2	20	4	20		19
零點偏移(率)	-0.03 %	0.01 %	-0.02 %	-0.01 %		-0.06	-0.01	0.30 %
全幅偏移(率)	-1.92 %	1.04 %	-1.26 %	-0.70 %		0.08	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.10	12.09	65.04	0.92	18.36	10.52	1.10	79265.21
1	10.71	12.97	63.68	2.26	16.52	11.11	1.10	78841.83
2	8.27	12.01	40.83	1.62	16.51	10.67	1.09	77070.27
3	6.40	14.67	38.70	2.97	14.45	10.76	1.09	73018.82
4	7.87	12.46	40.85	2.50	16.57	10.45	1.09	77287.93
5	6.79	11.78	53.03	1.36	17.71	10.40	1.09	75388.75
6	5.23	12.60	43.14	1.33	17.01	10.23	1.07	74813.27
7	4.81	12.84	35.73	2.05	16.91	10.37	1.08	75305.95
8	4.77	12.15	47.38	1.85	16.46	10.83	1.10	78061.56
9	5.48	11.99	51.08	2.01	16.35	10.75	1.10	79210.76
10	6.13	11.80	57.18	1.81	16.91	10.51	1.10	77862.68
11	6.31	11.52	55.62	1.43	16.81	10.28	1.09	78801.50
12	7.21	11.48	53.40	2.06	16.42	10.24	1.09	77812.93
13	8.02	11.44	56.21	1.87	17.21	10.16	1.09	78316.34
14	8.15	11.86	52.85	2.33	15.28	10.43	1.09	75989.09
15	11.83	12.90	52.78	2.50	15.66	10.55	1.09	76741.32
16	9.12	11.94	48.92	2.54	15.59	10.39	1.09	79188.14
17	8.17	12.18	40.30	2.95	17.41	10.00	1.09	80350.06
18	10.25	11.87	50.34	1.66	17.94	10.20	1.09	78380.02
19	9.78	12.93	52.47	1.29	18.97	9.71	1.09	82567.13
20	9.01	11.74	55.49	1.46	17.81	9.82	1.09	81467.83
21	7.07	11.43	48.27	1.72	17.89	10.05	1.09	79525.51
22	5.69	11.86	35.11	1.65	17.45	10.07	1.09	78331.91
23	5.62	12.08	39.85	1.73	17.76	10.11	1.09	80924.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.66	12.19	49.09	1.91	16.92	10.36	1.09	78105.12
最大值	11.83	14.67	65.04	2.97	18.97	11.11	1.10	82567.13
發生時間	15	3	0	3	19	1		19
最小值	4.77	11.43	35.11	0.92	14.45	9.71	1.06	73018.82
發生時間	8	21	22	0	3	19		3
零點偏移(率)	-0.11 %	-0.02 %	-0.04 %	0.00 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-0.08 %	-1.24 %	-0.46 %	-1.36 %		-0.16	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.76	11.42	47.16	2.41	18.26	9.66	1.39	72978.17
1	12.89	11.77	62.76	2.67	17.91	10.29	1.39	70925.40
2	11.34	11.54	62.18	2.98	16.64	10.36	1.39	71863.69
3	12.31	11.89	66.26	3.02	15.34	10.82	1.39	68477.51
4	11.83	11.91	60.17	2.80	15.69	10.72	1.38	71004.83
5	12.39	11.57	58.71	3.08	15.95	10.43	1.39	71923.13
6	11.65	11.58	58.87	3.02	16.70	10.36	1.38	73042.59
7	2.87	11.75	51.37	0.92	15.57	10.67	1.39	68401.63
8	11.55	11.63	57.59	1.24	16.81	10.41	1.39	72045.55
9	12.33	11.68	54.93	1.52	15.43	10.46	1.39	72197.65
10	11.50	12.79	48.81	2.43	16.34	9.89	1.39	71533.21
11	11.64	12.36	40.02	1.98	17.35	9.25	1.38	71477.95
12	12.11	11.19	36.26	1.61	16.90	9.37	1.38	70863.98
13	11.98	11.37	39.41	1.55	16.26	9.58	1.39	70297.63
14	12.57	13.15	38.07	2.06	17.22	9.09	1.39	72061.88
15	12.06	12.62	37.19	2.20	16.53	9.26	1.38	71045.83
16	11.92	13.07	30.17	1.34	18.25	8.82	1.36	73094.50
17	12.42	12.29	24.92	1.14	19.54	8.60	1.36	74652.61
18	11.43	11.86	29.05	1.20	17.83	8.73	1.37	73882.23
19	9.98	12.06	39.08	2.11	16.86	9.80	1.37	73572.69
20	11.72	10.89	42.17	1.66	18.34	9.37	1.38	75175.44
21	12.18	11.17	46.38	2.31	18.00	9.66	1.39	74660.01
22	11.92	11.37	36.82	1.97	17.25	9.65	1.40	74486.53
23	11.64	11.73	43.59	2.55	16.72	9.94	1.39	72350.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.50	11.86	46.33	2.07	16.99	9.80	1.38	72167.30
最大值	12.89	13.15	66.26	3.08	19.54	10.82	1.41	75175.44
發生時間	1	14	3	5	17	3		20
最小值	2.87	10.89	24.92	0.92	15.34	8.60	1.36	68401.63
發生時間	7	20	17	7	3	17		7
零點偏移(率)	-0.04 %	0.00 %	-0.04 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-1.20 %	-1.45 %	0.54 %	-0.56 %		0.15	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								