

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月17日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.11	2.53	49.04	1.64	16.12	11.65	1.25	81744.65
1	9.06	2.72	50.20	1.72	18.25	11.19	1.25	83894.82
2	9.80	2.65	49.68	2.30	16.28	11.37	1.25	84165.77
3	9.93	2.57	49.29	2.25	16.02	11.45	1.25	83872.62
4	8.54	4.79	45.06	2.75	14.76	11.85	1.25	81083.32
5	11.13	3.37	49.99	3.08	13.67	12.16	1.23	75969.56
6	9.50	2.51	55.14	2.03	14.84	11.98	1.23	80700.34
7	9.87	2.53	53.31	2.36	14.84	11.79	1.23	82398.77
8	9.49	2.60	41.72	2.10	15.65	11.50	1.23	83909.16
9	10.05	2.72	35.34	2.47	14.63	11.68	1.23	82490.82
10	8.37	2.58	39.03	1.80	15.71	11.63	1.23	82155.20
11	8.46	2.64	37.48	2.19	15.38	11.72	1.21	82388.01
12	4.55	5.01	49.37	1.37	16.47	11.61	1.18	82246.96
13	11.34	4.86	42.32	2.93	15.32	11.53	1.19	84316.14
14	9.63	3.05	36.29	2.23	15.73	11.61	1.21	82912.36
15	8.38	4.63	38.95	2.79	14.92	11.91	1.20	80872.51
16	5.03	2.93	41.02	1.65	15.78	11.70	1.20	82321.20
17	7.31	3.00	56.33	0.75	18.50	11.46	1.23	81452.95
18	8.69	3.55	47.66	1.17	17.45	11.11	1.23	85564.71
19	11.09	7.85	37.67	2.84	14.81	11.61	1.23	83654.51
20	14.70	7.30	39.85	2.89	13.55	12.01	1.23	80416.79
21	11.19	2.81	38.87	1.13	14.69	11.88	1.23	81218.10
22	9.55	2.96	43.17	1.29	14.51	12.10	1.23	80163.44
23	13.87	2.60	45.38	1.51	15.49	11.72	1.23	82460.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.53	3.53	44.67	2.05	15.56	11.68	1.23	82182.22
最 大 值	14.70	7.85	56.33	3.08	18.50	12.16	1.25	85564.71
發生時間	20	19	17	5	17	5		18
最 小 值	4.55	2.51	35.34	0.75	13.55	11.11	1.18	75969.56
發生時間	12	6	9	17	20	18		5
零點偏移(率)	-0.33 %	-0.00 %	-0.06 %	0.00 %		0.00		0.30 %
全幅偏移(率)	-0.33 %	0.63 %	0.06 %	-0.05 %		0.00		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月17日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.92	2.50	55.44	2.18	14.00	11.36	1.17	80874.32
1	5.80	2.77	65.05	2.94	15.32	11.48	1.18	80784.66
2	9.30	2.23	65.73	2.40	15.38	10.85	1.18	85540.15
3	9.19	2.37	61.66	2.68	14.55	10.99	1.18	86167.46
4	8.92	1.97	60.89	2.78	13.30	11.40	1.18	82818.93
5	6.26	1.71	60.45	3.20	13.07	11.42	1.18	83999.34
6	9.06	1.94	49.65	3.23	13.31	11.33	1.18	81685.25
7	8.08	1.88	49.48	2.78	13.67	11.26	1.18	84707.23
8	8.52	1.26	50.54	2.84	13.97	11.14	1.18	84895.32
9	9.22	1.07	52.29	3.25	12.79	11.36	1.18	84158.01
10	7.31	9.47	56.85	3.00	12.63	11.91	1.14	77526.87
11	12.10	17.37	53.84	3.10	13.69	11.76	1.10	75873.69
12	18.28	19.86	64.27	3.91	13.18	12.04	1.10	76356.54
13	13.27	7.72	55.19	2.12	13.87	11.83	1.10	76339.02
14	14.21	24.02	62.31	2.17	13.97	11.63	1.09	80399.14
15	14.70	12.16	57.81	2.25	13.25	11.83	1.09	79653.20
16	8.00	7.96	53.47	1.94	13.68	12.35	1.10	77312.97
17	15.18	6.43	49.00	1.54	17.62	10.16	1.10	83788.12
18	15.58	2.01	63.83	2.04	16.95	10.39	1.14	86596.40
19	14.72	7.55	58.49	3.12	13.27	10.81	1.15	84888.16
20	12.69	1.30	62.68	2.65	13.96	10.82	1.15	82961.56
21	11.51	1.72	55.17	2.28	13.83	10.74	1.13	81813.75
22	11.96	1.63	57.74	1.96	13.54	11.17	1.13	80429.59
23	15.66	2.16	49.00	3.56	13.28	11.27	1.13	79477.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.19	5.88	57.12	2.66	14.00	11.30	1.14	81626.98
最 大 值	18.28	24.02	65.73	3.91	17.62	12.35	1.18	86596.40
發生時間	12	14	2	12	17	16		18
最 小 值	5.80	1.07	49.00	1.54	12.63	10.16	1.09	75873.69
發生時間	1	9	17	17	10	17		11
零點偏移(率)	-0.35 %	-0.01 %	-0.35 %	-0.10 %		0.02		0.10 %
全幅偏移(率)	0.14 %	-0.06 %	0.11 %	0.13 %		-0.04		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月17日

[illegible]