

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年06月10日

報表日期: 113年06月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.68	8.52	50.31	0.76	19.86	10.43	1.03	88112.00
1	8.91	3.29	45.69	1.37	19.83	11.08	1.02	83263.00
2	11.33	3.54	45.71	1.84	18.63	11.21	1.05	83558.04
3	11.19	3.07	49.02	1.79	18.34	11.40	1.05	82483.34
4	10.21	3.76	54.32	1.46	18.78	11.38	1.05	82022.52
5	6.58	4.61	40.46	0.79	20.63	10.54	1.02	85921.15
6	7.53	4.34	45.66	0.86	19.36	10.89	1.02	85482.19
7	11.41	3.79	53.46	1.32	19.15	10.84	1.01	85894.37
8	12.36	3.42	53.43	1.41	18.96	10.93	0.99	85103.30
9	9.92	3.19	55.31	0.97	20.24	10.93	1.01	84012.29
10	7.59	5.09	61.51	0.54	20.58	10.58	1.02	86790.12
11	9.28	5.79	41.20	1.53	17.34	11.32	1.02	81442.85
12	6.55	5.07	55.69	1.08	17.96	11.43	1.02	80724.96
13	5.61	4.95	52.03	1.53	17.37	11.59	1.01	78898.71
14	11.24	7.69	57.91	1.29	19.51	10.99	1.00	83064.35
15	10.38	2.32	44.97	1.81	16.68	11.18	1.00	80090.50
16	5.56	5.15	49.03	1.23	17.45	11.42	1.00	79323.14
17	6.90	6.32	52.93	0.76	18.05	11.55	1.00	78600.82
18	1.69	6.88	62.72	0.59	18.81	12.00	1.01	75939.54
19	5.32	7.01	52.52	0.83	18.95	11.22	1.02	82967.72
20	7.75	5.07	53.95	1.28	17.32	11.30	1.02	82910.98
21	7.38	6.35	47.19	1.40	17.05	11.41	1.02	81106.35
22	6.77	4.76	52.82	0.93	18.73	11.17	1.02	82856.11
23	5.77	5.94	55.04	1.52	17.79	11.76	1.03	77529.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.16	5.00	51.37	1.20	18.64	11.19	1.02	82420.75
最 大 值	12.36	8.52	62.72	1.84	20.63	12.00	1.06	88112.00
發生時間	8	0	18	2	5	18		0
最 小 值	1.69	2.32	40.46	0.54	16.68	10.43	0.99	75939.54
發生時間	18	15	5	10	15	0		18
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	0.00 %		-0.27		0.10 %
全幅偏移(率)	0.00 %	0.22 %	-0.21 %	1.22 %		0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	4.07	43.11	1.18	19.74	10.01	1.02	86298.17
1	6.92	6.64	51.69	1.50	19.54	10.31	1.02	85019.38
2	6.81	3.55	56.39	0.77	20.05	10.26	1.02	84238.05
3	6.68	4.27	36.70	1.27	18.51	10.40	1.01	84774.60
4	8.36	3.60	45.58	1.39	18.55	10.87	0.99	80853.62
5	7.65	3.83	51.45	1.43	18.53	10.52	1.01	83783.85
6	2.23	2.65	48.82	1.13	18.13	10.75	1.02	80660.78
7	6.15	3.37	49.07	2.38	16.43	11.49	1.02	78017.08
8	8.23	3.15	49.13	1.23	19.20	10.45	1.02	83319.17
9	7.01	3.48	54.84	0.96	19.11	10.19	1.02	85975.01
10	5.76	2.43	40.76	1.39	17.93	10.89	1.02	81182.90
11	5.03	2.14	51.51	2.20	15.73	11.45	1.02	79062.30
12	5.09	2.68	53.99	1.56	17.44	11.14	1.02	79859.50
13	5.13	4.20	47.08	1.76	18.18	10.74	1.02	81753.18
14	8.65	3.61	41.55	3.08	16.19	11.18	1.02	80251.92
15	11.02	4.83	51.29	2.64	15.77	11.44	1.02	78710.33
16	12.03	3.79	50.72	3.33	15.57	11.77	1.03	75890.93
17	5.35	5.27	43.09	2.87	16.72	11.24	1.02	79321.32
18	7.96	2.41	42.10	2.24	17.95	10.78	1.02	82601.42
19	5.49	6.06	40.54	2.61	17.44	11.22	1.01	79084.83
20	4.66	3.27	39.03	1.85	18.45	10.62	1.02	83341.70
21	6.27	3.03	39.60	1.91	18.05	10.73	1.02	82718.94
22	6.41	3.58	51.35	1.20	18.63	11.30	1.02	77451.63
23	5.51	6.28	43.97	1.37	21.61	9.79	1.00	86021.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.80	3.84	46.81	1.80	18.06	10.81	1.02	81674.67
最 大 值	12.03	6.64	56.39	3.33	21.61	11.77	1.05	86298.17
發生時間	16	1	2	16	23	16		0
最 小 值	2.23	2.14	36.70	0.77	15.57	9.79	0.99	75890.93
發生時間	6	11	3	2	16	23		16
零點偏移(率)	-0.29 %	-0.00 %	-0.01 %	0.00 %		-0.07		-0.20 %
全幅偏移(率)	0.00 %	0.43 %	0.02 %	0.38 %		0.06		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年06月10日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.34	6.57	48.67	0.32	21.50	9.19	0.93	88034.78
1	3.78	2.62	44.77	0.53	20.57	9.80	0.92	83655.44
2	6.95	5.60	43.90	1.13	18.03	9.97	0.92	81646.08
3	9.13	3.26	43.28	0.92	19.23	10.11	0.92	82611.85
4	10.52	4.44	50.31	1.04	19.73	10.02	0.92	84600.94
5	10.45	2.35	51.46	0.81	18.82	10.50	0.92	80783.33
6	8.22	2.61	46.81	0.63	19.63	9.72	0.92	85082.21
7	4.23	3.14	42.84	0.83	18.57	10.07	0.93	86486.55
8	13.24	4.84	39.70	0.74	19.60	9.90	0.97	82859.83
9	5.83	4.97	42.32	0.53	19.33	10.59	0.97	81926.90
10	3.27	10.45	37.24	0.51	17.11	10.44	0.95	83859.29
11	0.17	2.75	52.69	0.42	16.90	10.94	0.99	77180.44
12	2.36	4.89	53.87	0.67	16.94	10.63	0.99	78795.71
13	0.43	3.08	59.91	0.38	18.18	10.70	0.98	79618.96
14	0.84	3.17	60.03	0.54	18.02	10.67	0.95	79537.79
15	0.94	3.34	54.09	0.55	17.09	10.97	0.93	78246.47
16	2.47	3.13	62.00	0.48	19.06	10.68	0.93	77422.19
17	2.27	3.56	52.70	0.29	20.15	9.87	0.97	81112.99
18	2.58	7.41	50.93	0.36	18.33	10.27	0.99	81047.15
19	4.29	5.96	46.51	0.39	18.42	10.13	0.98	82759.66
20	3.57	7.62	51.04	0.36	18.45	10.27	0.96	80598.62
21	3.64	3.33	48.75	0.19	18.66	10.28	0.93	78511.08
22	3.07	2.63	57.51	0.25	18.62	10.97	0.92	72345.12
23	2.90	4.26	50.43	0.28	19.71	10.18	0.93	81893.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.48	4.42	49.66	0.55	18.78	10.29	0.95	81275.71
最 大 值	13.24	10.45	62.00	1.13	21.50	10.97	1.00	88034.78
發生時間	8	10	16	2	0	15		0
最 小 值	0.17	2.35	37.24	0.19	16.90	9.19	0.90	72345.12
發生時間	11	5	10	21	11	0		22
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	0.00 %		-0.12		0.20 %
全幅偏移(率)	-0.10 %	-0.99 %	-0.05 %	0.16 %		0.30		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								