

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.21	12.99	49.63	1.56	16.89	11.49	1.29	80199.82
1	7.79	13.01	46.92	1.37	17.95	11.34	1.29	81097.46
2	10.97	13.05	53.19	1.80	16.91	11.58	1.29	79215.63
3	11.59	12.53	48.19	3.36	16.25	11.20	1.29	81138.27
4	12.45	12.89	46.88	1.90	16.06	11.45	1.29	79032.29
5	5.63	12.32	42.10	2.62	15.85	11.43	1.29	82102.41
6	12.22	12.87	47.27	1.95	16.91	11.40	1.30	80956.66
7	7.24	12.84	48.59	2.99	16.22	11.35	1.29	81309.21
8	11.81	12.81	50.33	2.73	15.81	11.49	1.29	79263.30
9	13.67	12.96	60.49	2.68	16.42	11.36	1.31	80216.38
10	11.23	13.06	47.71	3.05	15.29	11.51	1.33	80254.00
11	10.38	14.08	60.40	2.01	16.68	12.00	1.34	74782.41
12	14.86	13.73	52.84	3.09	16.43	11.61	1.32	79972.21
13	10.57	13.60	56.08	3.16	16.38	11.73	1.29	77382.51
14	12.83	13.23	50.85	3.05	16.08	11.46	1.29	78456.11
15	8.94	13.20	52.56	2.57	16.59	11.36	1.32	79411.66
16	14.00	13.26	48.73	3.06	15.65	11.42	1.34	81031.41
17	7.93	13.37	60.16	2.80	15.94	11.66	1.31	80553.86
18	9.54	13.59	57.93	2.41	16.85	11.70	1.29	79063.39
19	11.08	14.46	63.42	1.64	17.34	11.88	1.31	77101.54
20	6.82	12.97	51.73	1.78	18.02	10.92	1.33	84303.76
21	9.53	13.34	51.77	2.29	18.66	10.62	1.34	86242.36
22	12.71	13.14	56.22	2.56	17.53	10.93	1.34	84790.43
23	7.93	13.22	52.95	2.57	18.18	10.69	1.34	86079.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.50	13.19	52.37	2.46	16.70	11.40	1.31	80581.54
最大值	14.86	14.46	63.42	3.36	18.66	12.00	1.34	86242.36
發生時間	12	19	19	3	21	11		21
最小值	5.63	12.32	42.10	1.37	15.29	10.62	1.29	74782.41
發生時間	5	5	5	1	10	21		11
零點偏移(率)	-0.01 %	-0.02 %	-0.02 %	-0.01 %		-0.06	-0.01	0.40 %
全幅偏移(率)	-0.84 %	-1.55 %	-0.49 %	-0.57 %		0.14	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.27	11.54	46.16	1.22	16.93	10.15	0.98	80492.94
1	9.40	11.77	50.03	1.23	17.81	10.44	0.98	80333.62
2	10.23	11.75	52.88	1.22	16.99	10.59	0.98	79207.43
3	7.53	11.99	48.79	1.23	17.51	9.96	0.98	79641.12
4	14.13	11.77	47.78	1.35	15.81	10.73	0.98	75026.79
5	6.84	11.21	45.64	0.69	16.46	10.23	0.99	78150.22
6	4.90	11.46	43.06	1.68	17.06	10.17	0.99	80428.71
7	10.07	11.55	42.87	2.35	16.00	10.20	1.00	79724.56
8	12.64	11.96	57.98	2.03	16.37	10.85	1.03	79647.45
9	9.06	12.09	55.09	1.36	17.24	10.80	1.04	79968.17
10	9.84	11.84	50.63	1.74	15.48	10.74	1.04	79512.97
11	10.92	12.49	47.94	1.80	15.55	11.00	1.02	77285.41
12	8.93	12.93	59.53	1.12	16.75	11.30	1.02	74127.51
13	8.72	12.87	58.31	1.31	16.32	11.33	1.01	76944.64
14	校正	校正	校正	校正	替代	校正	1.01	79796.62
15	12.38	12.52	59.82	1.50	16.33	11.09	1.02	80136.48
16	6.61	12.32	52.11	1.76	15.44	11.03	1.03	81817.60
17	9.39	12.39	47.70	1.58	16.27	10.96	1.02	80485.25
18	10.44	12.08	56.91	0.94	18.32	10.46	1.01	83204.07
19	8.47	12.05	48.24	1.52	17.43	10.46	0.99	83785.22
20	15.08	12.56	60.09	2.22	16.23	10.95	1.01	83738.41
21	9.24	12.10	54.23	1.89	17.44	10.53	1.02	84542.84
22	8.46	12.26	58.02	1.27	18.60	10.57	1.03	83967.65
23	11.67	12.40	60.89	0.66	19.96	10.44	1.05	82985.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	9.84	12.08	52.38	1.46	16.88	10.65	1.01	80206.28
最大值	15.08	12.93	60.89	2.35	19.96	11.33	1.06	84542.84
發生時間	20	12	23	7	23	13		21
最小值	4.90	11.21	42.87	0.66	15.44	9.96	0.97	74127.51
發生時間	6	5	7	23	16	3		12
零點偏移(率)	-0.11 %	-0.08 %	-0.06 %	0.00 %		-0.03	-0.01	0.00 %
全幅偏移(率)	0.13 %	0.14 %	0.14 %	0.72 %		0.06	0.00	0.00 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.79	11.11	42.52	2.48	16.48	9.48	1.42	72584.30
1	10.49	12.83	39.58	2.92	18.54	9.05	1.41	75040.12
2	14.74	11.49	38.36	2.44	17.42	8.97	1.41	75199.84
3	10.89	12.27	39.52	2.62	17.71	8.88	1.41	75592.33
4	9.02	10.91	40.02	2.38	17.34	9.00	1.41	74863.24
5	9.41	11.19	37.89	2.34	17.20	9.06	1.41	75097.43
6	9.59	10.94	40.61	2.61	17.47	9.17	1.43	74516.29
7	10.09	11.92	33.38	2.65	18.10	8.81	1.42	74053.93
8	4.72	11.41	39.55	2.53	16.79	9.47	1.42	74092.77
9	5.48	11.25	52.37	2.28	17.86	9.03	1.41	77149.21
10	8.75	11.14	53.86	2.37	18.21	9.10	1.41	76786.96
11	8.40	11.23	58.17	2.34	17.88	9.49	1.40	73907.23
12	8.07	11.43	52.94	2.44	18.12	9.74	1.41	74100.15
13	8.03	11.97	54.68	2.43	17.59	9.66	1.41	75767.01
14	8.00	12.16	52.78	2.50	16.68	9.96	1.40	74163.86
15	7.41	11.38	50.18	2.37	17.14	9.66	1.40	74095.12
16	2.73	11.15	48.99	2.39	17.54	9.37	1.40	76888.96
17	3.13	10.97	54.56	2.55	17.76	9.56	1.41	77105.80
18	3.19	11.25	57.78	2.75	18.86	9.53	1.41	77701.38
19	3.05	12.20	49.19	2.87	18.33	9.32	1.40	80702.70
20	2.54	12.77	61.10	2.67	16.77	9.75	1.38	78430.22
21	9.30	13.16	65.09	2.48	16.79	9.63	1.39	76927.23
22	9.98	13.09	62.56	2.52	17.91	9.67	1.39	78262.28
23	9.47	13.40	68.32	2.87	19.02	9.79	1.39	77155.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.72	11.78	49.75	2.53	17.65	9.38	1.41	75841.00
最大值	14.74	13.40	68.32	2.92	19.02	9.96	1.43	80702.70
發生時間	2	23	23	1	23	14		19
最小值	2.54	10.91	33.38	2.28	16.48	8.81	1.37	72584.30
發生時間	20	4	7	9	0	7		0
零點偏移(率)	-0.07 %	-0.04 %	-0.08 %	-0.01 %		-0.06	-0.01	0.10 %
全幅偏移(率)	-0.49 %	0.43 %	-0.03 %	0.13 %		0.24	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								