

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.45	13.73	55.13	1.64	18.34	11.35	1.22	71090.89
1	11.75	13.85	45.80	3.15	18.47	11.23	1.23	70538.76
2	12.49	13.63	50.35	3.15	17.80	11.62	1.20	69554.82
3	10.33	13.02	51.12	3.63	17.44	11.35	1.20	73287.80
4	7.43	13.84	54.44	2.03	16.97	11.95	1.20	68752.69
5	13.30	13.27	52.55	3.72	18.49	11.15	1.22	75756.88
6	14.82	13.19	60.32	3.53	18.04	10.90	1.22	76077.50
7	7.50	13.59	48.37	2.78	17.40	11.53	1.21	71925.10
8	6.87	13.31	53.81	2.75	19.07	10.97	1.24	74461.77
9	6.68	13.15	56.25	3.14	17.84	11.09	1.24	74491.77
10	3.97	13.40	67.76	1.17	18.23	11.59	1.24	70003.72
11	4.06	13.05	49.50	2.21	16.76	11.51	1.23	71845.87
12	5.94	13.57	47.76	2.41	17.38	11.81	1.22	69042.68
13	3.69	13.60	54.87	1.65	17.22	11.87	1.20	69170.92
14	8.67	13.26	45.56	2.53	16.59	11.60	1.21	71372.85
15	8.43	11.94	50.33	2.27	16.89	11.72	1.23	70193.80
16	6.45	10.49	58.16	1.24	20.03	10.89	1.24	73397.74
17	6.48	10.97	51.11	2.00	18.44	10.89	1.25	74989.64
18	6.37	13.34	43.94	1.64	18.43	11.06	1.24	73897.96
19	6.99	12.81	48.40	2.60	16.75	11.24	1.20	73960.85
20	6.46	12.94	51.40	1.64	18.89	10.83	1.21	74884.29
21	6.38	12.64	44.33	2.02	17.43	11.26	1.21	72940.69
22	6.35	12.58	69.31	1.05	19.86	10.91	1.23	74043.48
23	6.33	12.92	50.37	1.95	18.51	11.09	1.23	72948.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.67	13.00	52.54	2.33	17.97	11.31	1.22	72442.94
最大值	14.82	13.85	69.31	3.72	20.03	11.95	1.25	76077.50
發生時間	6	1	22	5	16	4		6
最小值	3.69	10.49	43.94	1.05	16.59	10.83	1.19	68752.69
發生時間	13	16	18	22	14	20		4
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	-0.01 %		-0.10	-0.01	0.30 %
全幅偏移(率)	1.23 %	0.69 %	-0.26 %	0.57 %		-0.04	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.42	12.53	62.65	1.17	17.28	11.16	0.99	79992.90
1	8.28	13.02	62.23	1.12	18.50	11.32	1.00	77497.21
2	10.81	12.70	57.71	1.10	17.84	11.12	1.01	79524.12
3	11.16	13.27	57.58	1.18	17.76	10.88	1.02	80980.76
4	8.51	13.46	56.14	1.23	17.05	11.36	1.02	78694.67
5	9.15	13.35	58.58	1.07	16.65	11.49	1.02	78794.87
6	9.79	13.25	53.01	2.04	15.13	11.80	0.99	79896.04
7	5.38	13.06	57.56	0.64	17.34	11.42	0.98	78454.33
8	8.27	12.63	53.53	0.87	18.15	10.97	0.97	81451.49
9	3.21	13.22	55.24	1.12	16.92	11.61	0.96	78184.06
10	2.19	13.57	64.50	0.62	17.12	11.81	0.98	75502.65
11	6.35	13.30	56.63	1.00	16.66	11.67	0.98	73054.46
12	8.23	14.43	52.01	1.02	17.36	11.33	0.97	73737.82
13	7.91	13.10	48.04	1.41	16.44	11.22	0.96	78758.55
14	2.28	13.96	56.51	0.96	15.89	12.19	0.95	70121.86
15	4.41	11.61	63.11	1.25	16.38	11.93	0.97	76817.95
16	8.02	9.68	62.74	1.08	16.73	11.92	0.97	77804.30
17	6.95	12.85	55.45	1.74	16.23	11.85	0.97	73001.86
18	6.14	12.31	42.16	2.46	16.94	10.64	0.97	79880.04
19	6.66	12.07	40.59	1.40	18.29	10.40	0.98	82331.11
20	6.56	11.76	48.32	1.10	19.07	10.01	0.97	83146.51
21	6.68	11.47	37.18	0.98	18.27	10.14	0.97	79816.99
22	6.50	11.92	60.97	0.68	19.36	10.09	0.97	81034.62
23	6.46	11.50	47.99	0.32	19.36	10.06	0.97	78624.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.93	12.67	54.60	1.15	17.36	11.18	0.98	78212.64
最大值	11.16	14.43	64.50	2.46	19.36	12.19	1.02	83146.51
發生時間	3	12	10	18	22	14		20
最小值	2.19	9.68	37.18	0.32	15.13	10.01	0.94	70121.86
發生時間	10	16	21	23	6	20		14
零點偏移(率)	0.00 %	0.00 %	-0.05 %	-0.01 %		-0.12	-0.01	-0.20 %
全幅偏移(率)	1.39 %	0.93 %	-0.49 %	0.88 %		-0.25	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.22	11.22	51.85	3.58	18.83	9.20	1.32	74943.83
1	7.04	11.41	58.52	3.48	20.40	9.46	1.36	73498.12
2	9.50	11.07	54.71	2.85	19.03	9.42	1.36	71479.30
3	9.62	11.34	50.42	2.50	18.75	8.60	1.35	75892.69
4	8.98	11.96	52.21	3.91	19.19	9.04	1.33	69919.58
5	9.98	10.31	34.35	2.37	19.24	8.17	1.31	74401.39
6	9.66	11.58	43.02	2.07	18.48	8.69	1.31	72030.51
7	7.85	11.14	41.64	2.70	20.23	8.76	1.38	71137.73
8	10.62	12.37	55.42	3.08	17.61	9.08	1.37	75499.84
9	10.06	11.10	47.88	1.76	17.24	9.82	1.37	72916.38
10	8.88	11.12	48.38	1.73	17.96	9.76	1.36	76428.68
11	9.03	11.41	58.30	1.74	17.63	10.22	1.37	75478.95
12	7.53	11.56	57.91	1.66	17.98	10.27	1.32	71916.38
13	9.88	11.28	46.79	1.62	16.95	9.97	1.32	71884.14
14	7.53	11.17	52.87	1.67	17.39	9.95	1.35	71827.11
15	9.83	11.75	44.97	1.56	16.70	9.96	1.37	72196.94
16	9.18	11.73	52.17	1.67	17.59	9.71	1.36	74388.68
17	8.92	11.44	49.46	1.54	17.36	9.79	1.36	74189.06
18	9.11	11.97	60.72	1.69	17.73	10.11	1.34	71647.99
19	5.73	11.82	51.50	1.59	19.84	9.09	1.32	70708.08
20	8.76	12.26	57.41	1.72	18.45	9.37	1.36	77252.21
21	9.33	11.42	66.16	1.81	18.81	9.54	1.40	76902.00
22	9.67	11.72	59.36	1.70	17.79	9.87	1.39	74534.82
23	8.33	11.65	64.10	1.83	18.75	9.88	1.39	72094.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.84	11.49	52.50	2.16	18.33	9.49	1.35	73465.36
最大值	10.62	12.37	66.16	3.91	20.40	10.27	1.41	77252.21
發生時間	8	8	21	4	1	12		20
最小值	5.73	10.31	34.35	1.54	16.70	8.17	1.31	69919.58
發生時間	19	5	5	17	15	5		4
零點偏移(率)	-0.01 %	-0.10 %	-0.01 %	-0.01 %		-0.11	-0.01	0.10 %
全幅偏移(率)	-1.60 %	0.11 %	-0.63 %	0.12 %		0.25	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								