

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月15日

報表日期: 115年08月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.04	11.78	55.11	2.42	17.20	11.49	1.24	70779.41
1	8.18	11.85	57.56	1.91	19.46	11.00	1.25	73335.66
2	11.36	11.91	58.40	2.79	17.91	11.31	1.23	72666.60
3	7.86	11.58	63.64	2.37	18.16	11.22	1.23	72960.61
4	9.85	11.91	45.01	2.04	17.49	11.18	1.25	73407.22
5	8.79	12.53	51.43	1.71	19.13	10.82	1.25	75038.83
6	8.87	12.87	57.43	2.53	18.82	10.88	1.25	74313.71
7	11.18	12.91	59.80	2.73	17.97	11.28	1.25	72135.51
8	8.08	13.24	63.54	1.87	20.21	10.86	1.25	73236.34
9	9.22	12.82	49.06	2.48	19.24	10.85	1.25	74247.50
10	10.63	14.10	56.17	3.52	17.54	11.12	1.25	71821.91
11	8.82	13.46	45.11	3.06	17.23	11.71	1.25	68842.77
12	10.54	13.14	40.57	3.67	17.00	11.45	1.25	71917.05
13	8.42	13.33	40.23	3.06	16.88	11.61	1.25	70523.45
14	14.02	13.25	40.60	4.20	16.27	11.65	1.25	70700.52
15	5.75	13.39	41.43	3.40	15.85	11.86	1.23	69968.43
16	11.38	13.05	48.60	2.73	17.90	11.44	1.22	72170.56
17	8.79	13.07	46.12	2.67	17.10	11.53	1.25	70901.97
18	9.81	13.23	43.35	3.11	16.54	11.62	1.25	70769.42
19	8.53	13.14	45.79	2.76	17.33	11.48	1.25	71108.50
20	9.45	13.92	52.77	2.43	17.89	11.29	1.25	71758.00
21	8.62	13.01	45.60	2.90	17.26	11.35	1.25	71771.36
22	9.58	13.21	49.07	2.32	18.88	11.04	1.25	72704.10
23	10.71	13.33	47.22	2.19	19.17	10.64	1.25	74934.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.52	12.92	50.15	2.70	17.85	11.28	1.25	72167.25
最 大 值	14.02	14.10	63.64	4.20	20.21	11.86	1.27	75038.83
發生時間	14	10	3	14	8	15		5
最 小 值	5.75	11.58	40.23	1.71	15.85	10.64	1.21	68842.77
發生時間	15	3	13	5	15	23		11
零點偏移(率)	-0.01 %	-0.01 %	-0.11 %	-0.01 %		-0.01	-0.01	0.20 %
全幅偏移(率)	-0.74 %	0.76 %	0.88 %	0.73 %		-0.23	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月15日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.83	11.67	57.51	2.75	19.02	10.11	1.27	77582.43
1	3.70	11.86	53.17	2.63	18.71	10.25	1.27	75335.41
2	5.75	11.76	57.35	3.19	17.61	10.37	1.31	75248.19
3	3.27	11.67	53.49	3.01	18.23	10.08	1.31	74903.14
4	4.79	11.76	45.70	2.97	16.99	9.93	1.31	74514.62
5	3.30	11.23	48.12	2.82	17.65	9.79	1.31	74894.34
6	3.91	12.22	51.58	3.00	18.37	9.91	1.31	72270.21
7	2.97	11.43	44.45	2.68	18.91	9.44	1.28	76215.72
8	3.87	11.63	46.66	2.64	16.95	10.09	1.30	73162.94
9	3.71	12.18	55.96	2.84	17.58	10.71	1.27	68698.66
10	5.28	12.74	46.30	2.78	18.44	9.48	1.30	70568.90
11	4.04	9.90	54.94	2.76	17.55	9.59	1.29	71563.65
12	3.78	9.67	38.48	2.47	18.34	8.63	1.26	70098.74
13	3.53	10.78	39.86	2.63	18.08	8.73	1.25	70149.41
14	3.13	10.58	34.94	2.82	18.69	8.43	1.25	71094.29
15	4.24	8.94	59.53	2.51	17.02	9.20	1.26	70324.87
16	5.45	11.65	52.95	1.57	16.36	10.18	1.27	75654.55
17	7.72	11.67	52.21	1.54	17.07	10.29	1.27	75390.99
18	4.81	11.31	53.41	1.42	17.19	10.13	1.27	72614.55
19	7.99	11.46	53.31	1.56	15.98	10.44	1.30	72197.71
20	3.33	11.57	56.94	1.37	16.13	10.58	1.31	71295.24
21	3.00	11.49	52.86	1.29	17.31	10.31	1.30	71573.50
22	2.59	11.41	52.77	1.27	17.44	10.23	1.27	70437.80
23	3.08	11.77	57.72	2.37	17.72	10.43	1.27	76050.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.29	11.35	50.84	2.37	17.64	9.89	1.28	72993.36
最 大 值	7.99	12.74	59.53	3.19	19.02	10.71	1.32	77582.43
發生時間	19	10	15	2	0	9		0
最 小 值	2.59	8.94	34.94	1.27	15.98	8.43	1.23	68698.66
發生時間	22	15	14	22	19	14		9
零點偏移(率)	-0.15 %	0.01 %	-0.04 %	-0.01 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	-1.96 %	-1.22 %	0.58 %	0.31 %		0.18	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								