

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月13日

| 項目 單位 小時\限標 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
| | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 10.70 | 4.51 | 53.49 | 2.23 | 17.30 | 10.32 | 1.38 | 85180.59 |
| 1 | 8.24 | 5.60 | 48.96 | 1.69 | 19.29 | 9.94 | 1.38 | 83696.02 |
| 2 | 11.03 | 5.45 | 51.36 | 2.34 | 18.06 | 10.04 | 1.39 | 86225.96 |
| 3 | 10.18 | 4.87 | 51.45 | 2.52 | 16.45 | 10.60 | 1.41 | 79947.81 |
| 4 | 9.65 | 8.43 | 51.16 | 2.35 | 18.99 | 9.52 | 1.43 | 83595.48 |
| 5 | 10.73 | 2.70 | 60.36 | 2.29 | 17.80 | 9.84 | 1.42 | 82685.23 |
| 6 | 11.72 | 9.00 | 40.89 | 2.48 | 17.58 | 10.42 | 1.45 | 75200.73 |
| 7 | 9.68 | 7.37 | 52.97 | 1.98 | 18.51 | 9.98 | 1.44 | 82836.61 |
| 8 | 9.21 | 26.49 | 56.57 | 1.81 | 18.93 | 9.32 | 1.42 | 79274.08 |
| 9 | 7.73 | 2.71 | 43.78 | 1.63 | 17.44 | 10.04 | 1.45 | 77529.58 |
| 10 | 10.72 | 2.87 | 55.63 | 2.07 | 16.07 | 10.49 | 1.44 | 82408.39 |
| 11 | 9.30 | 1.83 | 59.48 | 1.67 | 17.26 | 10.59 | 1.43 | 80206.73 |
| 12 | 8.78 | 3.41 | 57.92 | 1.61 | 17.72 | 10.40 | 1.41 | 82537.48 |
| 13 | 4.73 | 5.05 | 49.74 | 1.45 | 17.56 | 10.63 | 1.42 | 77602.67 |
| 14 | 2.30 | 3.62 | 62.90 | 1.38 | 17.98 | 10.71 | 1.43 | 80460.07 |
| 15 | 7.24 | 3.13 | 52.27 | 1.88 | 17.20 | 10.56 | 1.39 | 84749.01 |
| 16 | 8.13 | 3.01 | 53.97 | 1.90 | 16.93 | 10.48 | 1.44 | 84192.73 |
| 17 | 9.15 | 2.78 | 63.85 | 1.89 | 16.65 | 10.70 | 1.42 | 84668.99 |
| 18 | 7.88 | 3.33 | 59.83 | 2.06 | 15.50 | 10.76 | 1.43 | 82831.13 |
| 19 | 6.35 | 3.03 | 54.32 | 1.88 | 16.21 | 10.57 | 1.42 | 83209.84 |
| 20 | 7.72 | 4.61 | 59.88 | 1.89 | 15.89 | 10.82 | 1.41 | 85682.99 |
| 21 | 9.42 | 7.56 | 62.31 | 2.41 | 15.17 | 11.10 | 1.43 | 81815.94 |
| 22 | 8.03 | 3.43 | 58.11 | 1.81 | 16.56 | 10.92 | 1.47 | 83392.90 |
| 23 | 3.75 | 3.73 | 65.82 | 1.24 | 18.43 | 10.99 | 1.48 | 81463.08 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平 均 值 | 8.43 | 5.36 | 55.29 | 1.94 | 17.31 | 10.41 | 1.42 | 82141.42 |
| 最 大 值 | 11.72 | 26.49 | 65.82 | 2.52 | 19.29 | 11.10 | 1.49 | 86225.96 |
| 發生時間 | 6 | 8 | 23 | 3 | 1 | 21 | | 2 |
| 最 小 值 | 2.30 | 1.83 | 40.89 | 1.24 | 15.17 | 9.32 | 1.38 | 75200.73 |
| 發生時間 | 14 | 11 | 6 | 23 | 21 | 8 | | 6 |
| 零點偏移(率) | -0.04 % | -0.01 % | -0.02 % | -0.03 % | | -0.03 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.04 % | 0.03 % | -0.19 % | 0.01 % | | 0.13 | 0.00 | 0.30 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月13日

| 項目 單位 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|----------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 小時\限標 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 0 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 1 | 10.80 | 12.51 | 49.48 | 4.55 | 17.94 | 9.55 | 1.81 | 87318.72 |
| 2 | 9.54 | 4.80 | 59.93 | 2.54 | 15.83 | 10.66 | 1.82 | 87286.89 |
| 3 | 10.43 | 12.71 | 51.69 | 3.88 | 18.09 | 10.09 | 1.82 | 88569.50 |
| 4 | 10.15 | 4.05 | 61.97 | 2.31 | 16.96 | 10.31 | 1.82 | 86604.39 |
| 5 | 10.86 | 7.91 | 53.98 | 2.39 | 15.67 | 10.74 | 1.82 | 86909.79 |
| 6 | 10.94 | 7.68 | 62.16 | 2.54 | 16.17 | 11.00 | 1.82 | 84486.92 |
| 7 | 9.47 | 5.43 | 55.57 | 2.00 | 16.40 | 10.81 | 1.82 | 83823.89 |
| 8 | 12.04 | 11.20 | 54.78 | 2.65 | 17.13 | 10.58 | 1.78 | 80604.86 |
| 9 | 11.70 | 5.96 | 56.24 | 2.73 | 16.22 | 10.37 | 1.79 | 87764.83 |
| 10 | 7.97 | 4.45 | 66.54 | 2.48 | 15.37 | 11.44 | 1.80 | 81474.27 |
| 11 | 9.57 | 6.56 | 56.34 | 2.58 | 15.12 | 11.09 | 1.80 | 84023.44 |
| 12 | 6.47 | 4.75 | 65.10 | 2.43 | 15.24 | 11.24 | 1.80 | 79780.79 |
| 13 | 5.26 | 3.57 | 59.44 | 1.98 | 16.01 | 10.86 | 1.78 | 79370.26 |
| 14 | 7.70 | 4.64 | 58.55 | 2.21 | 15.77 | 10.84 | 1.77 | 80883.77 |
| 15 | 9.72 | 7.04 | 66.29 | 2.57 | 15.36 | 10.98 | 1.77 | 78683.06 |
| 16 | 3.76 | 4.19 | 55.13 | 2.01 | 16.66 | 10.95 | 1.75 | 78760.34 |
| 17 | 2.57 | 3.63 | 47.10 | 1.81 | 15.87 | 10.76 | 1.74 | 81970.95 |
| 18 | 1.85 | 3.72 | 60.48 | 2.07 | 15.20 | 10.97 | 1.72 | 80470.76 |
| 19 | 1.15 | 3.52 | 57.79 | 1.88 | 15.76 | 10.96 | 1.71 | 79966.64 |
| 20 | 3.02 | 10.91 | 63.42 | 2.18 | 15.06 | 10.97 | 1.70 | 79675.68 |
| 21 | 5.44 | 6.86 | 57.26 | 2.36 | 14.56 | 11.04 | 1.71 | 80242.22 |
| 22 | 8.55 | 6.78 | 61.53 | 2.77 | 14.05 | 11.14 | 1.72 | 80354.61 |
| 23 | 10.62 | 7.36 | 59.19 | 2.77 | 14.31 | 11.16 | 1.72 | 81107.64 |
| 24 | 7.74 | 3.51 | 63.32 | 2.10 | 16.41 | 10.80 | 1.72 | 82066.31 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平 均 值 | 7.81 | 6.41 | 58.47 | 2.49 | 15.88 | 10.80 | 1.77 | 82591.69 |
| 最 大 值 | 12.04 | 12.71 | 66.54 | 4.55 | 18.09 | 11.44 | 1.85 | 88569.50 |
| 發生時間 | 7 | 2 | 9 | 0 | 2 | 9 | | 2 |
| 最 小 值 | 1.15 | 3.51 | 47.10 | 1.81 | 14.05 | 9.55 | 1.68 | 78683.06 |
| 發生時間 | 18 | 23 | 16 | 16 | 21 | 0 | | 14 |
| 零點偏移(率) | -0.01 % | -0.00 % | -0.02 % | -0.00 % | | 0.02 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.04 % | 0.10 % | -1.05 % | 0.08 % | | 0.18 | -0.03 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |