

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.89	7.55	59.53	0.29	19.91	10.88	1.07	76974.38
1	9.03	14.20	41.24	0.93	19.28	10.77	1.05	78213.75
2	6.89	4.26	46.90	1.44	17.22	11.66	1.05	73060.30
3	8.23	2.92	53.11	0.94	17.91	11.48	1.06	74160.15
4	8.12	2.85	50.00	0.75	19.49	10.88	1.06	77329.56
5	7.74	5.88	44.91	0.65	18.99	10.91	1.07	77694.94
6	6.63	6.80	46.44	0.88	18.71	11.19	1.08	75609.96
7	6.96	5.66	50.02	0.71	19.60	10.63	1.08	78373.93
8	9.19	5.95	45.05	0.98	19.25	10.81	1.06	77269.40
9	6.20	6.09	63.86	0.40	19.91	11.29	1.07	73671.51
10	3.60	6.04	41.73	0.50	19.66	10.86	1.07	77378.18
11	6.29	5.91	52.53	0.70	20.01	10.86	1.07	76555.91
12	9.06	5.75	49.36	1.02	19.16	10.88	1.07	77315.73
13	7.91	5.92	56.93	0.87	18.71	11.50	1.08	73013.43
14	8.45	5.61	54.46	0.76	19.17	11.13	1.08	75508.68
15	8.35	5.89	64.20	0.35	20.13	10.95	1.08	75640.46
16	8.67	5.83	47.94	0.44	19.54	10.96	1.06	76301.50
17	9.13	5.71	54.60	0.82	18.43	11.39	1.05	74075.84
18	8.11	5.53	53.60	0.84	18.37	11.19	1.03	75919.07
19	9.22	5.80	51.31	0.94	18.60	11.10	1.02	75925.69
20	7.50	5.72	54.62	0.62	18.58	11.37	1.02	74270.77
21	8.70	6.40	52.80	0.73	19.01	10.86	1.02	77780.96
22	6.42	8.06	57.37	0.66	18.71	11.35	1.04	74174.96
23	8.38	7.15	54.31	0.50	20.18	10.47	1.06	79494.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	6.15	51.95	0.74	19.11	11.06	1.06	76071.39
最大值	9.22	14.20	64.20	1.44	20.18	11.66	1.10	79494.31
發生時間	19	1	15	2	23	2		23
最小值	3.60	2.85	41.24	0.29	17.22	10.47	1.02	73013.43
發生時間	10	4	1	0	2	23		13
零點偏移(率)	-0.14 %	-0.04 %	0.00 %	0.00 %		-0.20		0.00 %
全幅偏移(率)	0.00 %	-0.18 %	-0.13 %	0.01 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.81	2.26	58.96	1.80	16.77	10.47	1.00	83701.51
1	1.64	2.34	55.26	2.03	17.59	10.58	0.99	82509.06
2	0.43	4.19	56.75	1.39	17.77	10.57	1.01	83229.37
3	9.09	4.05	52.75	2.64	16.59	10.11	0.99	87761.22
4	8.34	5.38	62.41	2.70	15.13	10.56	0.99	85152.00
5	7.87	1.74	57.98	1.75	16.63	10.27	1.01	85782.45
6	1.51	3.81	47.69	1.36	18.01	10.13	1.01	85758.04
7	5.08	7.30	57.21	1.75	17.33	10.23	0.99	85142.48
8	3.79	3.60	53.89	2.39	15.78	10.45	0.99	85349.87
9	1.99	5.24	69.54	1.25	17.75	10.86	0.99	80150.93
10	1.55	3.69	52.87	1.34	17.94	10.34	0.99	83898.49
11	0.14	8.13	55.00	1.68	17.56	10.90	0.99	79594.87
12	2.30	4.07	42.29	2.04	16.58	10.91	0.99	80738.22
13	7.84	3.66	48.57	1.46	18.85	9.91	0.99	86759.76
14	6.27	4.57	61.29	1.35	19.62	9.94	0.99	84918.63
15	6.12	2.39	45.31	2.31	17.85	9.94	1.00	86975.35
16	3.51	3.11	46.04	1.96	17.45	10.19	1.02	85476.94
17	4.12	7.11	41.28	2.79	16.45	10.34	1.02	85236.27
18	4.48	2.95	44.03	2.79	15.99	10.61	1.00	83831.66
19	6.82	2.78	40.91	2.06	17.61	10.16	0.99	85376.92
20	7.45	4.89	38.84	2.88	15.95	10.61	0.99	83578.92
21	7.32	2.96	55.49	2.46	16.36	10.53	0.99	83637.30
22	6.69	3.39	57.83	2.34	16.92	10.29	1.00	85162.05
23	9.34	4.96	52.70	2.70	17.27	10.09	0.97	86300.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.90	4.11	52.29	2.05	17.16	10.37	1.00	84417.62
最大值	9.34	8.13	69.54	2.88	19.62	10.91	1.06	87761.22
發生時間	23	11	9	20	14	12		3
最小值	0.14	1.74	38.84	1.25	15.13	9.91	0.97	79594.87
發生時間	11	5	20	9	4	13		11
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	0.00 %		0.04		-0.10 %
全幅偏移(率)	0.40 %	0.06 %	-0.14 %	-0.04 %		-0.17		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.25	5.34	50.97	1.31	15.98	11.00	0.97	78564.50
1	1.20	4.16	48.20	1.12	17.09	10.85	0.97	77547.38
2	0.89	5.94	45.34	1.54	15.41	10.70	0.97	76772.44
3	1.62	3.73	46.89	1.50	16.07	10.58	0.95	79514.96
4	4.49	4.56	36.06	2.13	14.88	10.49	0.94	76238.23
5	4.36	4.55	44.85	1.79	15.23	10.52	0.96	76684.24
6	2.05	6.84	45.29	2.09	14.02	10.97	0.96	72812.27
7	2.34	6.06	42.70	1.15	16.08	10.57	0.94	72653.67
8	5.27	1.06	50.68	1.39	16.22	10.96	0.95	78299.42
9	5.11	4.46	56.34	1.22	17.17	10.92	0.96	78548.82
10	3.96	6.53	55.72	1.04	18.31	10.74	0.95	79495.54
11	6.15	8.73	39.28	1.43	15.66	10.94	0.96	80125.56
12	5.71	2.38	58.04	1.26	16.98	10.87	0.95	79753.24
13	4.85	2.93	59.63	1.50	15.84	11.38	0.96	76294.32
14	3.90	8.94	39.36	1.02	17.59	10.31	0.95	79537.57
15	2.97	8.17	45.64	1.01	16.62	10.37	0.94	77850.70
16	5.07	11.26	50.43	1.58	15.90	10.70	0.94	76607.94
17	3.29	5.60	48.13	1.06	17.22	10.46	0.94	80119.47
18	5.66	6.83	45.85	1.95	15.09	10.80	0.94	78357.77
19	5.98	6.17	49.95	2.20	15.00	11.11	0.94	77400.29
20	7.46	6.38	48.09	2.27	14.50	11.10	0.94	77540.36
21	7.30	5.48	49.44	1.88	15.71	10.72	0.94	79743.07
22	9.37	4.61	59.77	1.71	16.22	10.72	0.96	82189.19
23	8.93	6.92	49.99	2.19	14.73	10.98	0.94	78673.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.59	5.73	48.61	1.56	15.98	10.78	0.95	77971.83
最大值	9.37	11.26	59.77	2.27	18.31	11.38	0.97	82189.19
發生時間	22	16	22	20	10	13		22
最小值	0.89	1.06	36.06	1.01	14.02	10.31	0.94	72653.67
發生時間	2	8	4	15	6	14		7
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	-0.01 %		0.02		0.00 %
全幅偏移(率)	-0.02 %	-0.42 %	-0.30 %	0.13 %		0.24		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								