

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月06日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.37	3.39	52.57	1.25	16.17	12.02	1.29	76446.97
1	6.53	3.17	58.39	1.03	17.79	11.91	1.30	77766.11
2	7.62	3.83	46.35	1.74	16.44	11.78	1.29	78677.77
3	7.07	2.81	46.46	1.87	16.40	11.78	1.28	78153.41
4	7.01	5.44	49.28	1.80	15.84	11.89	1.29	77437.34
5	4.36	3.03	52.23	1.07	16.83	11.93	1.25	83265.04
6	5.16	2.81	60.39	0.67	17.28	11.56	1.25	79941.81
7	5.07	2.79	47.68	1.74	15.96	11.80	1.28	78213.17
8	5.13	2.60	56.55	0.77	17.38	11.51	1.27	79610.64
9	8.52	3.31	46.21	1.85	16.21	11.78	1.28	78193.60
10	7.31	2.57	52.88	1.25	16.65	11.78	1.29	79042.65
11	7.38	2.65	62.34	1.20	16.64	12.01	1.29	77415.81
12	7.11	2.79	58.63	1.01	16.55	11.99	1.29	78475.22
13	9.74	2.56	55.51	2.00	16.53	11.73	1.29	80455.67
14	8.77	2.68	61.39	1.00	16.88	11.91	1.29	77626.08
15	8.13	2.94	67.84	0.98	17.29	11.26	1.29	80499.19
16	13.85	2.99	69.76	1.32	17.14	11.33	1.29	82993.12
17	8.46	2.85	54.77	0.83	18.09	11.24	1.29	83459.04
18	8.29	3.57	56.13	0.73	17.96	11.41	1.29	81961.92
19	6.37	3.34	69.79	0.86	17.23	11.87	1.29	78384.48
20	7.02	3.29	70.60	0.55	18.45	11.29	1.30	81264.61
21	9.55	5.10	63.76	1.09	16.95	11.17	1.29	83847.50
22	10.17	4.52	47.28	1.26	18.06	11.38	1.29	82557.97
23	7.80	7.27	54.40	1.22	17.02	11.69	1.29	80268.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.70	3.43	56.72	1.21	16.99	11.67	1.29	79831.56
最 大 值	13.85	7.27	70.60	2.00	18.45	12.02	1.33	83847.50
發生時間	16	23	20	13	20	0		21
最 小 值	4.36	2.56	46.21	0.55	15.84	11.17	1.23	76446.97
發生時間	5	13	9	20	4	21		0
零點偏移(率)	-0.12 %	-0.02 %	-0.02 %	-0.01 %		-0.12		0.30 %
全幅偏移(率)	0.00 %	0.11 %	-0.08 %	0.16 %		-0.31		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月06日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月06日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.82	2.63	62.40	0.67	16.36	11.19	1.53	78017.73
1	9.52	4.37	55.53	0.59	17.25	11.01	1.53	78350.65
2	14.15	5.99	54.68	1.35	17.00	10.83	1.53	80218.11
3	14.91	6.38	56.27	1.23	15.75	11.13	1.53	79318.05
4	3.31	2.69	62.38	0.49	16.15	11.26	1.53	78953.19
5	5.20	2.75	59.39	0.41	16.98	10.96	1.52	79440.51
6	4.93	7.94	53.32	0.60	15.95	10.97	1.51	79877.81
7	7.00	4.05	56.60	0.78	15.31	11.42	1.49	81426.53
8	8.73	3.68	54.43	0.54	16.14	10.90	1.50	78756.34
9	10.98	2.72	56.14	0.63	16.31	11.10	1.50	77531.41
10	12.15	5.84	58.15	0.59	17.08	10.81	1.52	79403.03
11	9.67	4.18	59.57	0.66	15.81	11.34	1.52	73240.28
12	11.36	6.16	53.06	0.58	16.45	10.75	1.52	78466.10
13	7.58	4.21	56.72	0.60	15.63	11.21	1.52	76881.10
14	9.59	7.46	57.35	0.56	16.14	11.02	1.52	76540.42
15	10.21	5.59	69.31	0.46	16.72	11.25	1.52	78298.67
16	15.84	2.91	58.58	0.95	17.33	10.44	1.52	83512.28
17	12.11	7.05	55.88	1.23	16.59	10.77	1.52	81322.95
18	10.53	2.25	59.38	0.47	16.31	11.04	1.52	79644.93
19	8.96	5.23	58.79	0.26	18.69	10.20	1.51	83887.21
20	15.71	3.40	54.72	0.83	16.55	10.81	1.51	80815.19
21	7.09	1.73	56.65	0.50	16.69	10.73	1.52	79247.87
22	11.49	2.26	65.92	0.67	17.41	10.83	1.52	79583.89
23	9.53	2.62	64.15	0.45	18.34	10.39	1.52	82761.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.10	4.34	58.31	0.67	16.62	10.93	1.52	79395.67
最 大 值	15.84	7.94	69.31	1.35	18.69	11.42	1.55	83887.21
發生時間	16	6	15	2	19	7		19
最 小 值	3.31	1.73	53.06	0.26	15.31	10.20	1.48	73240.28
發生時間	4	21	12	19	7	19		11
零點偏移(率)	-0.14 %	0.00 %	-0.01 %	-0.00 %		-0.11		-0.10 %
全幅偏移(率)	0.02 %	-0.31 %	0.24 %	-0.08 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								