

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月07日

報表日期: 114年03月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.56	4.51	68.91	0.48	18.43	11.57	1.28	80565.97
1	9.02	5.00	62.69	0.65	20.81	10.63	1.27	85866.59
2	9.72	4.91	59.08	1.04	18.81	11.47	1.27	81196.34
3	10.33	4.79	49.79	1.97	17.33	11.48	1.27	82662.49
4	7.50	6.71	58.68	0.92	18.59	11.26	1.29	83171.80
5	3.41	3.95	62.79	1.48	16.91	12.33	1.27	86038.14
6	8.19	3.52	61.48	0.84	18.74	11.34	1.27	82315.94
7	9.96	3.43	60.03	0.88	18.81	11.04	1.28	84780.09
8	9.16	3.59	58.61	0.92	18.95	11.16	1.29	83290.12
9	9.68	3.67	54.10	1.15	19.16	10.68	1.29	86697.45
10	10.07	3.59	54.66	1.03	18.75	10.83	1.28	85534.59
11	10.29	3.63	43.74	1.67	16.57	11.38	1.25	83344.31
12	8.63	3.30	58.32	0.96	17.75	11.44	1.23	82001.87
13	8.73	3.60	53.75	1.01	17.38	11.44	1.23	82404.22
14	9.51	4.29	46.98	1.36	17.20	11.21	1.23	84699.08
15	9.14	3.93	58.19	0.81	18.00	11.64	1.23	80077.77
16	7.45	3.48	59.59	0.93	18.68	10.98	1.25	84766.61
17	8.10	3.46	50.71	0.92	17.68	11.44	1.27	81946.04
18	8.35	3.40	55.22	1.43	16.70	11.53	1.29	81653.20
19	13.13	3.23	55.45	1.76	16.79	11.48	1.28	82431.66
20	5.51	3.50	57.84	0.90	17.95	11.39	1.28	81854.69
21	14.20	3.72	54.40	1.90	17.09	11.24	1.29	83922.28
22	6.15	3.36	61.29	0.84	17.16	11.46	1.29	82673.50
23	10.52	3.47	60.36	0.86	18.09	11.33	1.29	82600.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.97	3.92	56.94	1.11	18.01	11.32	1.27	83187.30
最 大 值	14.20	6.71	68.91	1.97	20.81	12.33	1.29	86697.45
發生時間	21	4	0	3	1	5		9
最 小 值	3.41	3.23	43.74	0.48	16.57	10.63	1.23	80077.77
發生時間	5	19	11	0	11	1		15
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.00 %		-0.11		0.30 %
全幅偏移(率)	0.00 %	0.02 %	0.18 %	-0.01 %		-0.31		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月07日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.11	5.15	53.21	0.32	18.72	10.15	1.52	84417.31
1	10.43	5.21	54.49	0.30	20.06	10.19	1.52	82551.87
2	10.38	9.37	47.42	3.04	18.13	10.41	1.52	81730.90
3	14.39	1.22	60.58	1.16	16.98	10.97	1.52	79769.95
4	7.65	4.89	55.80	0.62	17.55	10.72	1.52	79512.80
5	11.29	2.21	53.48	0.76	16.86	11.00	1.52	77607.95
6	6.63	4.00	61.23	0.77	16.78	11.01	1.52	79739.36
7	4.36	2.15	59.87	0.58	16.09	11.18	1.52	82094.02
8	11.27	1.78	58.58	0.92	15.46	11.43	1.52	76435.33
9	8.07	1.31	61.06	0.87	15.35	11.54	1.51	77235.86
10	10.81	1.86	53.51	1.06	15.51	11.28	1.50	76075.35
11	7.78	1.49	62.17	0.36	17.73	10.91	1.51	78458.71
12	17.27	4.94	56.99	1.15	16.19	11.09	1.52	76838.64
13	3.84	2.95	59.64	0.63	16.06	11.22	1.51	77419.73
14	10.05	1.45	53.37	0.51	17.51	11.12	1.51	77675.22
15	6.92	1.52	50.25	0.50	16.39	11.17	1.51	78163.90
16	10.12	2.72	61.83	0.39	17.03	10.97	1.52	79736.80
17	10.14	2.85	64.02	0.72	16.76	11.00	1.52	80075.47
18	11.45	3.14	64.75	0.86	16.09	11.27	1.51	78164.18
19	9.43	2.60	64.07	0.57	17.24	10.82	1.52	80543.55
20	9.65	2.52	57.79	0.72	17.86	10.40	1.51	83705.54
21	12.75	3.25	67.88	0.69	16.79	11.03	1.51	79345.57
22	7.32	2.90	62.34	0.59	15.73	11.49	1.52	75553.28
23	9.48	2.48	62.77	0.40	17.12	11.22	1.52	77662.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.65	3.08	58.63	0.77	16.92	10.98	1.52	79188.06
最 大 值	17.27	9.37	67.88	3.04	20.06	11.54	1.53	84417.31
發生時間	12	2	21	2	1	9		0
最 小 值	3.84	1.22	47.42	0.30	15.35	10.15	1.50	75553.28
發生時間	13	3	2	1	9	0		22
零點偏移(率)	-0.01 %	-0.05 %	-0.03 %	0.00 %		-0.13		0.00 %
全幅偏移(率)	0.02 %	0.48 %	0.22 %	0.13 %		-0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								