

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月30日

報表日期: 115年08月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.57	12.61	56.02	2.21	19.86	10.79	1.18	74156.55
1	9.11	12.49	58.93	1.87	20.74	10.51	1.18	75475.13
2	9.07	12.76	57.36	2.41	19.18	10.97	1.18	73788.61
3	10.53	12.95	56.82	2.94	18.31	11.27	1.18	72847.69
4	9.55	13.28	56.82	3.15	17.22	11.30	1.18	73011.07
5	2.08	11.78	53.32	1.56	18.65	10.75	1.18	75283.15
6	10.50	11.71	52.24	1.98	18.41	11.20	1.18	72701.60
7	8.84	12.25	54.60	2.58	16.27	11.65	1.18	71124.31
8	9.21	13.11	60.04	2.56	16.10	11.79	1.17	70165.82
9	9.63	14.05	56.98	2.72	16.11	11.61	1.18	70365.25
10	7.19	13.58	62.09	1.38	16.26	11.81	1.16	71824.85
11	8.51	12.97	55.96	2.45	18.84	11.33	1.16	71663.15
12	9.04	12.72	58.14	2.31	20.51	10.72	1.15	74575.72
13	9.21	12.87	53.96	2.59	18.98	11.25	1.16	72361.61
14	10.96	13.47	60.21	3.50	17.63	11.48	1.16	71860.14
15	8.61	13.61	62.50	3.47	17.34	11.62	1.15	70206.49
16	10.07	13.04	56.00	2.40	17.58	11.39	1.15	71992.76
17	8.77	14.38	65.70	1.86	18.72	12.17	1.15	65900.83
18	10.68	14.03	59.09	1.27	20.29	11.68	1.14	68181.96
19	9.26	12.58	50.62	1.59	19.84	10.54	1.15	76464.21
20	8.32	13.09	52.20	0.82	22.11	10.06	1.18	77334.33
21	8.02	12.85	52.00	1.40	19.67	10.69	1.16	74932.30
22	9.25	12.68	54.23	1.47	20.23	10.59	1.15	75156.64
23	10.05	12.88	49.80	1.90	18.51	10.96	1.17	74462.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.00	12.99	56.48	2.18	18.64	11.17	1.17	72743.18
最 大 值	10.96	14.38	65.70	3.50	22.11	12.17	1.19	77334.33
發生時間	14	17	17	14	20	17		20
最 小 值	2.08	11.71	49.80	0.82	16.10	10.06	1.13	65900.83
發生時間	5	6	23	20	8	20		17
零點偏移(率)	-0.12 %	-0.01 %	-0.01 %	-0.01 %		-0.01	-0.01	0.20 %
全幅偏移(率)	0.33 %	-0.59 %	0.19 %	-0.49 %		-0.06	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月30日

項目 單位	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
0	7.04	12.59	59.70	2.36	18.52	10.08	1.27	75909.90
1	8.58	12.72	56.37	2.17	20.85	9.81	1.27	74897.15
2	8.90	12.26	53.78	2.51	19.57	9.60	1.27	75205.38
3	9.77	12.32	52.38	2.56	19.10	9.72	1.27	74427.40
4	9.59	12.36	48.45	2.56	18.22	9.67	1.27	76076.31
5	10.22	11.29	53.94	2.76	18.32	9.82	1.28	77297.24
6	10.29	11.45	58.92	2.73	18.23	10.01	1.28	77543.86
7	11.28	11.35	59.17	3.09	19.40	9.80	1.27	75782.32
8	9.23	12.18	52.15	2.76	18.98	9.53	1.30	75736.70
9	9.66	12.66	51.64	2.64	18.42	9.17	1.27	74682.55
10	9.66	11.98	43.07	2.72	19.31	8.50	1.30	75040.88
11	10.90	10.94	45.59	2.69	18.52	8.84	1.25	72673.97
12	7.10	11.27	45.29	2.29	19.08	8.74	1.25	72645.96
13	10.10	10.79	47.99	2.65	19.22	8.68	1.26	73325.93
14	9.37	11.86	39.19	2.42	19.84	8.35	1.29	73945.87
15	9.59	11.47	35.03	2.46	21.33	7.98	1.27	75283.14
16	11.00	10.71	39.74	2.42	21.72	7.63	1.27	78119.73
17	8.26	10.61	48.25	1.02	18.47	8.34	1.27	72985.12
18	9.51	12.26	50.70	1.57	20.55	7.95	1.26	75254.13
19	8.73	12.86	41.85	1.52	20.70	8.22	1.28	75440.99
20	8.56	11.35	49.40	1.28	18.99	9.79	1.31	78888.15
21	7.56	12.59	49.55	1.35	18.60	11.04	1.31	75093.69
22	5.67	12.23	48.23	1.33	19.91	10.56	1.31	75421.62
23	5.35	11.15	36.53	1.23	19.03	9.52	1.30	75757.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.00	11.80	48.62	2.21	19.37	9.22	1.28	75309.82
最 大 值	11.28	12.86	59.70	3.09	21.72	11.04	1.33	78888.15
發生時間	7	19	0	7	16	21		20
最 小 值	5.35	10.61	35.03	1.02	18.22	7.63	1.24	72645.96
發生時間	23	17	15	17	4	16		12
零點偏移(率)	-0.10 %	0.00 %	-0.03 %	-0.01 %		-0.01	-0.01	-0.20 %
全幅偏移(率)	0.20 %	0.97 %	0.61 %	0.58 %		-0.03	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								