

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月03日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.61	6.40	53.14	1.24	17.45	11.32	1.03	83045.85
1	9.55	7.01	47.94	2.02	16.93	11.69	1.02	80220.43
2	5.99	6.70	53.50	0.89	17.57	12.12	1.02	76183.44
3	1.66	8.95	55.64	1.69	15.72	12.74	1.03	72290.31
4	1.85	7.15	55.79	0.68	17.67	11.63	1.02	80772.53
5	5.17	5.87	51.06	1.25	17.53	11.24	1.02	83919.65
6	5.25	5.55	50.01	1.25	17.32	11.31	1.03	83901.85
7	3.45	5.10	56.30	0.60	18.12	11.43	1.04	81886.71
8	7.50	5.54	44.39	1.22	17.47	11.40	1.02	83256.60
9	6.64	5.72	48.42	1.39	17.86	11.30	1.02	83037.47
10	2.50	5.67	61.15	0.73	17.30	12.13	1.01	76363.13
11	3.97	5.15	49.65	1.07	16.77	11.86	1.03	79427.87
12	0.71	5.75	57.59	0.76	17.21	12.27	1.03	75332.62
13	3.15	6.45	56.23	0.80	17.83	11.59	1.02	81089.42
14	9.43	6.04	49.13	1.23	17.40	11.54	1.03	82010.42
15	9.40	5.67	50.34	1.08	16.79	11.75	1.05	80689.73
16	4.82	6.53	54.27	1.11	16.83	11.66	1.05	81328.71
17	9.02	5.24	52.18	1.46	16.77	11.19	1.02	85633.15
18	10.75	5.55	46.65	2.29	15.58	11.34	1.02	85027.05
19	9.37	6.05	54.84	1.53	16.40	11.36	1.02	84190.25
20	9.38	7.25	55.13	1.02	17.16	11.22	1.02	84105.96
21	9.49	7.58	57.43	0.97	17.21	11.31	1.03	83936.43
22	8.03	8.01	50.32	1.67	15.96	11.75	1.03	80890.99
23	9.04	6.45	63.61	1.54	16.76	11.42	1.04	83027.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.49	6.31	53.11	1.23	17.07	11.61	1.03	81315.35
最大值	10.75	8.95	63.61	2.29	18.12	12.74	1.07	85633.15
發生時間	18	3	23	18	7	3		17
最小值	0.71	5.10	44.39	0.60	15.58	11.19	1.00	72290.31
發生時間	12	7	8	7	18	17		3
零點偏移(率)	-0.13 %	0.00 %	-0.01 %	-0.01 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	-0.57 %	-0.02 %	0.44 %		-0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月03日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.50	4.65	46.38	2.07	17.77	10.71	1.04	81708.87
1	4.79	4.65	50.63	1.78	18.75	10.95	1.04	79241.21
2	4.52	5.08	45.21	1.38	18.56	10.85	1.05	80194.78
3	1.87	2.25	47.77	1.82	17.68	10.93	1.05	79760.41
4	1.41	3.03	60.73	2.01	16.47	11.46	1.04	76802.69
5	2.72	3.92	55.59	1.72	17.16	11.03	1.02	79465.53
6	1.65	3.91	50.91	1.61	16.62	11.27	1.03	77417.22
7	1.87	3.57	52.15	2.18	16.21	11.48	1.04	77174.52
8	2.79	3.31	54.74	1.99	16.18	11.50	1.06	77373.27
9	2.41	3.47	57.36	1.91	16.04	11.42	1.06	76766.28
10	3.76	4.07	60.79	1.73	16.39	11.54	1.05	76338.72
11	2.72	4.53	45.06	1.55	17.30	11.01	1.06	79632.88
12	8.27	5.64	41.56	1.95	16.84	11.00	1.06	79213.82
13	9.23	4.76	42.46	1.94	17.34	11.08	1.06	78996.64
14	5.86	5.25	44.04	2.53	16.17	11.45	1.06	77136.44
15	7.64	4.00	45.07	2.32	16.04	11.29	1.07	78509.76
16	4.02	4.14	43.69	2.45	15.50	11.36	1.05	78809.57
17	9.61	3.92	46.11	2.96	15.45	11.23	1.06	79771.59
18	6.89	4.27	43.65	2.72	15.50	11.26	1.06	79340.77
19	4.08	3.91	49.33	2.54	15.08	11.43	1.06	78082.70
20	8.90	4.56	55.30	2.31	16.24	11.45	1.06	77119.42
21	10.25	4.90	44.42	2.78	16.79	10.73	1.06	82438.75
22	6.65	4.95	51.07	2.76	15.20	11.48	1.06	77996.68
23	10.08	6.33	58.90	3.43	14.33	11.78	1.06	76378.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.23	4.29	49.71	2.19	16.48	11.24	1.05	78569.62
最大值	10.25	6.33	60.79	3.43	18.75	11.78	1.07	82438.75
發生時間	21	23	10	23	1	23		21
最小值	1.41	2.25	41.56	1.38	14.33	10.71	1.02	76338.72
發生時間	4	3	12	2	23	0		10
零點偏移(率)	-0.03 %	0.00 %	-0.05 %	0.01 %		-0.02		-0.10 %
全幅偏移(率)	-0.02 %	0.13 %	0.15 %	0.09 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月03日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.67	6.46	59.28	0.51	16.85	10.94	1.03	77941.63
1	3.43	5.81	60.66	0.55	18.31	10.73	1.04	77136.03
2	2.65	4.48	55.82	0.68	16.09	11.46	1.01	74297.92
3	2.57	5.14	64.97	0.70	16.35	11.50	1.02	74004.69
4	2.76	4.05	53.92	0.61	17.19	10.32	0.99	82563.06
5	2.89	3.85	57.81	0.74	16.61	10.60	1.02	80020.66
6	2.59	3.66	61.10	0.73	15.97	10.93	1.03	77340.25
7	2.33	3.91	48.81	0.53	16.28	11.04	1.04	79883.84
8	3.20	6.15	50.20	0.68	16.32	11.13	1.06	77457.60
9	2.51	3.21	50.50	0.59	17.19	10.44	1.06	82211.66
10	2.46	5.35	50.38	0.76	15.98	11.29	1.07	76153.52
11	2.50	5.63	49.25	0.60	17.06	10.68	1.04	79955.41
12	2.66	4.65	45.41	0.49	17.56	10.31	1.06	82259.88
13	2.68	4.83	52.74	0.73	15.90	11.18	1.09	76928.19
14	2.74	4.43	51.48	0.85	15.72	11.10	1.06	76738.21
15	2.41	5.29	47.53	1.13	15.46	11.06	1.05	78038.85
16	2.48	4.53	49.88	1.08	16.14	10.76	1.06	79992.52
17	2.55	2.90	46.79	0.99	15.86	10.74	1.09	80860.85
18	2.90	5.06	49.27	1.24	14.88	10.78	1.07	81304.34
19	4.15	4.98	51.32	1.36	14.70	11.14	1.04	78116.80
20	6.74	4.86	53.24	1.06	16.21	10.73	1.04	80475.97
21	7.22	5.30	49.00	1.33	15.55	10.66	1.03	81265.84
22	5.35	7.55	49.78	1.40	14.32	11.19	1.02	74276.71
23	1.64	5.83	61.89	1.55	14.00	11.15	1.03	73367.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.17	4.91	52.96	0.87	16.10	10.91	1.04	78441.32
最大值	7.22	7.55	64.97	1.55	18.31	11.50	1.10	82563.06
發生時間	21	22	3	23	1	3		4
最小值	1.64	2.90	45.41	0.49	14.00	10.31	0.99	73367.23
發生時間	23	17	12	12	23	12		23
零點偏移(率)	-0.03 %	0.01 %	-0.02 %	0.00 %		-0.04		0.20 %
全幅偏移(率)	0.02 %	-0.44 %	0.02 %	0.43 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								