

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月26日

報表日期: 114年09月26日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.38	12.82	51.72	2.90	16.13	11.24	1.25	82985.08
1	13.20	13.96	61.68	3.19	16.41	11.60	1.25	79365.37
2	6.88	14.22	66.25	2.54	16.53	11.98	1.25	76313.57
3	8.64	13.20	59.54	2.85	16.77	11.02	1.25	84745.84
4	9.66	13.15	55.64	2.82	16.64	11.43	1.25	81106.56
5	9.54	12.43	57.44	3.17	16.91	10.89	1.25	85184.43
6	10.20	12.95	60.10	3.29	15.56	11.45	1.25	82127.84
7	10.05	13.13	60.44	2.66	15.25	11.65	1.25	80554.38
8	7.75	13.37	62.51	2.71	14.55	11.91	1.25	79188.91
9	8.90	13.17	60.84	2.80	14.74	11.75	1.25	80445.19
10	7.54	13.20	62.50	2.53	15.03	11.73	1.25	79787.02
11	8.91	14.63	61.23	2.66	14.68	12.05	1.25	78180.65
12	7.72	12.93	60.81	2.32	15.46	11.57	1.25	81459.71
13	8.84	13.18	55.29	2.68	14.29	11.69	1.25	81262.17
14	7.49	13.37	61.31	2.79	14.12	11.92	1.25	78655.86
15	14.96	13.54	63.16	3.68	13.37	11.90	1.25	78656.49
16	10.98	13.38	55.92	2.90	14.59	11.66	1.23	77679.45
17	11.73	12.83	62.00	2.81	14.77	11.49	1.23	79572.03
18	7.79	13.03	60.03	2.82	14.08	11.71	1.25	78413.03
19	6.02	13.25	61.80	2.50	15.07	11.78	1.25	77669.04
20	12.33	13.03	59.46	2.65	15.04	11.60	1.25	78758.37
21	13.76	14.41	60.71	3.04	14.30	11.67	1.25	78865.46
22	6.67	14.04	63.78	2.68	14.42	11.94	1.25	77040.60
23	4.84	13.39	60.19	2.15	15.57	11.37	1.26	80057.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.32	13.36	60.18	2.80	15.18	11.63	1.25	79919.77
最 大 值	14.96	14.63	66.25	3.68	16.91	12.05	1.29	85184.43
發生時間	15	11	2	15	5	11		5
最 小 值	4.84	12.43	51.72	2.15	13.37	10.89	1.23	76313.57
發生時間	23	5	0	23	15	5		2
零點偏移(率)	-0.03 %	-0.04 %	-0.01 %	-0.01 %		0.01		0.10 %
全幅偏移(率)	1.50 %	0.78 %	-0.37 %	-0.03 %		0.44		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月26日

報表日期: 114年09月26日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.72	12.82	63.54	2.75	17.53	10.13	1.41	79379.93
1	9.62	12.13	59.63	2.59	18.40	9.68	1.42	81663.45
2	10.38	11.88	58.96	2.63	17.99	9.50	1.42	82219.47
3	9.55	11.98	51.84	2.49	16.68	9.62	1.42	81210.50
4	8.90	12.58	56.13	2.74	15.21	10.26	1.41	82115.35
5	8.91	13.07	55.52	3.01	15.33	10.27	1.41	80580.43
6	5.49	13.00	54.52	2.63	14.85	10.61	1.41	76489.89
7	10.37	12.32	59.89	2.92	14.73	10.48	1.43	78860.95
8	8.84	11.38	57.68	2.62	15.33	10.07	1.43	77829.88
9	11.60	11.21	61.11	2.64	16.14	9.86	1.43	80892.76
10	10.27	11.39	60.39	2.52	16.22	10.02	1.43	79357.62
11	8.20	11.20	61.20	2.44	17.44	9.76	1.43	79935.14
12	7.46	11.43	63.88	2.51	18.40	9.79	1.44	77957.76
13	6.41	12.54	58.19	2.36	17.13	9.80	1.45	77893.20
14	5.29	11.70	59.20	2.40	16.31	10.07	1.43	78271.83
15	7.53	11.57	59.65	2.96	15.65	10.03	1.43	78028.85
16	9.67	9.14	57.18	1.40	16.16	9.39	1.43	78261.86
17	10.98	13.53	56.83	1.33	17.13	9.25	1.43	78454.72
18	6.75	13.16	52.48	1.16	17.08	8.80	1.43	76110.54
19	10.05	13.13	51.88	1.25	18.03	8.60	1.46	75340.12
20	8.37	13.07	46.95	1.19	16.82	8.68	1.46	74755.68
21	10.52	13.70	52.42	1.34	17.45	9.03	1.44	77811.30
22	10.37	15.30	66.03	1.31	16.16	10.75	1.43	80997.82
23	9.61	15.08	64.76	1.28	15.95	10.63	1.43	79803.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.83	12.43	57.91	2.19	16.59	9.80	1.43	78925.94
最 大 值	11.60	15.30	66.03	3.01	18.40	10.75	1.47	82219.47
發生時間	9	22	22	5	1	22		2
最 小 值	5.29	9.14	46.95	1.16	14.73	8.60	1.40	74755.68
發生時間	14	16	20	18	7	19		20
零點偏移(率)	-0.16 %	0.00 %	-0.01 %	-0.07 %		-0.02		0.00 %
全幅偏移(率)	0.39 %	0.33 %	0.33 %	-0.12 %		0.28		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								