

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.77	8.27	64.92	2.11	19.20	9.38	1.45	77997.72
1	1.86	8.18	55.62	1.90	20.77	8.71	1.43	81348.42
2	2.12	10.00	54.56	2.41	20.30	8.65	1.43	81508.95
3	2.93	10.44	52.48	4.77	20.02	8.63	1.43	80473.84
4	1.86	7.85	65.90	2.44	19.84	8.68	1.47	78140.28
5	1.65	8.86	48.56	2.36	19.37	8.36	1.48	77904.84
6	0.86	7.74	56.81	1.93	18.26	8.97	1.48	76108.17
7	0.72	8.86	66.26	1.80	18.63	9.30	1.45	78499.83
8	1.75	9.42	62.19	1.45	18.34	9.29	1.48	79800.80
9	0.58	7.00	54.89	1.17	17.17	9.68	1.48	77650.30
10	1.23	7.15	58.46	1.29	16.70	9.90	1.47	77319.07
11	1.76	7.53	56.95	1.33	16.54	9.97	1.44	76712.26
12	1.95	7.45	56.68	1.29	16.73	9.84	1.48	76284.66
13	2.27	10.00	57.33	1.41	17.47	9.88	1.48	78018.99
14	1.12	7.46	59.29	1.35	17.45	9.74	1.47	79532.38
15	5.58	7.91	63.86	2.02	15.74	10.71	1.45	70877.29
16	0.52	8.40	62.47	2.11	16.36	10.70	1.45	71596.38
17	8.05	9.16	55.48	2.30	18.86	9.35	1.47	82226.59
18	10.55	7.49	57.64	2.53	17.97	9.88	1.48	81928.93
19	16.46	10.91	54.55	3.66	16.38	9.36	1.48	74259.75
20	9.30	7.27	59.09	2.78	16.05	9.54	1.48	73115.06
21	11.10	11.17	58.85	3.51	17.07	9.10	1.48	74472.59
22	10.01	9.56	57.20	3.58	15.16	9.52	1.48	71440.26
23	5.39	7.48	60.74	2.06	18.65	9.11	1.47	77180.65
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.27	8.56	58.37	2.23	17.88	9.43	1.46	77266.58
最 大 值	16.46	11.17	66.26	4.77	20.77	10.71	1.49	82226.59
發生時間	19	21	7	3	1	15		17
最 小 值	0.52	7.00	48.56	1.17	15.16	8.36	1.42	70877.29
發生時間	16	9	5	9	22	5		15
零點偏移(率)	-0.08 %	0.01 %	-0.03 %	-0.01 %		-0.10		-0.10 %
全幅偏移(率)	0.02 %	0.73 %	0.35 %	0.19 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								