

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.13	13.80	65.95	1.28	18.12	12.53	1.01	79028.53
1	0.75	8.21	62.25	1.43	19.10	11.25	0.99	90344.23
2	7.25	9.01	46.66	1.83	18.05	11.38	1.01	90462.72
3	8.50	8.90	54.51	2.20	17.56	11.69	1.01	87699.43
4	8.79	8.27	62.04	1.84	18.27	11.53	1.02	87924.93
5	0.94	12.75	65.36	1.41	17.27	12.22	1.04	81452.61
6	8.54	10.91	60.40	1.86	18.26	11.35	1.05	90185.82
7	9.37	9.36	55.34	2.46	17.28	11.73	1.02	87283.56
8	9.14	8.56	53.45	2.30	17.37	11.20	1.02	88442.82
9	4.14	12.24	64.81	2.43	16.42	12.18	1.05	80977.07
10	8.73	8.54	51.25	1.94	18.43	11.24	1.05	90723.70
11	8.21	9.14	51.97	1.69	17.95	11.25	1.02	89397.02
12	9.36	11.35	53.94	2.21	17.06	11.41	1.05	86849.58
13	9.42	12.20	50.06	3.17	15.48	11.46	1.05	85017.67
14	10.08	11.86	49.94	3.03	16.46	11.39	1.03	83776.94
15	5.32	13.36	55.44	2.45	15.63	12.37	1.04	76525.90
16	7.22	10.21	58.83	3.29	14.46	12.74	1.01	74597.27
17	9.73	2.46	53.32	2.25	15.75	11.65	0.99	85615.36
18	9.33	5.70	56.13	2.31	15.58	11.74	1.00	85403.86
19	8.06	5.68	63.10	1.71	17.18	11.69	1.00	86752.33
20	10.01	6.38	47.15	2.46	16.02	11.73	1.00	88269.25
21	8.13	6.29	67.78	1.63	16.50	12.38	1.05	82552.83
22	4.94	10.09	49.96	3.16	14.21	13.49	1.03	71047.14
23	3.17	2.40	52.09	2.61	14.69	13.13	1.03	71118.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.05	9.07	56.32	2.21	16.80	11.86	1.02	84227.04
最大值	10.08	13.80	67.78	3.29	19.10	13.49	1.06	90723.70
發生時間	14	0	21	16	1	22		10
最小值	0.13	2.40	46.66	1.28	14.21	11.20	0.98	71047.14
發生時間	0	23	2	0	22	8		22
零點偏移(率)	-0.02 %	-0.01 %	-0.00 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.02 %	1.07 %	0.04 %	0.49 %		0.05		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.95	6.74	63.58	1.14	19.42	10.36	1.11	83922.11
1	0.27	8.01	52.22	1.17	20.66	9.84	1.10	87142.14
2	1.10	5.32	51.34	1.80	17.73	10.28	1.10	86731.03
3	5.74	9.27	59.22	2.08	18.33	10.04	1.11	87208.54
4	5.57	2.86	55.86	2.07	17.35	10.13	1.11	86024.95
5	9.15	3.38	56.93	2.25	17.81	10.14	1.12	86529.39
6	9.24	6.50	46.97	2.29	17.86	10.13	1.12	83927.40
7	9.00	5.51	52.46	2.07	17.73	10.16	1.11	87009.94
8	9.65	4.77	47.18	2.66	17.10	10.25	1.10	84961.14
9	7.53	5.10	55.90	2.01	17.53	10.11	1.11	85741.44
10	6.33	4.48	60.82	1.68	17.94	9.94	1.11	86988.08
11	9.63	10.65	46.07	3.31	14.93	10.88	1.12	83030.96
12	6.73	5.68	58.69	2.40	15.74	10.69	1.12	81295.76
13	9.19	4.26	56.67	5.17	16.08	11.10	1.12	82865.42
14	7.87	7.64	58.14	6.21	16.74	10.79	1.10	83693.06
15	6.97	9.44	45.24	5.43	14.51	11.67	1.09	75857.60
16	11.34	9.82	47.96	5.71	13.06	12.24	1.06	70237.86
17	3.78	2.45	44.97	3.57	16.07	11.26	1.08	83634.31
18	6.29	7.16	52.94	3.15	17.26	11.22	1.07	86498.69
19	11.77	3.19	52.71	4.74	17.19	10.96	1.07	84405.26
20	10.97	3.04	67.13	3.02	17.17	11.68	1.07	79388.56
21	8.58	2.89	62.58	2.77	17.75	11.64	1.07	81419.70
22	12.29	8.52	47.68	5.53	15.22	12.87	1.07	70270.05
23	7.40	5.02	46.85	3.12	16.22	12.50	1.05	65499.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.39	5.90	53.75	3.14	16.98	10.87	1.10	82261.78
最大值	12.29	10.65	67.13	6.21	20.66	12.87	1.12	87208.54
發生時間	22	11	20	14	1	22		3
最小值	0.27	2.45	44.97	1.14	13.06	9.84	1.05	65499.32
發生時間	1	17	17	0	16	1		23
零點偏移(率)	-0.04 %	-0.06 %	-0.00 %	0.00 %		0.01		-0.20 %
全幅偏移(率)	-0.87 %	1.22 %	-0.04 %	0.61 %		-0.10		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.85	8.47	58.42	0.90	17.65	11.09	0.99	75508.74
1	4.77	6.67	58.15	1.17	19.63	10.77	0.99	82058.19
2	9.00	9.32	53.23	1.69	16.18	11.25	0.99	80323.75
3	9.16	7.97	50.00	1.61	16.29	11.09	0.99	80307.71
4	8.57	6.91	56.53	1.73	15.92	11.39	0.99	81470.09
5	8.19	6.47	57.01	1.36	17.54	10.70	0.99	84907.29
6	9.41	9.45	47.35	1.98	15.61	11.02	0.99	78556.90
7	9.34	7.08	54.79	2.73	16.61	10.90	1.01	77696.30
8	10.02	7.63	50.30	2.73	16.78	10.63	1.00	78897.72
9	9.06	6.28	54.66	3.00	15.00	11.15	1.02	75348.10
10	8.35	5.21	60.51	2.63	15.88	11.11	1.03	77233.00
11	12.42	10.14	47.52	2.97	15.51	10.86	0.99	76506.95
12	8.43	8.31	56.58	2.85	14.68	11.26	0.98	71536.94
13	7.11	8.03	48.04	2.83	14.54	10.88	0.99	72777.53
14	11.91	10.40	46.16	5.86	13.35	11.14	0.97	71098.59
15	3.84	6.92	54.74	2.80	14.32	11.56	0.96	66733.64
16	1.24	11.35	51.71	3.51	12.35	12.28	0.94	61373.05
17	2.28	6.72	47.56	2.70	14.02	10.96	0.95	72858.54
18	2.07	3.08	54.11	2.42	14.49	10.98	0.96	74124.39
19	5.65	4.51	54.44	2.39	15.63	10.83	0.97	76631.20
20	7.36	5.58	55.93	2.84	14.77	11.29	0.99	76726.27
21	3.88	6.07	60.33	2.82	14.27	12.10	0.99	70350.29
22	0.41	12.17	44.76	4.30	12.14	13.44	0.97	57153.03
23	0.01	3.76	47.61	3.68	12.89	13.10	0.96	52759.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.47	7.44	52.93	2.65	15.25	11.32	0.98	73872.42
最大值	12.42	12.17	60.51	5.86	19.63	13.44	1.04	84907.29
發生時間	11	22	10	14	1	22		5
最小值	0.01	3.08	44.76	0.90	12.14	10.63	0.92	52759.76
發生時間	23	18	22	0	22	8		23
零點偏移(率)	-0.06 %	0.00 %	-0.04 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-1.24 %	-1.48 %	-0.71 %		0.30		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								