

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.21	12.81	55.30	3.45	17.31	11.22	1.23	82864.85
1	2.60	13.14	56.99	2.61	17.97	11.39	1.24	81171.77
2	8.34	12.74	49.33	3.49	17.70	11.15	1.25	83248.80
3	5.99	13.13	55.60	2.76	17.61	11.45	1.24	80988.58
4	9.51	12.47	51.56	3.13	18.57	10.78	1.25	85241.19
5	8.80	12.52	58.77	3.36	18.18	10.84	1.25	83305.89
6	7.01	12.69	58.77	3.00	17.60	11.15	1.25	83014.14
7	5.78	12.16	49.54	3.78	17.46	10.79	1.25	86535.88
8	10.71	12.13	56.33	1.90	18.06	10.71	1.25	86378.21
9	8.94	12.35	51.53	2.28	17.04	11.02	1.25	84668.64
10	10.27	12.55	52.53	2.08	16.38	11.25	1.25	83329.15
11	8.37	12.86	54.33	1.62	17.59	11.34	1.25	81783.10
12	9.63	12.58	45.43	2.53	16.15	11.29	1.25	83326.78
13	7.65	13.29	65.09	1.18	17.79	11.62	1.25	78970.72
14	9.39	12.62	45.78	1.34	18.75	10.95	1.25	83649.44
15	9.15	12.46	53.77	2.28	18.53	10.88	1.25	84438.25
16	8.43	12.83	56.78	2.06	19.09	11.07	1.25	82389.26
17	9.50	12.06	55.01	2.46	18.26	10.59	1.25	87167.42
18	10.13	12.43	52.66	2.68	18.82	10.63	1.25	86209.87
19	9.74	13.49	61.82	3.50	17.54	10.85	1.25	85201.13
20	8.75	13.93	62.71	1.96	17.79	11.03	1.25	83912.22
21	8.36	13.94	56.89	2.12	18.05	11.00	1.25	83924.12
22	9.15	13.85	52.22	2.60	17.77	10.99	1.25	84685.71
23	12.54	11.97	55.97	2.21	17.85	10.97	1.25	84282.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.62	12.79	54.78	2.52	17.83	11.04	1.25	83778.66
最大值	12.54	13.94	65.09	3.78	19.09	11.62	1.25	87167.42
發生時間	23	21	13	7	16	13		17
最小值	2.60	11.97	45.43	1.18	16.15	10.59	1.23	78970.72
發生時間	1	23	12	13	12	17		13
零點偏移(率)	-0.01 %	-0.08 %	-0.01 %	-0.01 %		0.00	-0.01	0.20 %
全幅偏移(率)	0.20 %	-1.19 %	0.30 %	-0.08 %		-0.06	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.99	12.18	49.59	1.16	17.80	10.77	0.99	80037.99
1	4.73	12.11	52.77	1.49	19.41	10.43	0.95	82756.33
2	3.26	12.17	44.90	0.64	18.54	10.66	0.94	80352.17
3	5.10	12.04	52.90	0.92	18.69	10.49	0.95	83400.90
4	5.01	12.59	40.29	1.29	17.94	10.48	0.94	83462.45
5	3.19	11.95	48.50	1.19	17.73	10.59	0.95	84236.60
6	1.61	16.07	48.41	1.41	17.19	11.00	0.98	81638.39
7	1.63	9.32	39.10	1.20	17.94	10.66	0.97	80182.55
8	6.17	12.03	54.66	1.05	18.16	10.64	0.97	85973.82
9	10.38	12.20	52.09	1.58	17.00	11.04	0.98	81330.68
10	12.72	12.63	53.09	2.08	16.14	11.46	0.99	81173.64
11	4.36	13.23	50.27	1.58	15.14	11.99	1.00	77378.99
12	10.80	12.74	47.93	1.98	16.13	11.57	0.98	79847.75
13	13.57	12.73	63.87	0.82	18.05	11.29	0.99	79987.89
14	9.83	11.92	37.83	0.82	19.84	10.37	0.97	86106.91
15	12.13	12.31	46.70	1.19	19.16	10.63	0.98	84058.87
16	13.38	12.10	50.93	1.20	18.11	10.57	0.99	85900.89
17	4.04	13.05	57.08	0.63	18.48	11.43	0.98	79089.29
18	9.39	12.53	53.41	0.85	19.08	10.61	0.97	84483.97
19	4.38	13.33	48.26	0.74	18.74	10.67	0.97	84751.03
20	8.71	14.29	62.78	1.23	16.97	11.46	0.99	80038.11
21	6.61	13.90	48.88	0.42	19.39	10.61	0.98	85165.41
22	4.61	13.39	53.43	1.01	17.87	10.75	0.97	84532.62
23	10.13	12.78	45.57	0.75	18.30	10.95	0.98	82772.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.20	12.65	50.14	1.13	17.99	10.88	0.97	82444.17
最大值	13.57	16.07	63.87	2.08	19.84	11.99	1.02	86106.91
發生時間	13	6	13	10	14	11		14
最小值	1.61	9.32	37.83	0.42	15.14	10.37	0.94	77378.99
發生時間	6	7	14	21	11	14		11
零點偏移(率)	-0.03 %	-0.06 %	-0.04 %	-0.00 %		0.00	-0.01	0.00 %
全幅偏移(率)	1.32 %	-2.15 %	-0.13 %	-1.03 %		0.23	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.31	12.26	41.74	2.91	19.27	8.90	1.31	74877.09
1	6.37	12.32	41.81	2.42	20.41	9.16	1.32	76806.85
2	5.58	12.13	40.58	2.52	18.71	9.20	1.32	74383.05
3	4.21	9.14	29.15	1.70	20.79	7.74	1.31	77751.58
4	3.97	10.71	30.14	1.66	18.58	8.86	1.31	70622.72
5	3.70	10.78	45.56	2.50	19.67	9.08	1.31	75568.99
6	4.37	10.46	58.08	2.72	20.35	8.24	1.31	81547.24
7	3.35	11.47	38.38	2.22	18.34	9.23	1.35	75340.19
8	4.64	11.65	44.18	2.51	20.70	8.65	1.36	77152.97
9	6.38	10.60	59.79	2.97	17.92	9.15	1.36	77337.77
10	9.33	10.85	58.35	3.63	19.14	8.93	1.36	78108.56
11	6.35	11.22	57.43	3.18	19.05	9.07	1.36	75424.58
12	7.27	11.18	48.50	2.89	18.18	8.88	1.36	77333.05
13	5.69	12.27	51.97	2.69	17.24	9.64	1.36	74272.09
14	3.01	11.29	56.96	2.44	19.07	9.54	1.35	70115.06
15	2.23	11.09	58.65	2.60	19.19	9.51	1.35	70605.48
16	3.55	11.01	55.87	2.73	19.31	8.95	1.35	75774.58
17	3.71	11.11	49.54	2.35	17.84	9.48	1.35	75653.34
18	3.06	10.95	50.72	2.48	19.22	9.25	1.36	72477.79
19	3.71	12.68	50.33	1.99	18.94	9.09	1.36	75004.83
20	7.96	11.70	56.97	3.01	19.09	8.99	1.36	72832.98
21	4.06	11.63	52.84	2.69	19.86	8.74	1.36	74775.88
22	6.57	12.79	48.13	2.71	19.51	8.99	1.36	75406.97
23	5.57	11.72	57.10	2.75	19.21	8.91	1.36	76288.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.12	11.38	49.28	2.59	19.15	9.01	1.34	75227.60
最大值	9.33	12.79	59.79	3.63	20.79	9.64	1.37	81547.24
發生時間	10	22	9	10	3	13		6
最小值	2.23	9.14	29.15	1.66	17.24	7.74	1.31	70115.06
發生時間	15	3	3	4	13	3		14
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.00 %		-0.02	-0.01	0.00 %
全幅偏移(率)	1.13 %	-0.14 %	1.28 %	0.47 %		0.39	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								