

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.74	11.95	49.99	1.72	17.23	11.39	1.29	81135.45
1	8.39	12.74	56.24	2.22	17.49	11.98	1.29	75823.34
2	10.06	12.04	49.85	3.17	16.14	11.60	1.29	79121.59
3	6.60	12.82	58.04	2.16	16.46	11.83	1.29	76165.48
4	11.77	12.08	52.59	1.73	17.44	11.45	1.29	81271.67
5	12.31	12.78	50.33	3.40	15.42	11.53	1.29	86040.60
6	9.55	12.99	52.68	2.62	16.35	11.59	1.29	80087.94
7	10.57	13.21	48.35	2.87	15.51	11.83	1.29	78798.73
8	8.65	13.08	46.62	2.31	16.01	11.72	1.29	78936.88
9	6.63	13.28	59.43	1.44	16.87	11.73	1.29	78186.12
10	11.38	12.86	55.24	2.35	15.37	11.59	1.29	79933.94
11	7.13	13.28	55.23	1.20	16.62	11.75	1.29	77245.34
12	10.06	12.96	49.64	1.43	16.54	11.51	1.29	78684.99
13	9.00	13.13	57.72	1.45	16.54	11.65	1.29	77486.74
14	10.70	13.15	48.76	1.79	16.13	11.53	1.29	80899.73
15	9.23	12.93	64.96	1.45	16.07	12.31	1.29	74282.40
16	7.82	11.48	50.28	1.39	16.73	11.34	1.31	81956.74
17	8.89	11.43	47.99	2.16	14.96	11.48	1.30	80386.69
18	10.68	11.62	52.31	1.77	16.33	11.52	1.31	80593.81
19	9.25	11.95	54.84	2.40	16.08	11.60	1.31	80416.59
20	9.69	12.16	55.24	2.26	16.61	11.65	1.30	79923.18
21	8.55	11.72	52.85	2.23	17.35	11.19	1.30	83239.17
22	7.69	12.00	51.02	2.34	16.19	11.59	1.31	80458.52
23	10.70	12.49	59.68	2.14	17.16	11.82	1.32	78312.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.33	12.51	53.33	2.08	16.40	11.63	1.30	79557.84
最大值	12.31	13.28	64.96	3.40	17.49	12.31	1.34	86040.60
發生時間	5	9	15	5	1	15		5
最小值	6.60	11.43	46.62	1.20	14.96	11.19	1.28	74282.40
發生時間	3	17	8	11	17	21		15
零點偏移(率)	-0.11 %	0.01 %	-0.03 %	-0.01 %		-0.04	-0.01	0.40 %
全幅偏移(率)	-1.68 %	-1.74 %	-1.12 %	-0.62 %		0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.76	11.88	50.09	1.42	18.65	9.97	1.02	79985.68
1	6.49	12.29	48.95	2.05	19.36	9.88	1.02	80504.38
2	10.36	11.75	50.70	2.09	17.54	9.98	1.02	79869.87
3	11.14	11.76	57.31	1.50	17.92	10.37	1.02	78458.06
4	8.12	11.85	54.65	1.01	18.87	9.98	1.02	80761.11
5	8.98	11.59	50.33	1.44	18.75	10.02	0.99	80001.27
6	12.34	13.22	43.25	2.71	16.99	10.17	0.97	86237.28
7	9.12	11.61	43.03	1.43	17.13	10.42	0.97	77718.84
8	12.62	11.70	47.90	1.31	18.03	10.37	0.97	81497.30
9	4.29	11.98	43.44	2.05	16.42	10.70	0.98	77993.09
10	10.92	11.59	41.67	1.12	18.41	10.12	0.98	76479.67
11	8.81	11.38	42.09	1.56	17.62	10.12	0.97	77930.43
12	8.11	11.63	44.13	2.10	15.91	10.50	0.97	75307.40
13	13.15	11.81	43.27	1.26	18.48	10.14	0.97	77269.88
14	9.05	11.88	48.17	1.69	17.37	10.31	0.97	81629.67
15	8.43	12.18	52.30	2.07	15.98	11.02	0.99	79171.04
16	7.33	11.42	37.92	1.80	17.12	9.96	1.00	78926.52
17	6.85	13.40	40.76	3.59	16.22	10.32	0.99	77668.74
18	12.23	12.25	47.98	1.37	15.00	10.95	1.01	78677.04
19	8.51	12.82	48.61	2.87	16.09	10.90	1.02	79782.17
20	13.94	12.18	47.07	2.56	16.33	10.80	1.02	79998.97
21	5.62	12.08	44.32	1.57	17.63	10.21	1.02	80089.10
22	11.05	11.67	42.43	1.78	17.80	10.04	1.00	79467.95
23	10.72	12.66	42.45	0.92	20.34	9.53	1.00	81417.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.66	12.02	46.37	1.80	17.50	10.28	1.00	79451.78
最大值	13.94	13.40	57.31	3.59	20.34	11.02	1.02	86237.28
發生時間	20	17	3	17	23	15		6
最小值	4.29	11.38	37.92	0.92	15.00	9.53	0.96	75307.40
發生時間	9	11	16	23	18	23		12
零點偏移(率)	-0.06 %	-0.06 %	-0.01 %	-0.01 %		-0.03	-0.01	0.00 %
全幅偏移(率)	-0.76 %	-1.80 %	-0.78 %	-0.25 %		0.13	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.06	11.00	45.48	0.63	18.48	9.48	1.39	76672.23
1	9.53	11.61	54.33	0.70	18.19	10.13	1.40	75685.55
2	7.50	11.34	56.82	0.66	17.82	10.11	1.39	75150.46
3	10.83	10.94	51.39	0.69	18.00	9.56	1.40	80537.94
4	11.19	11.21	48.88	0.72	17.50	9.55	1.40	81817.87
5	9.05	11.18	53.41	0.80	18.10	9.68	1.40	80640.09
6	9.66	11.40	51.02	0.71	16.90	10.02	1.39	78619.24
7	13.48	7.75	49.91	3.87	16.05	10.26	1.41	74792.18
8	9.11	11.44	49.80	3.28	16.61	9.99	1.41	76222.27
9	7.51	11.49	46.46	2.94	16.43	10.06	1.41	76223.96
10	10.33	11.60	46.87	2.55	16.17	10.04	1.41	75461.79
11	8.31	11.34	45.73	1.89	17.53	9.73	1.41	75093.50
12	7.23	11.46	46.65	1.82	17.10	9.76	1.40	73712.55
13	11.40	11.18	49.70	2.13	17.79	9.57	1.40	74897.95
14	8.39	11.62	47.33	2.14	18.45	9.61	1.40	76119.33
15	7.63	13.22	43.47	2.10	17.44	9.77	1.41	75705.55
16	9.04	14.76	41.60	2.83	14.45	10.06	1.41	76035.19
17	10.30	12.35	43.02	0.86	15.22	9.88	1.41	75904.16
18	9.33	11.78	44.71	1.40	17.58	9.81	1.41	76216.58
19	7.69	12.06	45.89	2.95	15.86	10.03	1.41	75841.08
20	9.67	12.02	45.31	3.57	15.22	9.95	1.41	74365.07
21	6.05	12.22	45.46	2.83	16.65	9.65	1.41	75302.01
22	11.64	11.63	57.81	3.37	15.58	10.45	1.42	76792.10
23	9.69	11.72	52.25	3.18	17.57	9.95	1.41	76308.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.32	11.60	48.47	2.03	16.95	9.88	1.40	76421.57
最大值	13.48	14.76	57.81	3.87	18.48	10.45	1.43	81817.87
發生時間	7	16	22	7	0	22		4
最小值	6.05	7.75	41.60	0.63	14.45	9.48	1.37	73712.55
發生時間	21	7	16	0	16	0		12
零點偏移(率)	-0.01 %	-0.09 %	-0.04 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	0.52 %	-0.38 %	0.07 %	-0.03 %		0.10	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								