

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月27日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.90	8.17	33.98	1.01	15.48	11.49	1.18	85058.97
1	9.31	7.97	39.66	0.94	16.17	11.66	1.18	82905.37
2	8.77	7.65	58.51	0.71	16.64	11.58	1.18	83319.30
3	9.42	7.81	57.68	0.34	17.40	11.01	1.18	87155.41
4	9.30	11.50	38.35	1.17	15.72	11.90	1.18	81232.15
5	13.76	10.75	50.86	0.71	17.60	10.84	1.14	88456.48
6	8.58	7.20	45.01	0.92	17.15	11.36	1.14	84523.66
7	8.19	5.57	50.30	0.65	16.93	11.70	1.14	81813.63
8	10.39	7.14	41.40	0.87	17.15	11.27	1.13	84848.37
9	9.69	7.35	46.55	0.87	16.66	11.62	1.11	82102.58
10	8.77	5.79	48.54	0.45	17.36	11.36	1.11	84058.97
11	9.57	6.94	30.29	1.05	15.99	11.35	1.12	85491.98
12	3.37	10.57	54.86	1.41	14.71	13.28	1.13	69552.55
13	6.86	10.56	57.71	2.04	13.87	13.68	1.13	66517.54
14	9.03	6.85	47.31	0.70	16.66	12.04	1.12	78765.32
15	4.49	8.55	60.03	0.51	17.31	12.02	1.12	78170.01
16	9.86	10.29	39.45	1.58	15.09	11.40	1.10	85449.07
17	9.79	6.77	40.76	1.64	15.53	11.54	1.10	84348.70
18	9.49	8.38	37.94	1.21	15.90	11.49	1.10	84272.92
19	8.74	10.22	43.06	1.39	15.65	11.84	1.11	81106.42
20	9.32	6.90	41.71	1.01	16.40	11.52	1.10	83601.94
21	9.25	6.28	42.24	0.81	16.41	11.67	1.12	82363.40
22	10.00	8.86	39.73	1.27	15.57	11.61	1.13	83284.37
23	8.31	9.53	52.42	0.94	15.91	12.24	1.13	77553.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.92	8.23	45.76	1.01	16.22	11.73	1.13	81914.68
最 大 值	13.76	11.50	60.03	2.04	17.60	13.68	1.19	88456.48
發生時間	5	4	15	13	5	13		5
最 小 值	3.37	5.57	30.29	0.34	13.87	10.84	1.10	66517.54
發生時間	12	7	11	3	13	5		13
零點偏移(率)	-0.43 %	0.00 %	-0.02 %	0.00 %		0.00		0.30 %
全幅偏移(率)	0.02 %	0.02 %	-0.12 %	0.03 %		0.11		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月27日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.90	1.48	42.74	2.21	13.36	12.04	1.02	74595.80
1	0.63	1.86	40.82	2.39	14.51	11.77	1.02	76087.69
2	2.04	1.29	39.76	1.79	14.97	11.51	1.02	78700.99
3	0.71	2.47	42.31	2.44	13.40	11.96	1.01	75821.43
4	0.48	7.79	44.96	1.85	14.54	11.64	0.99	78129.72
5	0.35	8.90	39.43	3.17	12.99	11.82	1.01	77245.86
6	0.72	8.25	37.81	1.90	15.03	11.22	1.02	73137.24
7	0.52	5.48	38.72	1.90	14.52	11.63	1.02	77941.05
8	3.78	4.39	31.28	1.70	15.50	11.24	1.02	78950.06
9	2.72	4.58	35.20	1.78	15.15	11.59	1.00	77008.24
10	9.37	9.55	39.47	1.98	14.00	11.87	0.99	75556.93
11	8.22	5.04	36.33	1.42	15.59	11.21	0.99	79760.36
12	4.82	3.94	23.91	2.31	13.27	11.46	0.99	75609.68
13	5.00	3.81	39.09	2.24	12.97	11.89	0.99	74052.26
14	4.14	4.06	49.93	2.10	13.10	11.92	0.99	75106.27
15	7.70	8.28	48.61	1.73	14.03	11.72	0.99	76970.58
16	1.87	9.15	37.23	2.44	12.02	11.85	1.00	75533.25
17	4.69	3.93	43.48	1.91	12.66	11.89	0.99	75333.14
18	5.97	8.39	50.29	2.24	12.81	12.01	0.99	74300.59
19	9.71	4.27	48.59	2.06	13.75	11.73	0.99	76189.02
20	7.06	3.80	42.98	2.13	13.37	11.70	0.99	76454.98
21	6.74	3.18	44.80	2.24	12.71	11.94	0.99	74846.01
22	8.56	4.06	50.33	1.88	13.40	11.71	1.00	76884.24
23	7.94	4.53	50.73	1.72	13.23	11.87	1.00	75446.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.44	5.10	41.62	2.06	13.79	11.72	1.00	76235.90
最 大 值	9.71	9.55	50.73	3.17	15.59	12.04	1.03	79760.36
發生時間	19	10	23	5	11	0		11
最 小 值	0.35	1.29	23.91	1.42	12.02	11.21	0.98	73137.24
發生時間	5	2	12	11	16	11		6
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.02 %		0.01		0.10 %
全幅偏移(率)	-0.78 %	0.35 %	0.19 %	0.02 %		0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年01月27日

報表日期: 113年01月27日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m ³ /Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.06	3.27	50.01	1.10	14.77	10.88	1.13	79386.99
1	8.65	3.62	54.52	0.61	16.73	10.75	1.13	80198.87
2	13.60	7.25	45.02	0.86	16.08	10.42	1.13	82536.77
3	6.80	7.74	45.43	0.68	15.36	10.93	1.13	80483.11
4	7.05	6.95	48.04	0.62	16.32	10.43	1.13	81103.85
5	10.48	7.42	45.22	1.00	15.66	10.49	1.15	80021.57
6	9.74	8.45	47.06	1.97	14.70	10.81	1.15	79022.58
7	11.56	8.61	56.80	0.95	15.32	11.38	1.12	72439.90
8	0.70	11.95	55.12	0.75	15.11	11.55	1.12	74860.74
9	2.60	5.06	44.62	1.28	15.55	10.57	1.10	83554.46
10	3.48	1.76	50.25	1.13	14.53	11.22	1.09	79240.45
11	5.94	8.11	44.07	1.04	14.46	11.19	1.10	78129.59
12	9.77	5.76	45.54	1.27	14.29	11.11	1.10	79720.68
13	10.58	4.80	44.43	0.89	14.82	11.04	1.10	78124.46
14	5.96	6.45	47.92	0.72	15.54	11.05	1.10	77795.72
15	6.56	4.54	41.06	0.49	17.26	10.28	1.10	81110.53
16	9.03	6.92	40.38	0.72	15.22	10.82	1.10	77955.06
17	5.82	3.86	43.95	0.66	15.57	10.55	1.10	79908.66
18	3.83	9.62	39.69	1.51	14.00	10.81	1.10	77789.37
19	3.17	3.72	34.21	0.50	15.19	10.40	1.10	75170.85
20	8.40	5.61	45.54	0.85	14.55	10.97	1.10	73600.13
21	11.54	3.59	44.67	1.66	13.64	11.31	1.09	74813.97
22	8.77	4.15	48.88	1.14	13.88	11.37	1.10	76795.67
23	9.12	4.37	46.99	1.03	15.68	10.63	1.10	80667.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.84	5.98	46.23	0.98	15.18	10.87	1.11	78517.97
最 大 值	15.06	11.95	56.80	1.97	17.26	11.55	1.15	83554.46
發生時間	0	8	7	6	15	8		9
最 小 值	0.70	1.76	34.21	0.49	13.64	10.28	1.09	72439.90
發生時間	8	10	19	15	21	15		7
零點偏移(率)	-0.11 %	0.00 %	-0.01 %	0.01 %		0.07		0.00 %
全幅偏移(率)	0.02 %	0.00 %	-0.12 %	-0.03 %		-0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								