

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.44	5.26	59.37	0.53	16.91	11.54	1.04	82275.87
1	7.17	6.13	47.32	0.54	16.92	11.22	1.03	84884.26
2	5.76	6.90	49.25	1.33	15.84	11.71	1.00	81333.07
3	7.31	5.27	58.32	1.13	17.22	11.53	1.00	82238.84
4	10.37	7.37	56.88	1.30	15.93	11.59	1.02	83049.47
5	6.16	6.55	71.42	0.83	15.60	12.94	1.02	79548.74
6	5.94	5.08	54.75	0.86	17.80	10.76	1.04	88116.55
7	6.84	5.98	59.24	0.47	18.56	10.95	1.05	85711.50
8	6.29	6.48	53.03	0.93	16.50	11.55	1.06	81966.56
9	5.21	6.38	59.17	0.91	16.65	12.41	1.06	74962.08
10	1.19	7.42	58.42	0.89	16.72	12.78	1.07	71730.94
11	5.67	1.83	41.34	0.81	17.07	11.34	1.04	83836.46
12	2.23	1.56	47.28	0.53	16.47	12.21	1.06	77083.02
13	1.69	1.71	50.01	0.45	16.96	11.82	1.05	80315.10
14	7.24	1.93	44.67	0.46	17.71	11.62	1.05	81084.96
15	6.92	1.78	57.49	0.39	17.34	12.08	1.06	76735.32
16	8.16	2.09	51.67	0.45	17.92	11.33	1.04	82483.93
17	9.05	5.46	46.29	0.53	18.28	10.84	1.04	86507.87
18	4.53	5.49	57.95	0.27	17.67	11.31	1.04	83036.12
19	6.33	5.44	49.08	0.65	17.70	11.05	1.03	85257.73
20	8.94	5.97	44.37	1.37	16.56	11.24	1.03	84383.37
21	10.91	5.56	47.95	1.67	16.36	11.67	1.03	81188.28
22	9.19	5.17	47.69	0.79	16.87	11.49	1.04	82381.16
23	8.77	4.94	60.57	0.40	18.03	11.38	1.03	82297.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.55	4.91	53.06	0.77	17.07	11.60	1.04	81767.01
最大值	10.91	7.42	71.42	1.67	18.56	12.94	1.12	88116.55
發生時間	21	10	5	21	7	5		6
最小值	1.19	1.56	41.34	0.27	15.60	10.76	0.99	71730.94
發生時間	10	12	11	18	5	6		10
零點偏移(率)	-0.05 %	-0.09 %	-0.01 %	0.00 %		-0.07		-0.10 %
全幅偏移(率)	0.00 %	0.84 %	-0.61 %	0.68 %		0.05		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.67	2.77	58.93	2.06	16.04	12.06	1.03	72601.47
1	2.99	2.36	31.47	1.80	16.99	10.86	1.02	81500.83
2	5.59	2.52	30.56	2.32	16.36	11.13	1.02	79669.91
3	9.28	2.57	32.42	2.72	16.60	11.09	1.03	79710.14
4	7.22	2.99	40.30	1.90	16.76	11.60	1.03	76256.23
5	5.47	5.70	36.42	2.10	16.91	11.23	1.02	79012.31
6	5.84	11.25	46.29	1.86	17.45	10.80	1.02	85850.18
7	8.12	4.23	44.55	2.28	16.26	11.49	1.02	77710.14
8	8.31	3.67	41.94	2.08	17.22	11.25	1.02	78311.54
9	4.37	3.94	50.18	0.85	18.81	11.16	1.01	77201.59
10	1.14	6.13	46.95	1.08	18.10	11.23	1.00	77385.56
11	1.47	12.55	54.44	1.29	17.12	11.45	1.02	76439.82
12	0.15	11.44	41.10	1.40	16.53	11.26	1.02	78095.26
13	1.07	10.46	45.92	1.03	17.63	11.10	1.02	78367.61
14	0.69	8.90	61.13	0.93	18.23	11.53	1.02	74244.87
15	7.23	9.58	37.83	1.52	16.84	11.04	1.02	79243.88
16	4.13	9.85	45.57	1.88	17.26	10.88	1.02	81031.48
17	1.80	8.46	56.93	1.63	17.28	10.98	1.02	79891.98
18	3.82	10.35	48.30	1.55	18.34	10.44	1.02	82875.03
19	9.19	5.79	44.57	1.89	19.01	9.97	1.02	85866.80
20	8.74	5.23	54.35	1.59	17.76	10.75	1.02	81396.06
21	8.43	5.82	58.14	0.91	19.35	10.29	1.02	82998.90
22	9.25	5.45	47.14	1.96	17.11	11.03	1.01	79634.46
23	3.77	2.09	63.12	1.35	17.56	11.54	1.00	75420.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.03	6.42	46.61	1.67	17.40	11.09	1.02	79196.54
最大值	9.28	12.55	63.12	2.72	19.35	12.06	1.04	85866.80
發生時間	3	11	23	3	21	0		19
最小值	0.15	2.09	30.56	0.85	16.04	9.97	0.98	72601.47
發生時間	12	23	2	9	0	19		0
零點偏移(率)	-0.06 %	-0.06 %	-0.02 %	-0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.14 %	0.13 %	0.09 %	0.14 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.61	5.83	65.40	0.53	16.74	11.66	1.10	72419.66
1	2.26	5.13	45.04	0.23	17.88	10.18	1.07	83380.07
2	2.34	3.11	44.55	0.63	15.78	10.80	1.09	80765.42
3	2.46	0.94	47.70	1.22	15.28	11.33	1.07	77614.98
4	3.42	2.36	52.86	0.93	15.62	11.26	1.09	76103.14
5	3.33	8.53	47.08	0.34	18.09	10.72	1.08	78475.26
6	3.07	4.66	41.44	0.45	16.45	10.52	1.05	77250.44
7	1.94	5.97	49.74	0.15	17.41	10.71	1.05	76353.86
8	1.24	3.81	48.78	0.18	17.67	10.47	1.08	78484.51
9	1.17	5.00	48.95	0.24	17.80	10.53	1.07	78952.39
10	1.18	4.38	51.65	0.32	17.43	10.38	1.08	79944.24
11	1.22	4.34	59.50	0.36	16.75	11.12	1.09	74062.38
12	1.23	6.87	56.01	0.38	16.51	11.17	1.05	75422.22
13	3.18	7.50	51.84	0.61	16.94	10.54	1.06	80169.27
14	4.34	4.78	52.89	0.45	17.43	10.77	1.08	75613.37
15	1.20	9.42	47.65	0.24	18.18	10.13	1.08	80051.42
16	1.09	2.77	36.35	0.16	17.47	9.79	1.05	76670.52
17	1.08	1.85	41.51	0.12	17.95	9.71	1.04	77038.12
18	1.12	1.68	44.30	0.12	17.54	10.12	1.05	76803.92
19	1.16	3.36	51.53	0.18	17.69	10.49	1.09	76474.75
20	1.13	6.12	46.32	0.19	17.60	10.18	1.09	78781.01
21	1.24	7.41	56.98	0.26	16.75	11.23	1.07	75859.55
22	1.37	6.19	50.83	0.40	16.95	10.39	1.05	81985.45
23	1.26	6.09	53.66	0.38	17.63	10.49	1.05	80765.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.90	4.92	49.69	0.38	17.15	10.61	1.07	77893.37
最大值	4.34	9.42	65.40	1.22	18.18	11.66	1.14	83380.07
發生時間	14	15	0	3	15	0		1
最小值	1.08	0.94	36.35	0.12	15.28	9.71	1.04	72419.66
發生時間	17	3	16	17	3	17		0
零點偏移(率)	-0.10 %	-0.04 %	-0.02 %	-0.02 %		-0.06		0.10 %
全幅偏移(率)	0.02 %	0.43 %	-0.71 %	0.54 %		-0.04		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								