

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.62	5.85	50.58	1.50	18.50	11.06	1.02	77697.71
1	9.72	5.84	52.49	1.80	18.65	11.24	1.03	76423.88
2	9.64	6.41	59.71	2.18	16.67	11.65	1.03	74645.37
3	9.08	10.02	55.12	2.61	16.08	11.68	1.03	75220.93
4	9.33	9.97	52.95	1.47	17.26	11.64	1.04	74634.50
5	11.01	7.41	62.37	2.51	16.80	11.54	1.04	75747.96
6	9.63	6.88	50.64	1.66	16.44	11.64	1.03	74903.55
7	9.34	8.58	58.36	2.24	16.24	11.55	1.02	75847.19
8	7.60	6.89	65.32	1.29	17.44	11.52	1.02	75158.96
9	7.86	7.48	55.58	1.41	16.99	11.64	0.99	74501.71
10	6.88	7.29	57.32	1.43	17.03	11.68	0.99	74008.58
11	4.99	7.07	59.46	1.41	17.47	11.63	1.02	73827.79
12	7.83	7.51	62.10	1.21	17.46	11.87	1.04	71651.73
13	8.19	7.07	48.20	0.72	18.75	11.17	1.05	76531.27
14	9.54	8.59	47.28	1.82	16.77	11.56	1.04	74813.95
15	9.91	6.33	54.47	2.73	16.62	11.71	1.03	72911.81
16	8.21	7.08	61.89	1.13	18.18	11.48	1.03	74363.57
17	8.96	10.39	53.90	1.32	16.88	11.63	1.02	74346.23
18	9.87	8.02	60.36	1.02	17.40	11.65	1.02	73826.14
19	6.58	7.77	66.68	0.98	18.18	11.64	1.02	73140.98
20	8.69	9.00	54.27	1.28	17.89	11.43	1.02	75167.41
21	9.68	7.60	66.03	1.07	18.47	11.29	1.02	75766.44
22	9.16	7.92	59.99	0.91	18.81	11.18	1.02	76132.03
23	9.23	8.07	62.26	0.89	19.19	11.26	1.02	74983.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.77	7.71	57.39	1.52	17.51	11.51	1.02	74843.89
最大值	11.01	10.39	66.68	2.73	19.19	11.87	1.06	77697.71
發生時間	5	17	19	15	23	12		0
最小值	4.99	5.84	47.28	0.72	16.08	11.06	0.99	71651.73
發生時間	11	1	14	13	3	0		12
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		-0.03		0.20 %
全幅偏移(率)	-0.85 %	1.81 %	-0.29 %	0.96 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.77	4.65	62.90	2.70	15.99	10.77	1.09	82154.63
1	9.63	3.76	41.84	2.24	18.03	9.71	1.09	88341.04
2	10.60	4.79	53.29	3.09	14.86	10.68	1.09	83946.35
3	9.51	7.86	56.49	3.68	14.01	10.70	1.09	85492.36
4	9.64	4.45	58.78	2.18	17.13	10.37	1.09	84862.12
5	8.29	2.71	47.46	2.21	16.74	10.48	1.07	85978.89
6	11.25	5.18	53.78	3.96	15.48	10.50	1.06	83624.33
7	7.90	3.69	57.13	3.44	14.93	10.50	1.06	85513.94
8	10.01	4.66	56.12	2.27	17.42	9.72	1.05	88963.39
9	9.21	2.91	56.66	3.00	15.01	10.67	1.03	83539.80
10	10.19	3.17	60.31	3.15	14.69	10.74	1.03	83847.21
11	9.29	3.33	52.62	3.61	14.75	10.59	1.04	85354.03
12	9.27	2.35	58.79	2.27	15.95	10.41	1.06	84538.05
13	7.42	4.35	60.58	1.56	17.38	9.98	1.06	87223.62
14	8.46	6.06	47.89	3.06	16.27	10.05	1.06	87578.65
15	8.80	4.32	51.11	3.24	15.28	10.43	1.06	85207.29
16	6.13	8.08	58.56	2.08	15.84	10.38	1.06	84874.14
17	8.13	8.40	54.99	1.92	17.38	9.98	1.06	86227.74
18	8.40	8.19	56.14	1.94	16.62	10.27	1.06	85220.23
19	10.74	4.95	56.68	1.77	17.54	9.89	1.07	87394.16
20	17.39	11.47	61.80	3.25	14.58	10.77	1.07	83158.84
21	10.36	3.92	52.01	2.32	16.55	10.17	1.06	86472.81
22	8.55	3.82	54.02	1.96	17.24	10.00	1.06	86453.49
23	9.02	9.53	56.14	1.86	17.23	10.10	1.06	85444.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	5.28	55.25	2.62	16.12	10.33	1.06	85475.49
最大值	17.39	11.47	62.90	3.96	18.03	10.77	1.15	88963.39
發生時間	20	20	0	6	1	0		8
最小值	6.13	2.35	41.84	1.56	14.01	9.71	1.02	82154.63
發生時間	16	12	1	13	3	1		0
零點偏移(率)	-0.07 %	-0.08 %	-0.09 %	0.00 %		0.06		0.00 %
全幅偏移(率)	0.02 %	-2.12 %	-0.54 %	-0.53 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年12月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.51	3.87	44.71	1.45	15.33	10.87	1.04	80994.75
1	9.74	8.73	53.32	1.57	16.02	10.88	1.03	79672.19
2	9.45	4.70	59.25	2.72	13.05	11.20	1.02	77334.32
3	8.62	4.79	56.14	2.08	14.29	11.04	1.02	77626.05
4	9.48	5.32	56.78	2.27	14.12	11.13	1.03	76671.95
5	10.03	5.93	60.87	2.64	15.26	10.97	1.03	80159.46
6	9.28	6.79	55.79	1.72	15.32	11.05	1.02	81280.24
7	8.36	4.92	47.22	1.73	15.03	10.88	1.02	78232.36
8	8.64	4.13	58.23	2.17	14.54	11.23	1.00	78277.64
9	9.85	6.57	55.62	2.10	15.17	10.75	1.02	81077.08
10	9.84	9.33	48.96	2.86	13.17	10.95	1.02	80855.98
11	7.77	5.48	61.89	3.03	12.62	11.58	1.00	73925.62
12	10.27	5.97	66.56	1.56	16.82	10.49	1.03	86106.04
13	8.03	7.67	59.85	2.07	14.34	11.33	1.02	79287.40
14	9.94	9.51	59.34	2.10	14.72	11.27	1.02	80298.69
15	12.54	9.27	59.36	4.84	12.11	11.70	1.02	76432.14
16	8.56	7.10	58.09	2.50	13.75	11.49	1.02	77134.31
17	9.44	3.32	65.98	1.85	15.13	11.22	1.02	78701.43
18	9.06	5.87	60.64	1.65	15.39	11.39	1.02	80580.06
19	9.03	6.69	58.83	1.31	15.62	11.31	1.02	80293.81
20	9.42	10.73	50.91	1.75	14.96	11.19	1.01	79811.12
21	8.43	5.00	58.24	1.29	16.05	11.09	1.02	81255.39
22	8.18	5.46	62.50	1.40	15.73	11.27	1.02	80933.14
23	9.13	5.16	63.15	1.39	16.20	11.09	1.04	82556.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.27	6.35	57.59	2.09	14.78	11.14	1.02	79562.39
最大值	12.54	10.73	66.56	4.84	16.82	11.70	1.04	86106.04
發生時間	15	20	12	15	12	15		12
最小值	7.77	3.32	44.71	1.29	12.11	10.49	0.99	73925.62
發生時間	11	17	0	21	15	12		11
零點偏移(率)	-0.06 %	0.01 %	-0.02 %	0.00 %		0.04		0.20 %
全幅偏移(率)	0.02 %	-1.50 %	-0.19 %	-0.48 %		0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								