

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月30日

報表日期: 113年07月30日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.98	3.24	60.04	3.51	16.65	11.48	1.03	82828.20
1	4.36	3.18	59.12	3.09	17.16	11.87	1.03	77631.60
2	5.16	3.91	52.70	1.72	16.31	11.65	1.04	81139.39
3	7.15	3.55	47.65	2.34	17.05	11.26	1.02	84790.48
4	5.78	3.30	56.34	3.47	17.08	11.28	1.02	84614.63
5	6.02	2.80	49.30	2.84	16.13	11.71	1.03	84048.01
6	7.40	2.65	54.76	2.00	17.16	11.72	1.04	80435.74
7	6.16	2.54	56.28	1.93	16.72	11.90	1.04	78902.36
8	4.53	2.50	56.52	1.58	17.45	11.60	1.06	81057.43
9	9.32	2.55	58.22	2.49	16.53	11.67	1.05	81202.28
10	7.76	2.36	63.22	1.50	17.78	11.62	1.04	81188.74
11	8.87	2.66	50.53	3.24	15.46	11.91	1.05	79782.30
12	2.00	6.82	48.41	3.43	14.47	12.08	1.06	75280.36
13	4.21	2.74	51.17	2.91	15.66	11.63	1.06	77098.28
14	7.24	3.00	50.78	2.35	16.01	11.74	1.06	77893.64
15	5.25	4.16	47.42	3.14	14.64	11.89	1.06	76203.41
16	6.03	5.65	47.36	3.64	14.33	12.22	1.03	73461.07
17	5.38	2.73	58.04	2.11	16.06	11.93	1.03	76803.46
18	5.02	3.28	52.97	2.96	15.11	12.12	1.04	78593.12
19	6.70	2.50	59.70	2.16	16.75	11.80	1.05	80147.03
20	10.50	2.65	59.98	2.21	16.67	11.60	1.06	80446.30
21	10.83	4.90	54.66	3.03	16.14	11.61	1.05	81108.65
22	8.72	2.84	61.12	1.77	16.67	11.90	1.05	78753.43
23	8.86	2.66	61.78	1.46	17.18	11.76	1.06	80600.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.51	3.30	54.92	2.54	16.30	11.75	1.04	79750.41
最 大 值	10.83	6.82	63.22	3.64	17.78	12.22	1.06	84790.48
發生時間	21	12	10	16	10	16		3
最 小 值	2.00	2.36	47.36	1.46	14.33	11.26	1.02	73461.07
發生時間	12	10	16	23	16	3		16
零點偏移(率)	-0.72 %	-0.01 %	-0.05 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	0.13 %	-0.65 %	0.35 %	-0.47 %		-0.10		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月30日

報表日期: 113年07月30日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	5.54	54.55	3.21	14.98	11.29	0.92	78761.43
1	7.41	5.96	53.61	2.54	16.37	10.96	0.92	80282.12
2	7.27	5.66	52.72	4.08	15.95	10.95	0.92	80181.45
3	4.48	5.17	54.97	3.76	16.13	10.82	0.96	81460.73
4	9.35	5.81	59.03	2.21	14.70	11.30	0.97	79260.73
5	9.36	6.23	59.72	2.57	14.15	11.73	0.97	78323.52
6	6.31	5.98	61.82	2.48	15.14	11.43	0.97	80163.66
7	8.11	2.12	60.44	2.04	15.68	11.31	0.93	79026.07
8	6.57	2.27	59.45	1.86	15.77	11.33	0.96	77813.28
9	8.89	2.24	60.53	2.12	15.31	11.33	0.92	78129.52
10	9.26	2.07	63.86	2.32	15.48	11.38	0.92	77787.22
11	5.12	2.31	61.54	2.40	14.40	11.68	0.92	76728.85
12	8.78	2.99	59.14	2.89	13.85	11.67	0.92	75961.07
13	4.07	4.06	56.61	3.18	13.33	11.66	0.91	74587.13
14	9.66	7.72	46.38	3.71	12.90	11.85	0.92	74630.30
15	3.83	3.83	54.73	1.94	13.19	11.89	0.93	72779.97
16	6.92	2.01	58.58	2.16	13.10	12.15	0.93	70193.34
17	3.53	2.77	56.71	1.71	14.65	11.29	0.94	75605.17
18	2.41	1.30	55.37	1.37	14.73	11.34	0.95	73353.49
19	15.23	2.54	58.74	3.77	15.60	11.18	0.97	77281.42
20	14.65	6.36	54.95	3.13	13.34	11.60	0.97	75985.26
21	17.18	3.70	54.58	2.02	15.13	11.22	0.98	77036.14
22	9.48	2.51	56.70	1.40	15.46	11.40	0.98	74933.68
23	9.56	2.22	60.23	1.76	16.98	11.04	0.95	77007.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.12	3.89	57.29	2.53	14.85	11.41	0.94	76969.70
最 大 值	17.18	7.72	63.86	4.08	16.98	12.15	0.99	81460.73
發生時間	21	14	10	2	23	16		3
最 小 值	2.41	1.30	46.38	1.37	12.90	10.82	0.90	70193.34
發生時間	18	18	14	18	14	3		16
零點偏移(率)	-0.04 %	0.00 %	-0.65 %	-0.12 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.13 %	-0.08 %	0.07 %		0.28		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								