

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月16日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 7.57     | 12.77    | 52.37    | 0.60     | 17.25    | 11.33    | 0.96     | 81363.08  |
| 1       | 5.54     | 12.66    | 53.12    | 0.27     | 19.55    | 10.83    | 0.98     | 83531.82  |
| 2       | 8.66     | 14.29    | 44.72    | 0.42     | 18.81    | 10.91    | 0.99     | 83167.13  |
| 3       | 5.42     | 15.97    | 48.81    | 0.23     | 19.59    | 10.60    | 0.99     | 84178.38  |
| 4       | 4.07     | 9.80     | 41.20    | 0.17     | 20.32    | 10.24    | 0.99     | 86808.50  |
| 5       | 2.74     | 13.98    | 41.83    | 0.59     | 17.67    | 10.97    | 0.99     | 81393.88  |
| 6       | 2.88     | 11.94    | 47.10    | 0.24     | 18.95    | 10.94    | 0.98     | 82064.22  |
| 7       | 7.41     | 11.99    | 50.19    | 0.24     | 19.13    | 10.70    | 0.99     | 84374.71  |
| 8       | 10.70    | 12.66    | 45.24    | 0.96     | 16.88    | 11.08    | 1.00     | 82620.51  |
| 9       | 6.67     | 5.92     | 50.09    | 0.76     | 17.25    | 11.34    | 0.99     | 78585.10  |
| 10      | 7.76     | 4.39     | 49.67    | 0.45     | 17.77    | 11.25    | 0.99     | 80313.73  |
| 11      | 8.01     | 4.59     | 53.44    | 0.76     | 17.26    | 11.37    | 0.99     | 81478.50  |
| 12      | 9.54     | 4.29     | 51.61    | 0.87     | 17.12    | 11.31    | 0.99     | 82115.95  |
| 13      | 7.94     | 4.05     | 56.86    | 0.81     | 17.33    | 11.60    | 0.99     | 80008.76  |
| 14      | 6.23     | 4.78     | 59.06    | 0.36     | 17.94    | 11.55    | 0.99     | 79726.21  |
| 15      | 5.44     | 6.40     | 54.22    | 0.49     | 17.32    | 11.53    | 0.99     | 78734.81  |
| 16      | 5.52     | 7.75     | 59.39    | 0.42     | 18.18    | 11.23    | 1.00     | 81298.98  |
| 17      | 9.28     | 7.79     | 54.28    | 0.44     | 18.33    | 10.88    | 0.98     | 83237.02  |
| 18      | 8.60     | 14.75    | 49.38    | 0.37     | 18.89    | 10.86    | 0.99     | 81081.46  |
| 19      | 9.53     | 8.01     | 49.07    | 0.39     | 18.39    | 10.79    | 0.98     | 81566.08  |
| 20      | 6.05     | 7.18     | 54.23    | 0.35     | 17.75    | 11.25    | 0.98     | 79034.32  |
| 21      | 10.22    | 7.62     | 53.95    | 0.94     | 17.11    | 11.27    | 0.98     | 80495.05  |
| 22      | 5.89     | 8.19     | 56.42    | 0.79     | 16.86    | 11.64    | 0.98     | 78165.79  |
| 23      | 4.09     | 10.84    | 56.47    | 0.44     | 17.21    | 11.42    | 0.99     | 79545.21  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 6.91     | 9.28     | 51.36    | 0.51     | 18.04    | 11.12    | 0.99     | 81453.72  |
| 最大值     | 10.70    | 15.97    | 59.39    | 0.96     | 20.32    | 11.64    | 1.02     | 86808.50  |
| 發生時間    | 8        | 3        | 16       | 8        | 4        | 22       |          | 4         |
| 最小值     | 2.74     | 4.05     | 41.20    | 0.17     | 16.86    | 10.24    | 0.95     | 78165.79  |
| 發生時間    | 5        | 13       | 4        | 4        | 22       | 4        |          | 22        |
| 零點偏移(率) | -0.07 %  | -0.06 %  | -0.02 %  | 0.00 %   |          | 0.00     |          | 0.00 %    |
| 全幅偏移(率) | 0.01 %   | 1.00 %   | -0.17 %  | 0.91 %   |          | -0.30    |          | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月16日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 5.32     | 7.98     | 50.78    | 0.73     | 17.35    | 9.98     | 1.07     | 79893.08  |
| 1       | 7.04     | 15.95    | 45.75    | 0.73     | 17.67    | 9.60     | 1.06     | 80553.36  |
| 2       | 7.05     | 9.75     | 45.43    | 0.91     | 17.95    | 9.51     | 1.07     | 78129.10  |
| 3       | 5.59     | 10.43    | 34.15    | 0.36     | 19.35    | 8.73     | 1.06     | 81831.06  |
| 4       | 0.93     | 9.24     | 40.94    | 0.62     | 17.27    | 9.68     | 1.07     | 77835.83  |
| 5       | 0.11     | 6.56     | 38.23    | 0.25     | 19.90    | 9.56     | 1.05     | 74338.35  |
| 6       | 1.77     | 8.60     | 30.82    | 0.46     | 18.18    | 9.08     | 1.07     | 86094.62  |
| 7       | 0.51     | 9.19     | 39.28    | 0.20     | 19.38    | 9.32     | 1.08     | 78107.19  |
| 8       | 1.41     | 13.35    | 40.06    | 0.63     | 17.98    | 9.39     | 1.10     | 81110.05  |
| 9       | 1.83     | 7.61     | 52.76    | 0.77     | 17.14    | 10.09    | 1.10     | 76020.27  |
| 10      | 6.92     | 4.66     | 54.40    | 0.54     | 18.95    | 9.48     | 1.10     | 82688.34  |
| 11      | 8.67     | 3.77     | 42.91    | 1.07     | 17.01    | 9.74     | 1.10     | 78455.33  |
| 12      | 9.03     | 5.72     | 50.72    | 1.14     | 17.47    | 9.85     | 1.10     | 79538.96  |
| 13      | 10.02    | 3.53     | 56.49    | 1.16     | 17.13    | 10.29    | 1.10     | 77485.21  |
| 14      | 5.99     | 2.92     | 44.82    | 0.89     | 17.58    | 10.12    | 1.10     | 72972.92  |
| 15      | 4.83     | 5.43     | 30.08    | 0.78     | 17.64    | 9.20     | 1.10     | 76903.01  |
| 16      | 4.38     | 4.33     | 53.59    | 0.42     | 19.10    | 9.89     | 1.10     | 76875.24  |
| 17      | 9.40     | 4.97     | 52.53    | 0.57     | 18.61    | 9.93     | 1.11     | 83521.10  |
| 18      | 9.12     | 4.32     | 57.54    | 0.42     | 19.23    | 9.92     | 1.10     | 83127.38  |
| 19      | 8.98     | 4.70     | 47.61    | 0.69     | 18.03    | 9.98     | 1.10     | 85226.33  |
| 20      | 9.58     | 4.41     | 54.70    | 0.72     | 17.67    | 10.12    | 1.10     | 83915.37  |
| 21      | 9.82     | 4.58     | 52.96    | 1.03     | 17.87    | 10.12    | 1.10     | 83572.00  |
| 22      | 9.38     | 4.65     | 59.04    | 1.12     | 17.72    | 10.10    | 1.10     | 83490.60  |
| 23      | 9.36     | 5.87     | 54.24    | 1.28     | 17.08    | 10.25    | 1.10     | 82368.51  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 6.13     | 6.77     | 47.08    | 0.73     | 18.05    | 9.75     | 1.09     | 80168.88  |
| 最大值     | 10.02    | 15.95    | 59.04    | 1.28     | 19.90    | 10.29    | 1.12     | 86094.62  |
| 發生時間    | 13       | 1        | 22       | 23       | 5        | 13       |          | 6         |
| 最小值     | 0.11     | 2.92     | 30.08    | 0.20     | 17.01    | 8.73     | 1.05     | 72972.92  |
| 發生時間    | 5        | 14       | 15       | 7        | 11       | 3        |          | 14        |
| 零點偏移(率) | -0.06 %  | -0.02 %  | -0.02 %  | -0.00 %  |          | -0.29    |          | 0.00 %    |
| 全幅偏移(率) | 0.04 %   | 0.14 %   | -0.24 %  | 0.50 %   |          | -0.18    |          | 0.00 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月16日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 1.62     | 13.99    | 54.66    | 1.65     | 15.44    | 11.22    | 0.96     | 78181.73  |
| 1       | 0.70     | 13.08    | 51.22    | 1.18     | 17.07    | 10.81    | 0.99     | 80553.56  |
| 2       | 1.10     | 13.16    | 46.90    | 2.00     | 15.43    | 10.96    | 0.99     | 77195.77  |
| 3       | 3.00     | 9.94     | 47.31    | 2.02     | 15.53    | 10.80    | 0.99     | 79615.39  |
| 4       | 1.60     | 10.75    | 49.65    | 1.73     | 15.50    | 10.85    | 0.98     | 80140.93  |
| 5       | 3.43     | 12.30    | 49.74    | 2.12     | 15.20    | 11.34    | 0.97     | 80532.98  |
| 6       | 4.06     | 7.96     | 47.79    | 1.91     | 15.31    | 10.86    | 0.96     | 77670.91  |
| 7       | 4.33     | 10.99    | 46.58    | 1.29     | 16.97    | 10.52    | 0.97     | 78186.93  |
| 8       | 5.08     | 15.00    | 41.86    | 1.26     | 17.20    | 10.36    | 0.97     | 80493.09  |
| 9       | 4.14     | 3.69     | 54.85    | 1.29     | 16.67    | 11.07    | 0.98     | 76814.90  |
| 10      | 3.95     | 4.62     | 50.87    | 1.31     | 16.58    | 10.91    | 0.95     | 78348.28  |
| 11      | 5.95     | 3.87     | 53.13    | 1.91     | 15.48    | 11.04    | 0.94     | 79469.80  |
| 12      | 6.60     | 10.15    | 53.94    | 2.34     | 14.70    | 11.42    | 0.94     | 77692.71  |
| 13      | 8.78     | 5.84     | 54.65    | 2.17     | 15.48    | 11.50    | 0.94     | 77333.11  |
| 14      | 7.79     | 5.36     | 55.86    | 2.12     | 16.03    | 11.14    | 0.94     | 78447.51  |
| 15      | 6.75     | 7.35     | 51.20    | 2.62     | 14.85    | 11.44    | 0.94     | 75659.65  |
| 16      | 9.52     | 7.30     | 50.31    | 2.11     | 16.81    | 10.75    | 0.95     | 81853.66  |
| 17      | 4.97     | 6.55     | 55.50    | 1.52     | 17.03    | 10.68    | 0.99     | 82967.99  |
| 18      | 10.07    | 6.68     | 51.74    | 1.70     | 16.92    | 10.70    | 0.97     | 84589.64  |
| 19      | 7.37     | 6.49     | 52.38    | 1.44     | 17.29    | 10.52    | 0.94     | 85548.86  |
| 20      | 7.79     | 10.39    | 54.22    | 1.73     | 15.95    | 10.93    | 0.94     | 82208.58  |
| 21      | 8.88     | 6.14     | 56.18    | 2.28     | 16.50    | 10.86    | 0.96     | 82463.82  |
| 22      | 11.38    | 9.32     | 50.37    | 2.85     | 15.58    | 10.90    | 0.96     | 79689.91  |
| 23      | 7.80     | 7.53     | 54.43    | 1.75     | 16.94    | 10.63    | 0.94     | 81884.82  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 5.69     | 8.69     | 51.47    | 1.85     | 16.10    | 10.93    | 0.96     | 79897.69  |
| 最大值     | 11.38    | 15.00    | 56.18    | 2.85     | 17.29    | 11.50    | 1.01     | 85548.86  |
| 發生時間    | 22       | 8        | 21       | 22       | 19       | 13       |          | 19        |
| 最小值     | 0.70     | 3.69     | 41.86    | 1.18     | 14.70    | 10.36    | 0.92     | 75659.65  |
| 發生時間    | 1        | 9        | 8        | 1        | 12       | 8        |          | 15        |
| 零點偏移(率) | -0.02 %  | -0.01 %  | -0.24 %  | -0.12 %  |          | -0.01    |          | 0.00 %    |
| 全幅偏移(率) | -3.08 %  | 0.70 %   | -1.36 %  | 0.33 %   |          | 0.20     |          | 0.10 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |