

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.32	5.49	64.26	1.57	18.48	12.41	1.47	67926.27
1	0.92	5.73	51.60	1.49	18.80	11.97	1.46	71129.61
2	2.42	3.75	60.57	1.32	19.73	12.06	1.46	69005.11
3	2.24	4.33	63.79	1.43	18.72	12.27	1.45	68434.56
4	0.92	4.10	48.97	1.46	18.69	12.12	1.41	69906.53
5	0.06	9.96	51.18	1.73	17.48	12.38	1.40	71783.51
6	1.13	2.39	48.58	1.50	18.58	11.37	1.42	76090.01
7	4.15	2.96	50.57	1.71	18.05	11.66	1.43	73483.40
8	4.17	2.67	47.52	1.67	18.54	11.43	1.44	74737.93
9	2.70	2.53	47.26	1.62	17.99	11.89	1.41	71005.86
10	0.15	2.83	53.80	1.41	18.10	11.82	1.43	72188.09
11	0.21	3.39	46.81	1.42	18.30	11.66	1.44	73135.17
12	6.84	6.87	43.69	2.26	18.11	11.55	1.44	73869.48
13	6.40	9.62	44.22	2.00	18.23	11.55	1.44	72839.57
14	8.15	2.73	47.15	1.79	18.19	11.51	1.42	73756.03
15	1.89	1.38	53.48	1.33	18.72	11.35	1.43	74333.92
16	2.21	1.18	59.93	1.19	19.75	11.41	1.48	73550.84
17	8.47	1.53	48.42	1.54	19.27	11.19	1.44	75593.49
18	2.47	2.57	51.34	1.31	19.01	11.41	1.40	74497.25
19	6.55	3.36	54.30	1.55	18.23	11.65	1.45	73239.93
20	6.42	6.89	48.08	1.77	18.03	11.56	1.44	74156.98
21	2.05	1.06	57.22	1.27	19.29	11.34	1.42	74375.34
22	8.85	2.06	52.66	1.66	18.64	11.66	1.40	72634.93
23	4.36	2.67	58.55	1.42	19.38	11.68	1.40	72180.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.50	3.84	52.25	1.56	18.60	11.70	1.43	72660.59
最大值	8.85	9.96	64.26	2.26	19.75	12.41	1.49	76090.01
發生時間	22	5	0	12	16	0		6
最小值	0.06	1.06	43.69	1.19	17.48	11.19	1.38	67926.27
發生時間	5	21	12	16	5	17		0
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.27 %	0.27 %	-0.36 %	0.17 %		0.34	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.32	2.89	44.12	0.90	18.58	9.72	1.49	65697.43
1	1.16	1.02	63.89	1.24	17.00	10.95	1.50	60575.58
2	1.94	0.89	59.26	0.66	19.91	10.51	1.51	63776.83
3	1.82	1.61	46.72	1.00	17.95	10.36	1.48	66876.97
4	1.84	4.44	61.82	1.27	16.77	10.67	1.45	65631.57
5	1.74	2.54	62.15	1.04	17.95	10.32	1.44	65789.04
6	0.69	1.94	51.86	1.36	16.69	10.50	1.45	61623.04
7	1.16	1.61	68.21	1.35	16.65	10.78	1.46	60982.37
8	1.40	1.61	57.55	1.27	17.18	10.69	1.45	63011.66
9	0.23	1.64	55.83	1.26	17.00	10.81	1.46	61217.99
10	0.12	2.97	66.89	1.39	16.15	11.59	1.46	58253.22
11	0.11	1.85	50.16	1.21	16.95	10.62	1.46	64705.57
12	1.17	4.28	60.33	1.38	16.27	10.46	1.46	64338.46
13	5.06	4.10	55.87	1.71	16.17	10.26	1.42	62980.23
14	6.23	2.37	51.86	1.88	15.84	10.69	1.41	62548.51
15	1.77	1.24	63.63	1.49	16.31	11.03	1.41	62228.59
16	6.47	2.60	57.77	1.55	17.22	10.54	1.43	62348.80
17	2.86	2.17	58.41	1.26	17.15	10.23	1.44	66469.36
18	4.54	1.80	58.03	1.28	17.37	10.21	1.42	66598.98
19	6.78	1.96	66.18	1.52	16.61	10.49	1.43	63925.19
20	5.98	2.26	58.85	1.44	16.78	10.53	1.49	63431.77
21	5.15	1.76	56.70	1.42	16.97	10.53	1.47	64472.66
22	3.08	1.61	60.09	1.05	18.06	10.35	1.44	66178.77
23	1.92	2.20	59.34	1.08	17.42	10.48	1.43	65145.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.69	2.22	58.15	1.29	17.12	10.56	1.45	63700.35
最大值	6.78	4.44	68.21	1.88	19.91	11.59	1.52	66876.97
發生時間	19	4	7	14	2	10		3
最小值	0.11	0.89	44.12	0.66	15.84	9.72	1.38	58253.22
發生時間	11	2	0	2	14	0		10
零點偏移(率)	-0.14 %	0.00 %	-0.01 %	-0.01 %		-0.05	0.00	0.00 %
全幅偏移(率)	1.30 %	0.93 %	0.05 %	0.17 %		0.13	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.57	3.76	64.97	0.71	16.20	10.84	1.82	83746.45
1	1.37	3.57	56.39	0.65	16.55	10.57	1.81	83773.13
2	1.08	0.90	64.11	0.59	16.96	11.10	1.83	84118.55
3	2.28	6.25	55.05	0.74	16.15	10.82	1.81	87401.03
4	2.18	2.38	66.34	1.12	14.94	11.21	1.78	85437.63
5	2.68	4.52	65.12	0.87	16.03	11.00	1.82	87426.91
6	2.26	2.23	59.58	0.89	15.85	10.87	1.81	86649.96
7	0.94	5.48	62.84	0.85	15.18	11.25	1.83	87069.15
8	1.24	5.17	66.85	0.79	15.96	11.05	1.86	85868.16
9	0.56	7.92	53.46	0.41	16.50	10.96	1.83	81553.99
10	0.22	3.64	60.73	0.72	15.55	10.88	1.86	82536.34
11	0.09	11.51	58.41	0.94	15.24	10.89	1.85	82841.26
12	2.25	9.59	56.34	1.26	14.67	11.01	1.85	83055.90
13	3.36	6.09	59.61	1.09	14.95	10.97	1.87	82205.45
14	6.97	12.05	51.66	2.02	13.28	11.11	1.86	77442.90
15	12.66	1.99	59.16	2.25	13.54	11.50	1.86	79248.19
16	2.95	1.67	63.34	1.32	14.74	11.42	1.86	82293.43
17	2.52	1.24	61.20	1.00	15.24	11.17	1.85	83714.12
18	2.98	7.85	59.13	1.06	15.15	11.09	1.83	83985.99
19	3.19	2.01	61.37	1.47	14.05	11.37	1.82	81901.45
20	4.74	6.14	55.94	1.56	14.39	11.13	1.82	82198.23
21	4.70	10.42	58.92	1.77	13.79	11.49	1.85	79904.79
22	4.00	3.77	62.70	1.47	14.25	11.37	1.84	80800.47
23	5.05	6.28	64.00	1.03	15.54	11.34	1.80	84070.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.99	5.27	60.30	1.11	15.20	11.10	1.83	83301.84
最大值	12.66	12.05	66.85	2.25	16.96	11.50	1.89	87426.91
發生時間	15	14	8	15	2	15		5
最小值	0.09	0.90	51.66	0.41	13.28	10.57	1.77	77442.90
發生時間	11	2	14	9	14	1		14
零點偏移(率)	0.00 %	-0.01 %	-0.10 %	-0.01 %		-0.22	0.00	0.00 %
全幅偏移(率)	2.54 %	0.56 %	-0.16 %	0.24 %		0.12	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								