

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.50	2.65	53.34	1.37	15.02	11.84	1.25	81520.28
1	1.48	2.26	49.60	1.39	15.82	11.71	1.25	82204.09
2	4.72	1.95	42.75	1.97	14.66	11.83	1.25	82564.01
3	14.69	2.05	39.60	2.71	14.18	11.91	1.25	82490.90
4	16.31	2.21	52.03	1.84	15.09	11.73	1.25	82596.47
5	5.74	2.37	52.08	2.44	15.69	11.65	1.27	81838.02
6	7.64	1.95	56.47	1.95	16.07	11.40	1.28	84285.16
7	8.80	1.99	46.03	1.62	14.58	11.70	1.27	83271.06
8	9.56	1.79	52.36	1.44	15.63	11.47	1.27	83896.82
9	9.64	1.89	54.23	1.03	17.11	11.06	1.27	86607.52
10	13.82	4.18	49.64	3.32	13.39	11.77	1.29	84378.06
11	9.52	3.42	47.80	2.98	13.11	11.95	1.29	81184.09
12	8.31	2.25	57.85	1.53	15.14	11.79	1.29	83106.10
13	10.93	2.04	50.64	1.96	14.66	11.87	1.29	82251.09
14	9.40	1.97	48.32	2.13	14.53	11.80	1.29	82850.43
15	9.65	2.04	50.86	2.25	14.54	11.80	1.29	82980.25
16	9.23	1.92	50.86	2.05	15.09	11.55	1.29	84609.55
17	9.23	1.96	58.28	1.68	14.81	11.80	1.29	82401.76
18	10.87	2.10	50.15	1.07	16.35	11.16	1.27	86638.77
19	9.00	2.54	55.86	0.62	17.83	10.60	1.27	90083.92
20	9.97	2.47	42.52	1.00	16.94	11.00	1.26	87445.32
21	8.40	2.32	36.92	1.89	15.11	11.43	1.25	85288.96
22	8.56	2.64	45.61	1.99	14.77	11.89	1.26	81838.17
23	9.03	2.56	56.45	1.01	16.88	11.43	1.25	84037.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.00	2.31	50.01	1.80	15.29	11.59	1.27	83765.37
最 大 值	16.31	4.18	58.28	3.32	17.83	11.95	1.31	90083.92
發生時間	4	10	17	10	19	11		19
最 小 值	1.48	1.79	36.92	0.62	13.11	10.60	1.24	81184.09
發生時間	1	8	21	19	11	19		11
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.01 %		0.10		0.20 %
全幅偏移(率)	0.00 %	0.23 %	-0.26 %	-0.50 %		0.46		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月10日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	7.39	2.26	66.09	1.92	14.12	11.27	1.51	80512.34
1	3.78	1.19	63.60	1.60	14.84	11.30	1.51	77488.10
2	6.78	6.59	48.84	2.28	14.04	11.04	1.49	79750.99
3	5.62	1.52	53.94	2.12	14.75	11.02	1.48	80281.58
4	6.03	2.33	55.66	2.20	13.92	11.39	1.49	77793.93
5	7.92	2.51	53.96	1.88	15.86	10.59	1.51	83228.74
6	7.65	1.64	51.46	2.30	14.74	10.93	1.51	81453.17
7	11.92	5.29	53.38	3.59	13.72	11.14	1.52	78734.26
8	8.24	2.73	56.68	3.64	13.75	11.18	1.52	77667.01
9	12.97	3.11	56.72	4.29	14.05	11.12	1.52	77957.51
10	5.13	1.43	54.71	3.36	13.72	11.25	1.48	78656.05
11	8.67	2.07	57.95	3.89	13.70	11.18	1.48	77871.31
12	10.64	3.18	57.19	4.09	13.09	11.24	1.48	78470.45
13	8.17	6.96	57.04	2.89	12.48	11.46	1.48	75834.88
14	12.84	7.88	58.95	1.01	12.70	11.40	1.49	79625.91
15	8.42	6.82	50.81	0.97	12.65	11.17	1.49	77570.40
16	10.63	5.38	50.52	0.76	14.08	10.79	1.48	79108.92
17	8.20	4.56	58.35	0.70	14.39	10.78	1.49	78759.14
18	8.21	4.84	51.02	0.72	14.22	10.54	1.49	79767.07
19	13.99	5.70	50.40	0.89	13.69	10.40	1.48	80412.04
20	16.86	4.31	54.93	1.20	12.76	11.00	1.49	77755.18
21	9.58	5.22	59.57	1.44	13.22	11.34	1.49	80157.36
22	7.96	9.47	60.54	1.87	14.69	10.91	1.49	80068.62
23	8.64	5.12	54.86	1.88	14.75	10.70	1.49	80835.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.01	4.25	55.72	2.15	13.91	11.05	1.49	79156.69
最 大 值	16.86	9.47	66.09	4.29	15.86	11.46	1.53	83228.74
發生時間	20	22	0	9	5	13		5
最 小 值	3.78	1.19	48.84	0.70	12.48	10.40	1.48	75834.88
發生時間	1	1	2	17	13	19		13
零點偏移(率)	-0.36 %	0.00 %	-0.01 %	-0.01 %		0.03		0.10 %
全幅偏移(率)	0.02 %	-0.06 %	-0.19 %	0.00 %		0.17		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								