

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.16	15.18	61.88	2.26	15.14	12.29	1.23	74995.91
1	10.49	14.79	53.15	2.59	16.73	11.35	1.20	81255.26
2	8.96	14.69	54.48	2.33	15.96	11.70	1.18	78928.74
3	10.55	13.83	57.76	3.10	15.53	11.36	1.18	82331.42
4	9.95	14.27	52.76	3.91	13.77	11.61	1.18	77190.75
5	5.10	14.56	55.19	3.66	13.89	12.59	1.24	69522.54
6	15.12	13.19	53.32	3.70	14.49	11.90	1.25	75091.45
7	7.80	13.27	46.35	3.80	14.16	11.96	1.25	75783.88
8	12.54	13.31	55.00	2.26	15.27	11.90	1.25	76617.10
9	8.97	13.46	52.45	3.08	14.76	11.93	1.25	77440.35
10	10.49	13.25	58.28	2.91	14.63	11.91	1.26	77305.90
11	7.90	12.48	53.49	2.78	14.80	11.34	1.27	80271.84
12	10.76	13.41	55.13	2.37	14.53	11.78	1.26	78700.19
13	12.32	13.28	54.40	2.44	15.35	11.76	1.25	79007.13
14	8.59	13.80	55.49	2.38	14.74	12.23	1.25	75025.03
15	11.58	13.06	54.76	2.42	15.23	11.71	1.26	79825.81
16	8.97	13.56	57.89	2.28	14.99	12.09	1.27	76463.05
17	13.15	12.55	54.98	2.55	14.98	11.33	1.25	83152.44
18	8.03	12.79	50.49	2.90	14.49	11.28	1.22	80216.97
19	12.87	13.39	52.93	2.61	14.86	11.85	1.21	73880.73
20	9.50	12.22	49.97	1.95	15.82	11.41	1.24	78128.63
21	10.78	13.89	44.75	2.07	15.44	11.27	1.25	81490.49
22	13.75	12.01	53.44	2.43	14.73	11.79	1.26	78553.76
23	10.81	11.85	52.49	2.65	15.01	11.46	1.26	80857.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.34	13.42	53.78	2.73	14.97	11.74	1.24	78001.55
最大值	15.12	15.18	61.88	3.91	16.73	12.59	1.28	83152.44
發生時間	6	0	0	4	1	5		17
最小值	5.10	11.85	44.75	1.95	13.77	11.27	1.18	69522.54
發生時間	5	23	21	20	4	21		5
零點偏移(率)	0.00 %	-0.01 %	-0.03 %	0.01 %		-0.05	-0.01	0.30 %
全幅偏移(率)	-1.97 %	-0.82 %	-0.83 %	-1.18 %		0.03	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.69	12.54	50.63	3.08	13.52	11.61	1.05	77197.31
1	10.24	12.52	49.58	3.13	15.17	11.43	1.06	78291.91
2	9.93	12.51	51.65	3.40	14.73	11.50	1.04	76964.32
3	9.24	11.88	47.06	3.11	16.27	10.74	1.04	77527.27
4	10.42	11.43	41.69	3.57	15.51	10.47	1.04	76526.59
5	11.57	11.51	45.93	3.76	15.45	10.57	1.04	75461.47
6	9.74	12.11	48.54	4.36	14.29	11.34	1.05	76014.91
7	7.88	12.11	45.35	3.04	14.64	11.20	1.04	76688.00
8	14.13	12.33	51.07	2.00	14.33	11.39	1.06	76619.94
9	12.36	12.36	56.46	1.99	14.16	11.45	1.06	76710.58
10	11.21	12.11	58.29	2.19	13.78	11.31	1.06	76055.57
11	12.73	12.05	57.72	2.68	13.62	11.26	1.06	76865.99
12	11.59	12.33	57.59	2.58	13.25	11.51	1.04	74726.02
13	10.90	12.55	55.60	2.63	13.12	11.48	1.05	74313.07
14	10.59	12.63	58.88	2.40	13.18	11.53	1.03	73470.60
15	10.74	12.29	61.10	2.29	13.77	11.31	1.05	74468.10
16	8.80	12.45	62.91	1.95	14.99	11.25	1.06	74886.92
17	11.58	12.92	59.46	2.13	15.66	11.08	1.06	73947.77
18	11.62	11.81	51.28	2.83	14.75	10.62	1.04	79117.19
19	9.41	12.38	48.79	2.08	14.59	11.10	1.02	74858.23
20	12.53	12.98	52.74	1.53	15.47	10.96	1.02	75763.29
21	12.83	12.84	53.87	2.06	15.62	10.67	1.02	77344.26
22	9.54	12.78	49.89	1.61	15.47	10.65	1.04	77360.41
23	11.04	12.83	52.33	2.01	15.60	10.68	1.05	76460.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.80	12.34	52.85	2.60	14.62	11.13	1.04	76151.69
最大值	14.13	12.98	62.91	4.36	16.27	11.61	1.06	79117.19
發生時間	8	20	16	6	3	0		18
最小值	7.88	11.43	41.69	1.53	13.12	10.47	1.02	73470.60
發生時間	7	4	4	20	13	4		14
零點偏移(率)	-0.15 %	-0.01 %	-0.03 %	-0.01 %		-0.10	-0.01	0.10 %
全幅偏移(率)	0.10 %	0.38 %	-0.00 %	-0.01 %		-0.07	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.01	10.87	48.24	3.48	14.49	9.89	1.42	68765.57
1	9.67	10.81	46.36	2.89	16.50	9.56	1.41	68929.24
2	11.21	10.48	44.10	3.42	14.95	9.52	1.41	68313.62
3	16.95	10.39	44.72	3.97	14.89	9.48	1.42	69801.09
4	9.60	10.77	48.89	2.96	14.73	9.99	1.42	69454.45
5	11.13	11.58	53.96	4.13	15.45	10.01	1.43	72127.41
6	9.26	12.24	50.07	3.68	14.71	10.33	1.43	70137.46
7	12.74	11.33	50.20	4.22	15.14	10.01	1.46	70336.94
8	12.50	11.55	54.42	2.63	13.74	10.49	1.45	70083.37
9	9.31	11.55	52.79	2.94	13.74	10.37	1.43	71097.06
10	9.85	11.45	51.39	3.18	14.32	10.33	1.43	70084.22
11	10.87	11.24	57.34	2.83	15.57	10.01	1.46	71577.00
12	9.22	11.51	52.73	2.40	14.69	10.10	1.43	70196.60
13	10.69	12.41	53.56	2.26	14.38	10.26	1.43	69097.18
14	8.95	11.80	51.39	1.97	14.80	9.98	1.43	70905.43
15	8.91	11.20	54.11	1.93	15.01	10.00	1.45	70983.53
16	10.03	11.26	52.67	1.95	15.58	10.00	1.43	71810.08
17	9.70	11.33	53.90	1.87	15.59	10.22	1.43	70753.01
18	9.65	11.00	52.63	2.18	17.18	9.58	1.43	74811.27
19	9.90	11.00	50.23	2.79	16.37	9.62	1.43	74576.78
20	8.41	11.31	55.03	2.03	15.34	10.31	1.43	69452.21
21	10.91	11.10	44.38	1.75	16.85	9.39	1.43	74681.54
22	8.46	10.93	45.71	1.94	14.48	9.94	1.43	69935.95
23	11.37	11.32	51.42	2.30	14.40	9.84	1.43	71666.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.51	11.27	50.84	2.74	15.12	9.97	1.43	70815.74
最大值	16.95	12.41	57.34	4.22	17.18	10.49	1.48	74811.27
發生時間	3	13	11	7	18	8		18
最小值	8.41	10.39	44.10	1.75	13.74	9.39	1.40	68313.62
發生時間	20	3	2	21	8	21		2
零點偏移(率)	-0.03 %	0.00 %	-0.09 %	-0.01 %		-0.09	-0.01	0.00 %
全幅偏移(率)	-0.47 %	1.27 %	-0.05 %	0.03 %		0.00	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								