

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.24	10.81	69.26	2.32	16.64	12.36	1.11	67096.18
1	8.42	6.43	66.61	2.13	18.37	11.69	1.10	70553.54
2	8.64	8.80	51.78	2.75	17.78	11.13	1.10	74260.19
3	9.15	6.48	51.62	3.22	15.91	11.21	1.10	73046.59
4	9.49	6.83	57.36	2.48	16.63	11.50	1.10	72053.37
5	6.82	9.43	51.41	1.30	17.39	11.51	1.11	73240.84
6	6.46	6.87	54.70	1.20	18.06	11.39	1.11	73348.60
7	3.66	8.06	59.15	1.01	17.44	11.93	1.11	70573.78
8	7.50	7.76	52.40	1.62	17.27	11.49	1.10	73074.36
9	8.76	8.24	45.42	2.25	15.93	11.57	1.09	71948.07
10	8.32	7.49	57.41	1.37	17.68	11.49	1.09	72410.56
11	8.92	7.85	51.30	1.73	17.17	11.44	1.07	74025.80
12	6.22	7.20	53.78	1.26	17.42	11.65	1.08	72091.31
13	2.64	7.37	64.98	0.82	18.50	11.71	1.10	71270.14
14	0.88	7.34	67.12	0.47	18.80	11.23	1.10	74341.45
15	1.09	7.93	54.52	0.89	18.09	11.26	1.07	74839.93
16	2.87	8.46	48.58	1.09	18.38	11.06	1.09	76150.98
17	6.98	8.66	53.22	1.19	18.59	10.99	1.10	77038.03
18	6.25	11.09	43.57	1.53	17.38	10.79	1.08	77494.03
19	9.32	9.28	45.82	2.06	16.83	10.96	1.08	74610.64
20	4.84	8.11	52.26	0.94	18.66	10.76	1.10	77481.25
21	4.69	9.89	47.66	0.92	18.56	10.88	1.10	76124.28
22	2.41	10.62	57.45	0.75	17.99	11.54	1.10	72116.78
23	1.02	10.33	44.07	1.07	17.47	11.18	1.10	72956.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.86	8.39	54.23	1.52	17.62	11.36	1.09	73422.79
最大值	9.49	11.09	69.26	3.22	18.80	12.36	1.12	77494.03
發生時間	4	18	0	3	14	0		18
最小值	0.88	6.43	43.57	0.47	15.91	10.76	1.06	67096.18
發生時間	14	1	18	14	3	20		0
零點偏移(率)	0.00 %	-0.01 %	-0.19 %	-0.00 %		0.02		0.00 %
全幅偏移(率)	0.02 %	-0.15 %	0.84 %	-0.17 %		0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.47	6.56	64.80	1.73	16.97	10.84	1.03	81590.38
1	7.99	10.68	51.07	2.30	17.24	10.35	1.04	84841.23
2	7.87	3.57	57.79	2.43	16.92	10.49	1.05	84201.55
3	6.52	5.77	49.47	1.86	17.39	10.16	1.04	86671.85
4	4.46	9.12	47.55	2.27	16.54	10.76	1.02	85310.63
5	1.32	3.50	54.77	1.64	17.75	10.12	1.02	86625.68
6	0.29	5.97	53.42	1.03	18.50	9.87	1.02	89015.60
7	0.34	4.60	56.98	1.66	17.92	10.35	1.02	84742.07
8	0.98	8.01	47.32	1.95	17.21	10.41	1.03	84636.57
9	2.47	3.40	53.68	2.54	16.39	10.42	1.05	84837.68
10	11.86	3.82	55.19	3.07	15.90	10.53	1.05	85022.39
11	8.24	3.22	54.67	1.73	18.46	9.95	1.05	88120.62
12	8.07	3.81	50.04	1.90	18.21	9.99	1.05	87095.79
13	4.53	2.29	51.06	1.44	18.73	9.74	1.05	88294.10
14	1.94	6.65	49.43	1.94	17.42	10.09	1.05	86324.71
15	1.83	2.23	56.43	1.90	17.23	10.23	1.05	86359.52
16	2.68	2.02	56.48	1.95	17.17	9.98	1.05	87879.09
17	5.11	4.78	53.74	2.61	16.37	10.00	1.03	88280.09
18	9.98	4.42	52.49	3.91	14.39	10.66	1.04	84969.91
19	6.67	3.31	61.91	1.46	18.07	9.88	1.02	87541.39
20	2.89	4.58	48.45	1.79	17.97	9.67	1.02	89131.91
21	1.34	3.80	61.61	1.79	17.86	10.28	1.01	84814.82
22	0.75	6.14	53.14	1.36	18.08	10.25	1.00	84833.41
23	0.28	7.21	51.62	1.86	17.23	10.34	1.00	84957.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.29	4.98	53.88	2.00	17.33	10.22	1.03	86087.43
最大值	11.86	10.68	64.80	3.91	18.73	10.84	1.05	89131.91
發生時間	10	1	0	18	13	0		20
最小值	0.28	2.02	47.32	1.03	14.39	9.67	0.99	81590.38
發生時間	23	16	8	6	18	20		0
零點偏移(率)	-0.05 %	-0.01 %	-0.18 %	-0.03 %		0.04		-0.10 %
全幅偏移(率)	-0.02 %	0.74 %	0.31 %	0.12 %		-0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.63	6.95	53.29	2.07	15.63	10.86	0.97	76098.08
1	10.53	15.49	51.97	3.80	12.80	11.40	0.97	73079.79
2	5.03	4.40	55.20	2.89	13.90	11.51	0.98	72546.87
3	3.99	7.76	57.80	2.53	14.36	11.50	0.99	74666.54
4	5.57	5.48	53.45	2.41	14.58	11.20	0.99	77823.83
5	4.87	5.09	58.51	2.39	14.96	11.14	0.99	77006.79
6	4.98	10.84	53.00	2.31	15.30	11.00	0.99	77435.44
7	1.71	3.57	49.20	0.78	18.10	10.61	0.99	81254.36
8	3.42	3.68	51.76	1.23	16.32	10.91	0.98	78683.66
9	7.75	10.77	44.51	2.00	14.99	10.94	0.98	76876.22
10	9.79	11.67	56.66	2.81	14.02	11.17	0.98	76003.57
11	7.95	5.73	50.25	1.67	15.70	10.78	0.96	78335.56
12	7.28	6.32	48.76	1.87	14.74	10.93	0.95	73640.22
13	6.02	5.29	50.18	1.20	16.11	10.74	0.97	77325.81
14	7.41	5.17	52.82	1.50	15.16	11.07	0.96	77711.85
15	6.30	4.77	57.47	1.49	15.42	11.01	0.97	78377.50
16	8.21	5.22	49.57	1.26	16.54	10.55	0.98	82814.96
17	9.36	6.27	47.65	1.64	16.12	10.32	0.97	81338.22
18	8.39	4.04	45.85	1.27	16.56	10.12	0.95	76143.84
19	6.92	5.01	51.19	1.53	15.54	10.33	0.96	76243.95
20	6.61	7.39	47.05	1.20	16.96	10.12	0.97	77658.48
21	4.57	9.84	42.49	1.19	17.67	9.24	0.96	80380.18
22	3.76	8.57	40.21	1.38	15.08	10.47	0.96	74342.41
23	1.89	9.84	40.79	0.98	15.83	10.58	0.97	74732.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.21	7.05	50.40	1.81	15.52	10.77	0.97	77105.05
最大值	10.53	15.49	58.51	3.80	18.10	11.51	1.01	82814.96
發生時間	1	1	5	1	7	2		16
最小值	1.71	3.57	40.21	0.78	12.80	9.24	0.94	72546.87
發生時間	7	7	22	7	1	21		2
零點偏移(率)	-0.06 %	-0.01 %	-0.54 %	-0.05 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-1.09 %	-0.02 %	-0.02 %		0.16		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								