

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月09日

報表日期: 113年07月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.14	4.53	57.27	2.21	16.41	11.84	1.02	80239.33
1	6.29	4.66	52.50	1.77	18.34	11.53	1.02	80989.89
2	7.87	4.72	44.44	3.25	15.79	11.87	1.02	80368.03
3	6.99	4.98	42.63	3.60	15.25	11.99	1.02	79676.42
4	7.40	5.30	49.40	2.87	16.18	11.96	1.02	79219.62
5	7.57	4.85	61.09	2.75	16.66	11.79	1.00	82407.12
6	5.32	4.73	58.67	2.34	16.76	11.85	1.02	79449.23
7	4.53	4.97	59.00	2.85	16.22	12.11	1.02	77754.71
8	5.02	4.97	55.01	3.91	15.36	12.04	1.02	79867.32
9	7.58	4.36	51.70	1.60	16.29	11.98	1.00	80208.21
10	8.72	4.81	44.49	1.53	16.43	11.81	1.02	80811.24
11	8.02	4.42	46.42	1.19	16.94	11.70	1.02	80871.89
12	10.15	4.48	44.87	1.47	15.95	11.88	1.02	79387.85
13	13.39	7.91	37.34	1.81	15.22	12.19	1.02	77764.14
14	10.64	2.28	42.20	1.24	16.70	12.06	1.01	77901.66
15	10.07	3.53	46.78	2.35	16.32	11.93	1.01	79573.96
16	7.75	4.86	57.46	2.78	15.85	12.12	1.01	78836.16
17	8.31	6.59	58.43	2.70	15.92	12.27	1.00	76535.73
18	7.46	3.41	36.09	2.78	16.26	11.64	1.01	78712.26
19	10.58	2.97	42.66	2.24	17.55	11.49	1.02	81674.67
20	12.07	5.36	42.27	4.23	15.01	12.05	1.02	80156.82
21	9.21	2.46	48.91	2.31	14.89	12.48	1.01	77851.98
22	10.87	1.52	49.13	2.43	17.09	12.01	0.99	79109.96
23	7.25	3.14	54.74	1.48	17.91	11.59	1.02	81843.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.38	4.41	49.31	2.40	16.30	11.92	1.01	79633.83
最 大 值	13.39	7.91	61.09	4.23	18.34	12.48	1.03	82407.12
發生時間	13	13	5	20	1	21		5
最 小 值	4.53	1.52	36.09	1.19	14.89	11.49	0.97	76535.73
發生時間	7	22	18	11	21	19		17
零點偏移(率)	-0.07 %	-0.00 %	-0.04 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	-0.31 %	0.04 %	-0.01 %		-0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月09日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.24	4.68	59.88	1.37	17.39	11.17	0.93	79618.20
1	1.02	2.04	59.31	2.38	16.10	11.62	0.93	77482.95
2	4.07	2.41	70.54	1.85	15.67	11.90	0.93	75582.26
3	3.85	2.04	61.63	2.21	16.03	11.43	0.92	79040.43
4	4.51	2.27	45.81	2.43	15.79	11.56	0.92	77774.11
5	2.96	8.81	55.63	3.37	13.83	11.96	0.91	76748.35
6	2.43	13.79	59.31	2.47	15.57	11.77	0.90	73740.33
7	3.88	0.92	43.07	3.05	15.21	11.51	0.92	78788.11
8	4.08	2.02	45.00	2.03	16.46	11.39	0.94	77982.59
9	1.53	7.39	52.78	3.11	15.39	11.42	0.93	79469.45
10	1.35	1.59	48.12	1.81	17.18	10.95	0.94	81569.15
11	1.48	4.15	49.82	2.97	14.55	11.50	0.94	79199.28
12	6.49	3.22	58.25	2.61	14.76	11.74	0.94	76622.67
13	11.23	4.20	48.35	3.11	16.00	11.26	0.94	79841.53
14	8.75	2.23	51.09	2.18	17.30	11.22	0.93	78712.69
15	3.62	2.71	53.99	1.99	15.08	11.87	0.94	75616.45
16	1.35	3.41	61.48	2.21	15.06	11.96	0.93	75509.57
17	2.67	3.98	59.79	3.09	14.08	11.79	0.91	76756.31
18	2.00	2.25	59.14	2.32	15.40	11.52	0.91	78509.70
19	3.46	2.04	60.81	1.96	16.89	10.96	0.92	81745.58
20	8.22	2.51	60.83	2.03	17.25	10.89	0.94	81318.77
21	7.55	2.40	58.30	1.47	16.91	11.09	0.94	79914.04
22	4.08	2.08	66.68	1.21	16.93	11.53	0.94	77073.44
23	0.86	2.43	63.34	0.61	18.17	11.29	0.94	77933.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.86	3.57	56.37	2.24	15.96	11.47	0.93	78189.55
最 大 值	11.23	13.79	70.54	3.37	18.17	11.96	0.96	81745.58
發生時間	13	6	2	5	23	5		19
最 小 值	0.86	0.92	43.07	0.61	13.83	10.89	0.90	73740.33
發生時間	23	7	7	23	5	20		6
零點偏移(率)	0.00 %	-0.04 %	-0.31 %	-0.04 %		-0.10		-0.10 %
全幅偏移(率)	0.13 %	0.79 %	0.21 %	0.41 %		-0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月09日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.15	4.84	56.78	1.24	19.01	10.36	0.96	81184.17
1	2.45	5.61	48.60	1.35	17.88	10.85	0.94	78322.27
2	3.92	8.70	54.34	1.95	15.88	11.14	0.92	77608.54
3	2.68	4.53	58.61	1.49	16.73	11.13	0.92	76625.69
4	2.45	4.64	58.88	1.25	18.12	10.54	0.92	80282.07
5	4.31	5.36	55.25	2.08	15.85	10.99	0.93	79602.87
6	2.03	13.43	52.15	1.77	16.09	10.90	0.93	77628.72
7	3.05	11.62	57.78	1.81	16.36	10.94	0.98	79268.29
8	0.10	5.98	63.99	1.36	16.79	11.50	0.98	77185.78
9	3.64	7.10	61.55	1.49	17.18	11.29	0.96	80873.70
10	1.55	7.69	61.59	1.54	15.59	11.76	0.97	77524.24
11	1.91	9.58	56.48	1.56	15.92	11.50	0.95	77832.21
12	2.19	7.92	56.94	1.44	15.69	11.70	0.98	76396.53
13	2.46	18.17	52.79	1.76	15.26	11.54	0.98	76022.31
14	6.19	6.85	51.81	2.09	15.86	11.22	0.95	76711.39
15	1.77	7.69	59.27	1.19	16.36	11.58	0.99	77150.70
16	5.78	7.63	62.02	1.37	16.58	11.68	0.93	76702.34
17	1.72	6.27	62.26	1.38	15.92	11.88	0.93	73319.34
18	1.95	4.06	60.62	1.09	17.26	11.24	0.93	77520.94
19	2.56	5.88	52.41	1.14	16.85	10.52	0.94	78930.09
20	1.44	5.65	49.58	1.42	15.43	10.52	0.93	77246.00
21	4.53	5.81	52.38	1.43	16.47	10.26	0.96	78304.25
22	0.53	4.60	59.38	1.13	17.41	10.64	0.96	74990.42
23	2.39	3.10	47.18	1.05	19.81	10.01	0.95	79123.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.70	7.20	56.36	1.47	16.68	11.07	0.95	77764.84
最 大 值	6.19	18.17	63.99	2.09	19.81	11.88	1.00	81184.17
發生時間	14	13	8	14	23	17		0
最 小 值	0.10	3.10	47.18	1.05	15.26	10.01	0.91	73319.34
發生時間	8	23	23	23	13	23		17
零點偏移(率)	-0.01 %	0.00 %	-0.14 %	-0.05 %		-0.03		0.00 %
全幅偏移(率)	-0.25 %	-0.12 %	-0.22 %	0.00 %		0.45		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								