

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月08日

報表日期: 114年09月08日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.50	13.42	51.67	3.26	15.51	11.74	1.20	70305.21
1	10.17	13.07	50.30	3.24	16.88	11.42	1.20	71741.86
2	9.25	12.21	44.77	3.60	14.69	11.73	1.21	70616.45
3	6.48	12.66	55.99	2.37	17.36	11.47	1.22	71244.80
4	11.32	11.84	50.72	3.48	16.45	11.46	1.21	71900.72
5	2.72	13.15	56.38	1.98	16.52	11.54	1.23	72285.28
6	9.57	12.09	49.42	2.47	16.26	11.02	1.24	73242.19
7	11.09	12.80	47.87	2.83	15.67	11.04	1.24	72173.01
8	8.48	12.02	52.84	2.48	15.30	11.72	1.24	69498.81
9	10.54	12.23	36.00	2.51	16.91	11.29	1.24	71616.35
10	6.57	12.18	33.46	3.19	14.43	11.52	1.22	68294.86
11	9.53	12.53	58.26	2.72	15.21	11.86	1.20	68298.59
12	6.40	12.00	51.47	2.71	14.33	11.85	1.22	68207.92
13	7.58	12.51	54.12	2.09	15.37	11.85	1.20	68157.77
14	10.90	12.08	53.89	2.68	14.39	11.93	1.23	68400.54
15	8.71	12.30	52.60	2.39	14.78	12.06	1.23	67426.59
16	10.70	12.04	59.33	2.35	15.03	11.82	1.21	70246.22
17	7.79	12.09	56.82	2.06	15.25	11.85	1.22	70370.37
18	9.27	11.89	57.35	2.23	14.81	11.75	1.20	70985.32
19	9.96	11.90	58.74	2.31	14.81	11.83	1.21	70082.71
20	8.23	11.96	58.44	2.18	15.09	11.81	1.21	70468.42
21	9.35	11.52	60.75	2.40	14.64	11.47	1.20	73170.60
22	9.46	13.16	63.50	2.50	14.54	12.08	1.21	68429.24
23	6.00	12.61	64.83	1.87	15.63	12.20	1.22	66304.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.73	12.34	53.31	2.58	15.41	11.68	1.22	70144.53
最 大 值	11.32	13.42	64.83	3.60	17.36	12.20	1.25	73242.19
發生時間	4	0	23	2	3	23		6
最 小 值	2.72	11.52	33.46	1.87	14.33	11.02	1.20	66304.99
發生時間	5	21	10	23	12	6		23
零點偏移(率)	-0.07 %	0.01 %	-0.34 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.00 %	-0.20 %	0.07 %	-0.06 %		0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月08日

報表日期: 114年09月08日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.17	12.11	65.20	2.18	15.93	10.95	0.97	79123.78
1	2.25	11.81	55.31	2.15	16.56	10.61	0.97	79281.15
2	2.27	12.25	58.56	2.31	15.91	10.82	0.97	80264.43
3	2.41	11.96	55.42	1.15	17.19	10.66	0.97	81286.91
4	2.61	11.77	65.43	0.97	17.79	10.43	0.97	84292.45
5	2.59	11.92	51.67	1.41	17.08	10.75	0.98	84162.26
6	3.15	12.75	55.45	1.32	17.15	10.97	0.99	79599.93
7	2.61	12.24	60.11	1.02	17.38	10.85	0.99	79694.57
8	2.32	12.56	61.46	1.80	16.10	11.27	1.00	79640.71
9	2.43	12.54	58.19	1.53	16.26	10.87	0.99	82922.47
10	2.28	12.31	61.74	2.13	15.39	11.18	0.99	77844.09
11	2.04	13.81	60.59	2.02	16.11	11.32	0.99	78335.98
12	1.81	13.72	56.44	1.80	15.80	11.25	0.98	76947.60
13	1.54	13.44	55.44	2.02	15.93	11.09	0.97	77886.79
14	1.42	13.68	60.08	2.13	15.83	11.28	0.97	78280.53
15	1.23	13.86	57.23	2.74	14.80	11.47	0.97	76299.30
16	1.51	14.05	57.13	2.49	15.88	11.02	0.98	81468.09
17	1.49	5.96	55.05	3.16	15.42	11.23	0.97	78192.91
18	1.97	11.26	62.43	2.06	16.04	11.07	0.98	81208.40
19	1.69	13.65	57.90	3.22	15.16	11.17	0.99	81596.35
20	1.74	13.64	59.96	2.81	15.76	11.15	0.97	80814.06
21	1.81	13.39	60.92	1.96	16.85	10.90	0.99	81275.81
22	2.14	13.80	62.91	1.70	16.95	11.21	1.00	79650.38
23	1.92	14.61	53.89	2.08	16.44	11.74	1.02	75391.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.06	12.63	58.69	2.01	16.24	11.05	0.98	79810.85
最 大 值	3.15	14.61	65.43	3.22	17.79	11.74	1.04	84292.45
發生時間	6	23	4	19	4	23		4
最 小 值	1.23	5.96	51.67	0.97	14.80	10.43	0.96	75391.56
發生時間	15	17	5	4	15	4		23
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	-0.01 %		-0.06		-0.20 %
全幅偏移(率)	0.14 %	0.05 %	-0.02 %	-0.16 %		0.08		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月08日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.33	12.12	56.71	3.67	16.76	9.61	1.37	78067.80
1	4.52	12.14	55.90	3.66	19.68	9.01	1.37	81346.24
2	8.67	10.84	60.98	1.46	16.43	9.82	1.36	81050.36
3	10.66	12.04	56.93	3.13	18.40	8.89	1.36	83280.15
4	10.64	11.11	52.86	3.18	18.27	8.74	1.36	82083.96
5	7.73	11.15	46.89	1.51	18.79	8.67	1.36	82178.53
6	9.29	11.61	50.28	1.62	17.80	8.83	1.37	80532.29
7	9.09	10.89	47.59	2.47	18.15	8.90	1.40	77075.81
8	9.07	10.89	46.40	2.34	18.06	8.92	1.36	79820.38
9	10.03	11.20	57.87	2.44	17.84	9.00	1.38	81368.69
10	10.30	11.41	58.45	2.45	17.53	9.29	1.42	78622.14
11	7.49	11.43	53.68	2.26	17.56	8.94	1.37	81644.51
12	7.67	12.77	54.99	2.29	15.14	9.74	1.40	75612.26
13	7.10	13.04	61.06	2.28	15.89	9.93	1.38	76842.92
14	7.41	12.98	57.11	2.09	16.96	9.77	1.35	76424.85
15	10.90	12.82	60.93	2.47	16.74	9.48	1.36	79137.85
16	10.24	12.86	59.56	2.34	16.24	9.71	1.40	77923.93
17	6.51	12.41	55.41	2.00	16.33	9.37	1.38	80071.61
18	9.09	12.54	63.35	2.17	17.89	9.22	1.36	80776.14
19	10.17	12.72	56.69	2.21	16.59	9.60	1.35	79738.95
20	7.98	12.73	55.94	2.06	16.25	9.60	1.37	79603.61
21	9.66	13.20	62.96	2.09	16.74	9.99	1.41	81914.29
22	7.87	13.12	61.82	2.04	16.68	9.95	1.40	79057.10
23	8.99	13.13	56.13	2.04	17.02	9.45	1.39	81500.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.60	12.13	56.27	2.34	17.24	9.35	1.38	79819.78
最 大 值	10.90	13.20	63.35	3.67	19.68	9.99	1.43	83280.15
發生時間	15	21	18	0	1	21		3
最 小 值	4.52	10.84	46.40	1.46	15.14	8.67	1.34	75612.26
發生時間	1	2	8	2	12	5		12
零點偏移(率)	-0.01 %	0.00 %	-0.13 %	-0.02 %		-0.02		0.20 %
全幅偏移(率)	0.02 %	0.16 %	0.18 %	0.08 %		0.34		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								