

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.79	13.88	59.67	1.06	20.62	11.26	1.25	70403.64
1	8.98	11.58	53.31	0.91	21.60	10.44	1.25	75992.87
2	11.26	12.45	53.96	2.02	17.84	11.70	1.25	70031.40
3	10.24	11.92	55.30	1.89	17.96	11.33	1.25	72716.86
4	10.33	11.98	56.77	2.56	16.95	11.53	1.25	72288.84
5	9.09	12.94	54.05	1.72	17.77	11.23	1.25	78153.22
6	9.57	13.03	56.67	2.68	16.95	11.41	1.25	73064.91
7	9.59	13.31	58.59	2.49	17.18	11.58	1.25	71534.65
8	8.38	13.91	60.56	1.32	20.08	11.13	1.25	72241.39
9	8.92	12.58	55.70	2.16	19.14	10.77	1.23	75588.61
10	8.05	13.05	56.34	2.59	17.36	11.37	1.23	72983.38
11	12.90	12.85	64.94	2.19	19.38	10.70	1.25	76124.61
12	15.08	12.97	62.86	3.59	17.07	11.23	1.24	73567.67
13	16.39	14.46	61.01	3.82	15.01	11.81	1.21	68825.10
14	13.96	13.00	64.24	2.90	16.81	11.45	1.22	71050.31
15	4.76	13.78	48.49	2.56	17.34	11.33	1.23	71921.65
16	7.64	13.76	38.90	1.95	18.48	10.71	1.23	75817.47
17	8.12	12.32	42.35	1.77	19.35	10.76	1.24	74438.83
18	3.72	11.67	42.20	1.09	20.76	10.32	1.25	76631.99
19	3.70	12.27	47.08	1.67	19.41	10.55	1.23	76624.87
20	5.55	12.57	48.91	2.54	16.58	11.12	1.22	74507.44
21	7.23	11.77	61.47	2.07	18.36	10.91	1.23	74637.69
22	7.52	11.23	57.11	2.00	19.10	10.76	1.24	74876.70
23	7.34	11.62	58.76	1.59	19.36	10.81	1.25	74489.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.05	12.70	54.97	2.13	18.35	11.09	1.24	73688.06
最大值	16.39	14.46	64.94	3.82	21.60	11.81	1.26	78153.22
發生時間	13	13	11	13	1	13		5
最小值	3.70	11.23	38.90	0.91	15.01	10.32	1.20	68825.10
發生時間	19	22	16	1	13	18		13
零點偏移(率)	-0.06 %	-0.01 %	-0.02 %	0.00 %		-0.09	-0.01	0.20 %
全幅偏移(率)	0.10 %	0.30 %	-0.00 %	0.50 %		-0.05	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.16	14.35	58.93	1.42	16.10	12.30	0.97	59879.12
1	7.31	13.21	48.64	1.13	18.82	11.20	0.97	67772.77
2	9.76	11.92	45.76	1.06	17.94	10.28	0.97	75463.75
3	10.29	13.46	55.49	1.46	15.57	11.58	0.94	68517.16
4	9.37	12.41	57.95	1.24	17.36	10.53	0.94	79164.03
5	9.65	13.05	59.18	1.36	16.69	10.91	0.96	79543.98
6	7.42	13.56	52.81	2.03	16.33	11.16	0.94	79770.46
7	7.71	13.34	56.17	1.26	17.30	11.00	0.94	79727.18
8	7.35	10.93	65.76	0.78	17.95	10.65	0.96	79586.10
9	7.49	11.17	59.03	0.61	17.35	10.93	0.98	78611.19
10	7.54	11.43	55.52	0.93	16.94	11.23	0.98	73780.82
11	2.50	11.43	57.06	1.33	17.41	10.88	0.98	79313.41
12	1.86	12.24	49.11	1.41	17.30	10.57	0.97	77225.80
13	1.69	11.64	50.42	0.86	18.14	10.56	0.97	74974.56
14	4.26	11.78	53.61	1.15	16.07	11.24	0.95	72729.77
15	6.16	11.99	62.16	2.09	14.86	11.11	0.96	76307.45
16	6.04	10.89	45.13	1.08	16.76	10.09	0.94	74523.97
17	6.43	11.57	33.78	0.91	18.63	9.46	0.94	74598.26
18	6.19	14.47	47.96	2.34	16.64	10.10	0.94	73973.66
19	5.89	11.14	52.15	1.19	17.26	9.91	0.94	73074.56
20	8.59	11.48	51.07	1.82	15.73	10.08	0.94	72397.96
21	5.41	10.87	53.60	1.14	18.09	9.53	0.94	73540.05
22	5.30	10.52	50.40	0.82	19.73	8.88	0.94	77763.78
23	6.34	11.80	47.41	0.78	18.16	9.98	0.94	74826.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.57	12.11	52.88	1.26	17.21	10.59	0.95	74877.76
最大值	10.29	14.47	65.76	2.34	19.73	12.30	0.99	79770.46
發生時間	3	18	8	18	22	0		6
最小值	1.69	10.52	33.78	0.61	14.86	8.88	0.93	59879.12
發生時間	13	22	17	9	15	22		0
零點偏移(率)	-0.12 %	-0.00 %	-0.09 %	-0.01 %		-0.08	-0.01	-0.10 %
全幅偏移(率)	0.13 %	0.14 %	0.14 %	0.13 %		0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.86	11.73	59.00	3.10	20.73	8.78	1.36	77342.88
1	4.54	12.41	52.14	3.36	20.08	9.57	1.36	74548.52
2	7.03	12.65	50.95	3.14	18.87	9.56	1.33	73503.22
3	9.88	12.42	53.23	3.30	19.10	9.63	1.35	75241.22
4	9.39	12.66	55.06	3.05	17.25	10.21	1.39	73903.57
5	9.01	12.61	53.86	3.00	17.25	10.01	1.39	74439.97
6	8.87	13.28	53.84	3.04	16.92	10.04	1.39	73689.40
7	3.41	11.13	50.88	3.11	18.22	9.74	1.39	77757.06
8	3.47	11.92	53.75	4.18	20.31	9.70	1.39	77294.61
9	4.41	11.77	51.92	0.32	18.74	10.44	1.35	76177.47
10	4.87	11.84	54.80	3.25	18.43	10.60	1.36	75925.13
11	6.73	11.89	54.40	3.76	19.04	10.58	1.38	76637.01
12	5.42	11.79	50.60	3.40	18.92	10.49	1.36	75058.43
13	3.26	11.79	54.44	3.18	19.95	10.35	1.32	73448.67
14	3.11	11.24	49.89	3.09	20.11	9.79	1.33	75851.59
15	3.23	11.26	43.33	3.06	19.49	9.86	1.31	74708.12
16	3.48	11.69	38.43	3.25	19.28	9.65	1.36	76932.99
17	3.79	11.49	46.48	2.50	19.30	8.98	1.37	76157.80
18	6.07	10.95	50.94	1.65	19.97	8.63	1.34	76754.32
19	6.87	11.04	48.62	1.71	20.36	8.44	1.33	76884.90
20	6.54	10.53	49.87	1.55	20.41	8.53	1.37	76028.65
21	7.67	10.65	49.31	1.69	20.54	8.33	1.39	76812.85
22	9.58	10.64	54.56	1.90	19.78	8.78	1.38	73447.22
23	6.08	10.95	52.26	2.68	19.54	8.85	1.36	73689.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.98	11.68	51.36	2.76	19.27	9.56	1.36	75509.79
最大值	9.88	13.28	59.00	4.18	20.73	10.60	1.42	77757.06
發生時間	3	6	0	8	0	10		7
最小值	3.11	10.53	38.43	0.32	16.92	8.33	1.31	73447.22
發生時間	14	20	16	9	6	21		22
零點偏移(率)	-0.02 %	-0.02 %	-0.07 %	0.00 %		-0.11	-0.01	-0.20 %
全幅偏移(率)	-1.49 %	0.01 %	-0.37 %	0.37 %		0.34	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								