

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月02日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.31	4.82	44.19	2.57	15.11	11.96	1.31	79936.84
1	7.49	3.85	45.93	2.65	15.50	12.04	1.31	78846.74
2	6.84	3.07	38.20	2.82	14.56	12.18	1.31	78856.26
3	8.00	2.64	37.48	2.81	15.01	12.01	1.30	79790.68
4	7.65	6.47	39.59	2.77	15.08	11.75	1.29	82438.45
5	9.59	4.19	46.12	0.71	15.51	12.19	1.29	76734.63
6	7.97	4.60	46.70	1.39	15.01	12.42	1.29	75757.44
7	12.78	5.85	33.72	1.54	15.60	11.69	1.29	81770.72
8	9.09	10.86	39.17	1.03	16.08	12.09	1.29	80571.86
9	8.71	4.04	39.97	1.02	15.50	12.11	1.28	82611.22
10	9.24	4.56	37.47	1.61	14.83	12.45	1.27	80199.72
11	7.52	5.90	39.55	1.27	15.24	12.39	1.28	80537.89
12	7.32	2.86	41.06	0.90	15.89	12.22	1.29	81330.25
13	7.45	3.33	45.63	0.70	16.29	11.93	1.29	83418.99
14	7.28	9.27	41.12	0.66	16.78	11.98	1.29	82872.94
15	12.15	2.98	46.55	1.04	15.73	12.17	1.27	81789.41
16	9.62	2.79	36.24	1.54	15.08	12.19	1.29	82055.06
17	6.26	3.09	41.29	1.12	16.17	11.88	1.29	84096.95
18	7.81	2.73	53.42	0.73	16.59	11.99	1.29	82575.09
19	4.93	3.24	50.91	0.37	17.84	11.29	1.29	85247.21
20	3.78	3.16	61.44	0.53	18.30	11.20	1.31	84202.22
21	7.28	3.14	56.90	0.55	17.90	11.09	1.31	85342.54
22	11.71	3.25	52.99	0.75	17.22	11.28	1.31	83897.54
23	8.35	4.97	59.26	0.31	18.66	10.88	1.31	86444.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.13	4.40	44.79	1.31	16.06	11.89	1.29	81721.89
最 大 值	12.78	10.86	61.44	2.82	18.66	12.45	1.32	86444.60
發生時間	7	8	20	2	23	10		23
最 小 值	3.78	2.64	33.72	0.31	14.56	10.88	1.26	75757.44
發生時間	20	3	7	23	2	23		6
零點偏移(率)	-0.01 %	-0.01 %	-0.03 %	-0.01 %		-0.39		0.20 %
全幅偏移(率)	0.00 %	0.50 %	-0.14 %	0.68 %		-0.15		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月02日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.82	1.56	60.07	2.78	14.59	11.34	1.10	77480.29
1	2.95	1.76	54.90	2.24	14.55	11.44	1.10	75603.83
2	4.84	1.70	58.34	2.75	13.86	11.53	1.10	76248.78
3	3.15	1.61	56.06	1.97	13.43	11.67	1.10	75519.82
4	1.92	1.76	59.24	1.78	13.52	11.55	1.10	76886.20
5	4.77	2.17	55.62	2.50	13.99	11.40	1.09	76861.86
6	8.59	1.98	37.98	2.10	15.78	10.94	1.06	73786.65
7	7.14	3.69	40.47	1.88	15.84	10.80	1.06	76816.68
8	9.07	1.21	58.15	1.82	15.10	11.17	1.07	81653.00
9	9.07	1.09	57.71	2.16	14.15	11.46	1.09	81013.51
10	7.97	1.13	55.93	2.07	13.52	11.81	1.09	78724.77
11	5.56	1.29	56.92	2.18	13.01	11.83	1.10	79436.10
12	7.26	1.13	56.92	2.34	13.28	11.85	1.09	79083.62
13	8.11	1.40	60.24	1.77	14.41	11.60	1.06	80040.64
14	8.64	1.39	59.78	2.31	13.22	11.81	1.04	78944.15
15	8.26	1.26	58.51	2.01	13.08	11.79	1.04	78804.78
16	4.93	3.01	58.22	2.21	13.29	11.67	1.04	79166.01
17	5.28	1.33	60.09	1.47	14.64	11.52	1.05	80587.71
18	6.10	1.46	60.79	2.11	13.73	11.43	1.06	81476.32
19	4.69	1.42	58.85	1.93	14.88	11.29	1.06	81925.51
20	4.04	1.41	57.81	2.10	14.06	11.41	1.06	81261.54
21	6.74	1.32	57.72	1.93	14.11	11.51	1.07	80782.63
22	7.73	2.56	59.49	1.64	14.95	11.29	1.09	80130.14
23	1.92	6.81	58.82	0.58	16.81	10.95	1.10	81152.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.02	1.89	56.61	2.03	14.24	11.46	1.08	78891.11
最 大 值	9.07	6.81	60.79	2.78	16.81	11.85	1.13	81925.51
發生時間	8	23	18	0	23	12		19
最 小 值	1.92	1.09	37.98	0.58	13.01	10.80	1.04	73786.65
發生時間	4	9	6	23	11	7		6
零點偏移(率)	-0.03 %	0.00 %	-0.01 %	0.01 %		-0.05		0.10 %
全幅偏移(率)	-0.01 %	-0.41 %	0.25 %	0.28 %		-0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年01月02日

[illegible]