

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	6.09	50.01	3.31	17.20	11.35	1.02	79978.61
1	2.74	8.27	61.15	3.43	17.23	12.45	1.05	71954.59
2	8.61	8.75	50.61	4.26	15.43	11.87	1.05	78185.57
3	4.15	13.10	68.80	3.11	17.60	11.91	1.06	76180.18
4	9.00	9.08	58.49	3.53	17.88	11.11	1.05	82429.73
5	11.76	13.10	58.25	2.08	17.60	11.77	1.05	77258.53
6	9.27	12.13	60.40	1.94	18.27	11.47	1.05	79153.48
7	8.84	7.46	54.36	2.00	18.20	11.44	1.05	79292.73
8	9.62	7.42	52.38	2.07	18.69	11.24	1.03	79599.49
9	7.37	7.34	51.73	1.88	18.69	11.30	1.05	79549.43
10	9.03	7.38	66.37	1.77	18.50	11.22	1.07	80378.37
11	8.03	8.04	59.35	2.19	16.57	11.63	1.06	78936.17
12	9.33	7.15	54.32	2.18	17.35	11.36	1.04	80044.12
13	8.68	7.42	67.47	1.73	17.13	11.84	1.05	75979.47
14	10.00	8.07	50.58	2.74	16.35	11.41	1.04	76655.71
15	8.65	6.36	61.16	1.99	17.66	11.44	1.05	77133.25
16	9.80	7.24	58.59	2.60	16.59	11.52	1.04	78833.39
17	8.47	9.67	57.30	2.76	16.39	11.91	1.04	74800.12
18	8.49	3.09	61.40	3.53	14.90	12.46	1.02	70332.41
19	7.02	5.76	59.57	2.33	16.11	12.01	1.03	73935.42
20	7.83	6.14	61.69	2.08	17.25	11.52	1.05	78933.57
21	9.50	5.95	61.37	2.17	17.25	11.54	1.03	78617.84
22	8.24	5.53	55.96	1.74	17.78	11.56	1.05	78502.23
23	7.74	5.85	55.95	1.93	17.30	11.78	1.04	76439.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.32	7.77	58.22	2.47	17.25	11.63	1.04	77629.32
最大值	11.76	13.10	68.80	4.26	18.69	12.46	1.08	82429.73
發生時間	5	3	3	2	8	18		4
最小值	2.74	3.09	50.01	1.73	14.90	11.11	1.01	70332.41
發生時間	1	18	0	13	18	4		18
零點偏移(率)	-0.69 %	-0.01 %	-0.26 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	-1.30 %	0.07 %	0.32 %	-0.30 %		-0.06		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.14	2.04	47.95	1.89	18.38	9.63	0.99	91342.60
1	5.47	4.30	55.36	2.18	17.68	10.31	0.99	86654.86
2	5.41	3.92	57.49	1.76	17.52	10.15	1.02	87923.23
3	9.12	3.83	56.26	2.56	16.35	10.27	1.00	87864.30
4	9.40	4.10	57.15	2.50	16.54	10.36	0.99	87364.08
5	9.42	7.48	57.75	2.22	17.65	9.91	1.00	89952.28
6	9.43	7.30	56.06	2.73	17.12	10.34	0.99	94344.52
7	9.11	5.76	52.17	3.03	15.75	10.52	0.99	85058.01
8	6.44	3.65	57.61	1.95	17.59	10.61	0.99	83335.40
9	10.66	6.90	55.57	2.29	17.82	10.18	0.99	86456.11
10	11.20	2.51	43.39	3.46	15.11	10.39	0.99	79650.76
11	7.61	5.01	59.59	1.79	16.79	10.27	0.99	84287.27
12	9.28	8.89	59.09	1.92	16.51	10.48	0.99	82814.04
13	8.29	4.71	49.26	2.20	16.03	10.66	0.99	80884.67
14	9.45	2.44	54.58	1.96	17.08	10.23	1.02	85473.80
15	6.82	7.44	52.33	1.59	17.55	10.34	1.01	84200.72
16	8.78	7.34	52.18	1.85	18.33	10.11	0.99	86020.28
17	7.84	7.17	61.77	1.93	17.11	10.81	0.99	80093.42
18	2.58	9.56	52.81	2.41	15.33	11.10	0.99	77442.75
19	2.94	3.86	61.39	1.92	15.82	11.03	0.98	74612.81
20	8.25	3.61	65.01	1.89	17.19	10.55	0.99	83758.20
21	7.93	4.02	53.57	2.12	17.45	10.07	0.97	84409.67
22	7.33	3.43	66.66	1.41	17.51	10.42	0.99	81829.72
23	5.84	4.76	49.71	1.56	16.64	11.01	0.99	79110.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.78	5.17	55.61	2.13	16.95	10.41	0.99	84370.16
最大值	11.20	9.56	66.66	3.46	18.38	11.10	1.03	94344.52
發生時間	10	18	22	10	0	18		6
最小值	2.58	2.04	43.39	1.41	15.11	9.63	0.97	74612.81
發生時間	18	0	10	22	10	0		19
零點偏移(率)	-0.20 %	0.00 %	-0.17 %	-0.01 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	-0.04 %	0.40 %	-0.23 %		-0.34		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.68	5.99	45.36	4.12	14.89	10.53	0.97	79143.79
1	8.24	7.78	56.45	3.88	15.03	11.11	0.98	76076.65
2	8.73	6.06	60.05	3.77	16.58	10.50	0.99	81492.51
3	8.71	6.89	56.52	3.84	15.64	10.50	0.98	81255.49
4	8.81	7.93	59.67	3.76	16.89	10.30	0.98	79952.21
5	9.19	4.25	61.82	4.16	15.70	10.42	0.98	82203.65
6	10.56	7.10	55.16	4.06	15.38	10.63	0.98	80777.27
7	6.27	5.05	49.31	2.45	15.32	10.60	0.96	77008.53
8	9.70	4.42	49.77	2.63	17.40	10.16	0.99	76918.05
9	9.25	5.22	51.01	3.01	16.04	10.42	0.98	76296.19
10	8.71	3.32	51.21	2.73	16.09	10.36	0.95	76153.80
11	4.64	3.62	53.40	2.82	14.85	10.65	0.96	73242.80
12	4.51	10.54	50.73	2.00	16.17	10.19	0.98	73835.32
13	6.73	3.39	47.91	2.48	15.41	10.31	0.99	73469.61
14	8.12	4.92	43.82	2.86	15.63	10.24	0.99	74325.10
15	5.46	12.36	58.39	2.34	15.88	10.68	0.99	74319.07
16	6.89	2.90	57.81	2.10	16.19	10.74	1.00	78494.85
17	8.14	4.71	68.23	2.20	16.56	11.29	1.00	72148.12
18	8.18	6.29	55.63	2.85	14.35	11.55	0.96	70263.06
19	9.10	5.78	55.70	2.74	16.25	10.69	0.94	77102.54
20	7.71	6.78	53.85	2.37	15.88	10.59	0.98	77895.15
21	8.63	4.55	55.88	2.44	15.61	10.77	0.99	76244.89
22	7.48	6.89	64.33	2.26	15.99	10.99	0.98	74377.22
23	4.69	4.67	54.46	1.77	16.71	10.81	0.97	76454.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.84	5.89	54.85	2.90	15.85	10.63	0.98	76643.78
最大值	10.56	12.36	68.23	4.16	17.40	11.55	1.02	82203.65
發生時間	6	15	17	5	8	18		5
最小值	4.51	2.90	43.82	1.77	14.35	10.16	0.94	70263.06
發生時間	12	16	14	23	18	8		18
零點偏移(率)	-0.50 %	-0.05 %	-0.31 %	-0.01 %		-0.02		0.00 %
全幅偏移(率)	-0.07 %	-0.04 %	-1.00 %	-0.21 %		0.21		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								