

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.01	10.28	63.67	2.73	17.84	11.27	1.05	74068.18
1	8.81	11.62	58.26	3.80	16.95	11.21	1.05	75209.63
2	9.18	12.94	68.98	4.23	15.28	12.07	1.05	70455.71
3	6.30	10.09	63.40	3.57	16.20	12.09	1.05	69334.75
4	6.76	7.39	54.28	3.79	16.23	11.27	1.05	74992.91
5	8.19	8.18	63.30	1.67	17.63	11.55	1.07	70320.63
6	5.07	10.15	59.08	1.70	16.77	11.59	1.07	72458.07
7	3.32	11.11	65.16	2.06	16.59	11.77	1.07	72069.51
8	9.19	10.77	61.02	2.39	16.97	11.51	1.05	72833.32
9	8.69	9.99	60.91	1.73	17.62	11.47	1.05	72660.25
10	8.52	7.92	48.87	1.91	17.01	11.34	1.06	73338.99
11	5.07	7.66	54.03	1.68	17.20	11.53	1.05	72059.61
12	5.06	8.82	55.97	1.64	17.12	11.57	1.06	71334.16
13	1.05	9.69	58.51	1.28	17.17	12.12	1.08	68116.81
14	0.10	10.93	58.41	0.68	18.30	12.25	1.08	66925.52
15	0.09	10.45	56.07	0.96	18.61	11.30	1.07	73034.83
16	1.92	9.11	57.84	1.48	17.56	11.17	1.07	75003.80
17	1.61	6.22	47.13	2.76	14.88	11.98	1.05	69813.49
18	0.43	1.90	51.50	2.40	15.40	11.77	1.05	72469.30
19	0.56	5.26	55.84	2.00	16.39	11.78	1.07	71934.11
20	6.19	5.23	67.52	1.52	17.73	11.46	1.07	73227.89
21	7.28	5.46	61.63	1.37	17.77	11.55	1.06	72320.54
22	7.56	5.85	49.27	1.65	17.78	11.41	1.05	73003.39
23	7.60	6.82	40.29	2.39	16.11	11.34	1.05	74771.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.19	8.49	57.54	2.14	16.96	11.60	1.06	72156.54
最大值	9.19	12.94	68.98	4.23	18.61	12.25	1.11	75209.63
發生時間	8	2	2	2	15	14		1
最小值	0.09	1.90	40.29	0.68	14.88	11.17	1.03	66925.52
發生時間	15	18	23	14	17	16		14
零點偏移(率)	-0.68 %	-0.01 %	-0.37 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.04 %	-1.38 %	0.36 %	-0.68 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.45	5.70	58.92	1.62	15.83	11.79	0.99	75484.80
1	4.54	4.28	60.34	1.55	18.86	9.85	0.96	88367.03
2	4.66	6.23	64.80	1.82	16.81	10.31	0.94	87124.15
3	4.83	7.94	61.51	2.16	16.90	10.51	0.95	84581.10
4	4.74	5.06	62.44	1.17	17.82	10.36	0.97	85854.74
5	4.85	8.02	50.16	1.85	16.98	10.20	0.97	87529.38
6	4.51	6.39	55.47	2.27	16.55	10.58	0.97	86792.44
7	2.68	5.83	59.81	2.00	16.93	10.56	0.98	84894.01
8	0.36	5.46	56.13	1.69	17.28	10.61	0.99	84304.12
9	4.27	6.47	48.90	1.36	18.07	10.48	0.98	85420.28
10	1.21	4.51	49.94	1.54	16.88	10.91	0.98	82575.96
11	1.71	5.08	42.34	1.50	16.98	10.37	0.99	84587.29
12	0.31	7.02	50.44	1.81	16.96	10.09	0.99	87872.14
13	0.60	2.74	51.82	1.64	16.35	10.99	0.99	81685.64
14	0.97	6.01	63.27	0.70	18.86	10.17	0.99	86134.77
15	2.99	7.85	37.66	1.49	17.36	10.24	0.99	85870.37
16	3.57	5.08	49.68	2.81	14.74	11.01	0.99	82206.59
17	0.62	3.66	52.37	1.95	16.84	10.76	0.99	83624.12
18	3.21	3.16	51.74	1.42	17.79	10.49	0.97	85310.10
19	7.92	3.45	48.66	1.82	18.23	10.31	0.97	86240.56
20	7.55	2.94	54.77	1.60	17.83	10.36	0.97	86027.04
21	7.11	5.65	55.13	1.56	17.67	10.65	0.97	83728.62
22	9.02	5.20	50.02	1.71	17.48	10.87	0.96	82808.14
23	9.00	4.04	40.16	1.82	17.58	10.55	0.96	84609.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.86	5.32	53.19	1.70	17.23	10.54	0.97	84734.68
最大值	9.02	8.02	64.80	2.81	18.86	11.79	1.00	88367.03
發生時間	22	5	2	16	1	0		1
最小值	0.31	2.74	37.66	0.70	14.74	9.85	0.94	75484.80
發生時間	12	13	15	14	16	1		0
零點偏移(率)	-0.40 %	-0.01 %	-0.92 %	-0.02 %		0.03		-0.20 %
全幅偏移(率)	2.23 %	-0.61 %	0.83 %	0.04 %		-0.08		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.80	8.31	52.99	2.61	16.54	10.59	0.99	81249.44
1	4.58	6.62	58.81	3.04	16.40	11.28	0.99	76921.61
2	5.38	6.18	52.52	2.92	16.12	10.37	0.99	81819.69
3	5.45	6.43	53.81	3.10	15.25	10.77	0.99	78208.91
4	5.36	7.72	52.94	3.04	15.38	10.67	0.98	77337.90
5	4.84	7.69	56.68	2.75	16.01	10.66	0.98	78294.91
6	4.66	7.25	53.28	3.00	15.19	10.65	0.98	78102.59
7	4.64	8.02	47.15	1.74	15.38	10.77	1.01	72456.96
8	6.08	12.48	45.88	1.93	15.77	10.23	1.00	76869.63
9	2.28	7.08	48.52	1.27	16.23	10.19	1.04	76281.34
10	4.10	9.53	43.30	1.38	15.89	9.94	1.00	77938.73
11	5.24	8.05	35.59	2.03	14.21	10.36	1.05	71942.29
12	3.06	7.64	35.43	1.37	15.55	10.15	1.01	72866.42
13	3.49	8.85	36.87	2.28	14.61	10.09	1.06	72627.09
14	1.81	2.35	39.01	1.00	16.70	9.50	1.04	76923.51
15	1.47	3.78	37.12	0.98	16.58	9.65	1.05	77371.66
16	0.69	4.08	48.11	0.94	16.92	9.99	1.06	75957.89
17	1.05	6.87	40.00	0.92	16.72	10.37	1.04	77557.44
18	1.18	3.93	55.53	1.09	16.02	10.82	0.99	74822.06
19	1.55	4.79	55.38	1.29	15.42	10.86	1.02	74471.07
20	3.92	5.78	53.36	1.50	15.20	10.73	1.04	75476.05
21	5.66	6.53	56.79	1.56	15.49	10.84	1.02	73168.65
22	5.63	4.32	57.66	1.36	16.64	10.37	1.02	86177.80
23	7.22	6.49	49.76	1.45	16.45	11.02	0.99	82343.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.80	6.70	48.60	1.86	15.86	10.45	1.01	76966.13
最大值	7.22	12.48	58.81	3.10	16.92	11.28	1.12	86177.80
發生時間	23	8	1	3	16	1		22
最小值	0.69	2.35	35.43	0.92	14.21	9.50	0.97	71942.29
發生時間	16	14	12	17	11	14		11
零點偏移(率)	-0.04 %	0.00 %	-0.72 %	-0.10 %		0.02		0.00 %
全幅偏移(率)	0.04 %	-0.81 %	-0.16 %	-0.11 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								