

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.91	6.45	51.92	2.91	15.63	11.58	0.98	84106.21
1	0.48	6.55	65.94	2.06	17.03	11.69	1.02	81751.51
2	1.49	7.77	67.42	2.72	16.88	11.84	1.01	80846.83
3	0.19	9.15	50.43	2.77	15.51	12.53	1.02	76154.92
4	0.19	9.29	54.45	2.61	15.70	12.52	1.04	75951.82
5	0.12	5.46	37.37	0.61	17.00	11.88	1.04	74733.05
6	6.03	6.43	55.22	1.20	16.71	11.42	1.02	84404.66
7	8.72	6.14	54.74	2.61	14.99	11.78	1.00	82813.23
8	9.98	5.12	59.87	2.75	15.26	11.73	0.98	82855.46
9	6.05	4.36	56.87	1.83	16.19	11.51	1.01	84269.90
10	4.75	4.96	62.25	1.19	17.01	11.51	1.02	83194.48
11	8.31	5.13	53.06	1.59	16.36	11.62	1.02	82508.44
12	5.53	4.40	56.77	0.50	17.89	11.31	1.02	83844.74
13	8.82	4.71	52.18	0.98	17.30	11.04	1.02	86296.35
14	9.97	4.87	54.27	1.22	17.73	11.29	1.00	84044.60
15	10.34	4.43	47.93	1.43	17.55	11.13	1.01	86044.95
16	10.97	4.38	59.12	1.16	17.53	11.13	1.02	85847.31
17	9.80	4.79	49.10	0.96	16.97	11.37	1.00	84178.97
18	9.32	4.85	50.85	0.93	17.63	11.42	0.98	83172.13
19	8.89	4.46	52.24	0.96	17.85	11.33	0.97	84169.92
20	9.85	4.30	57.40	0.77	18.54	10.86	0.98	87410.22
21	11.76	5.58	49.22	1.26	17.30	11.55	0.98	82680.75
22	10.37	4.58	50.45	0.98	17.91	11.01	0.98	86999.83
23	9.17	4.04	48.77	1.43	16.95	11.25	1.01	85909.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.00	5.51	54.08	1.56	16.89	11.51	1.00	83091.25
最 大 值	11.76	9.29	67.42	2.91	18.54	12.53	1.10	87410.22
發生時間	21	4	2	0	20	3		20
最 小 值	0.12	4.04	37.37	0.50	14.99	10.86	0.97	74733.05
發生時間	5	23	5	12	7	20		5
零點偏移(率)	-0.26 %	-0.01 %	-0.66 %	-0.02 %		-0.02		0.00 %
全幅偏移(率)	0.00 %	-0.77 %	1.36 %	-1.14 %		0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 113年05月01日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.57	4.18	67.45	2.32	17.11	10.36	0.95	82631.13
1	5.93	4.58	59.90	2.57	16.39	10.61	0.92	80238.50
2	1.23	4.55	69.76	2.22	17.12	10.81	0.94	80576.01
3	2.47	4.47	60.13	2.33	17.10	9.86	0.94	88119.73
4	1.35	8.21	53.86	2.64	16.17	11.78	0.93	74393.80
5	1.23	7.11	43.43	2.44	17.26	10.25	0.94	84815.60
6	1.32	6.08	63.05	2.62	15.24	10.37	0.93	85412.04
7	1.14	3.17	44.43	1.91	14.26	11.43	0.92	75988.02
8	3.61	2.25	43.96	1.45	15.33	11.07	0.93	79796.27
9	9.32	2.35	44.49	2.64	15.19	10.96	0.96	80774.73
10	1.85	8.62	36.56	0.80	13.78	11.31	0.95	74793.65
11	2.64	7.79	37.36	0.92	16.11	10.84	0.97	80432.34
12	9.07	4.22	43.36	1.45	18.19	10.01	0.96	85210.32
13	7.75	4.70	37.88	1.41	15.60	10.55	0.95	82875.68
14	8.88	7.59	39.86	1.55	15.88	10.51	0.92	82756.06
15	5.35	4.89	34.35	1.00	16.43	10.10	0.94	82446.94
16	4.43	4.19	46.94	0.62	18.23	9.86	0.92	83465.42
17	5.25	6.52	40.59	0.62	18.65	9.58	0.92	82792.52
18	8.31	7.12	42.03	1.20	18.16	9.49	0.93	83880.17
19	6.57	5.20	40.47	1.03	16.93	9.92	0.92	80245.74
20	4.06	2.68	44.69	0.78	17.52	9.67	0.92	81452.41
21	6.32	3.07	42.85	0.95	17.65	9.72	0.92	80173.37
22	6.01	4.52	39.51	0.86	17.24	9.72	0.92	81526.00
23	6.04	2.54	44.33	1.06	17.46	9.73	0.92	78968.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.70	5.03	46.72	1.56	16.62	10.35	0.93	81406.86
最 大 值	9.32	8.62	69.76	2.64	18.65	11.78	1.00	88119.73
發生時間	9	10	2	4	17	4		3
最 小 值	1.14	2.25	34.35	0.62	13.78	9.49	0.91	74393.80
發生時間	7	8	15	16	10	18		4
零點偏移(率)	-0.12 %	-0.00 %	-0.76 %	-0.01 %		-0.07		0.20 %
全幅偏移(率)	0.02 %	0.44 %	-0.41 %	0.02 %		0.40		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								