

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月12日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.81	9.11	45.45	3.37	14.60	12.40	1.34	69715.56
1	5.77	6.55	51.58	3.00	15.29	12.18	1.33	71258.32
2	7.97	6.34	53.63	2.73	16.27	12.07	1.33	71485.78
3	3.00	8.80	63.54	3.12	15.17	12.59	1.35	68144.75
4	4.42	7.77	65.55	2.77	15.88	12.24	1.39	70809.81
5	8.51	16.69	55.08	2.72	15.53	11.79	1.40	70538.89
6	10.69	5.78	58.72	3.59	14.40	12.41	1.39	70353.10
7	11.51	5.64	60.50	3.90	13.99	12.55	1.40	69350.13
8	9.38	7.44	59.52	3.90	13.86	12.60	1.40	68584.09
9	10.81	2.82	53.22	3.73	14.28	12.32	1.41	71305.42
10	10.01	3.44	62.02	3.69	14.58	12.33	1.38	69851.15
11	7.89	1.99	57.66	3.29	14.90	12.46	1.40	68611.93
12	9.18	2.27	62.63	3.25	14.88	12.41	1.38	69233.48
13	9.82	2.83	56.68	3.34	14.96	12.27	1.36	70116.85
14	10.30	1.84	66.99	3.38	14.70	12.57	1.40	68552.07
15	12.77	2.80	42.99	4.04	14.19	12.37	1.35	69669.25
16	8.34	3.85	44.52	4.24	13.83	12.67	1.38	67236.62
17	9.74	1.88	64.39	3.41	14.81	12.33	1.41	69829.81
18	9.97	2.78	47.54	3.83	14.48	12.32	1.41	69863.98
19	8.20	2.51	58.33	4.08	13.54	12.83	1.40	66329.93
20	7.12	1.65	63.30	3.09	15.36	12.37	1.38	68625.72
21	9.52	2.80	48.96	4.14	13.71	12.48	1.35	68816.25
22	10.48	2.29	60.58	4.22	13.70	12.80	1.36	66756.57
23	8.60	1.56	66.03	2.99	15.44	11.96	1.41	71932.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.66	4.64	57.06	3.49	14.68	12.39	1.38	69457.15
最大值	12.77	16.69	66.99	4.24	16.27	12.83	1.43	71932.05
發生時間	15	5	14	16	2	19		23
最小值	3.00	1.56	42.99	2.72	13.54	11.79	1.33	66329.93
發生時間	3	23	15	5	19	5		19
零點偏移(率)	0.00 %	-0.16 %	-0.05 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.36 %	1.69 %	-0.27 %	0.14 %		0.15	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月12日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.80	2.46	37.54	1.80	17.77	9.75	1.33	80862.97
1	4.89	3.10	52.43	1.51	18.67	10.16	1.33	82746.95
2	5.31	2.09	55.93	1.34	19.54	10.15	1.33	84576.02
3	8.75	3.39	49.53	2.30	16.91	10.31	1.33	84347.12
4	6.58	3.52	63.01	2.02	17.67	10.56	1.33	81966.42
5	8.89	5.30	50.62	2.13	17.97	10.13	1.34	87418.53
6	3.79	15.12	49.07	1.70	18.09	10.27	1.42	77525.12
7	8.62	3.40	64.70	2.26	16.89	11.22	1.43	74889.85
8	10.72	3.10	51.72	2.30	18.28	10.00	1.42	85641.57
9	9.89	3.04	54.72	2.36	16.54	10.59	1.39	85084.75
10	11.12	3.51	57.81	2.66	16.37	10.68	1.42	82267.49
11	9.52	2.86	53.45	2.01	18.27	10.19	1.40	83666.14
12	10.87	3.02	54.68	2.44	16.98	10.28	1.40	80253.41
13	10.37	4.33	55.27	2.49	17.04	10.42	1.38	82144.99
14	9.97	2.99	63.42	1.85	18.49	10.37	1.39	83281.40
15	10.13	4.15	56.18	1.70	19.15	10.12	1.41	86313.25
16	10.43	3.77	55.95	2.01	18.09	10.51	1.42	85172.47
17	10.42	3.19	59.31	2.37	17.11	10.79	1.43	83085.04
18	7.91	5.63	53.71	1.78	18.59	10.67	1.43	82753.03
19	9.71	5.62	62.06	2.05	17.81	10.49	1.43	84523.06
20	10.65	5.03	48.64	2.10	18.71	10.18	1.39	85677.49
21	9.14	3.19	60.28	1.73	18.67	10.30	1.38	85355.74
22	10.07	3.33	60.50	2.11	17.73	10.48	1.38	84328.44
23	10.24	3.69	45.84	2.30	17.24	10.44	1.37	84367.74
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.87	4.12	54.85	2.05	17.86	10.38	1.39	83260.37
最大值	11.12	15.12	64.70	2.66	19.54	11.22	1.46	87418.53
發生時間	10	6	7	10	2	7		5
最小值	3.79	2.09	37.54	1.34	16.37	9.75	1.33	74889.85
發生時間	6	2	0	2	10	0		7
零點偏移(率)	-0.16 %	-0.10 %	-0.11 %	-0.03 %		0.00	0.00	0.00 %
全幅偏移(率)	0.04 %	0.03 %	-0.42 %	0.03 %		0.03	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月12日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.55	6.12	45.92	2.11	16.68	10.76	1.81	85495.34
1	7.51	6.07	47.89	2.01	17.13	10.86	1.81	84543.13
2	10.15	9.52	49.02	2.42	18.74	10.13	1.82	89844.60
3	11.23	3.95	61.48	2.97	14.97	10.89	1.81	84717.05
4	7.88	3.35	67.33	2.28	17.01	10.56	1.81	86354.98
5	8.53	4.22	63.11	2.14	17.33	10.43	1.80	88591.65
6	11.00	5.46	64.99	2.39	16.31	10.68	1.80	86528.44
7	12.60	5.36	60.18	2.29	16.04	10.98	1.80	78027.85
8	13.52	5.32	63.32	2.85	16.05	10.84	1.80	85531.84
9	12.76	2.56	60.91	2.39	16.51	10.72	1.80	85595.25
10	9.27	3.69	57.15	2.11	16.50	10.63	1.81	85638.80
11	11.19	2.10	62.07	2.19	17.88	10.39	1.84	85175.46
12	10.75	1.92	57.75	2.35	16.32	10.67	1.83	81718.25
13	9.80	1.80	62.68	2.35	16.07	10.84	1.82	81982.19
14	8.45	1.90	56.53	2.03	17.14	10.54	1.81	83153.82
15	9.31	3.28	53.58	2.24	15.70	10.76	1.82	84418.21
16	10.43	2.58	64.65	2.71	15.19	11.10	1.84	82269.34
17	10.44	2.70	59.05	2.80	15.12	11.28	1.82	80090.46
18	10.11	2.02	60.50	2.70	15.70	11.11	1.83	80073.57
19	11.02	1.87	63.93	2.50	16.03	11.12	1.84	81411.65
20	9.90	2.92	56.09	2.18	16.94	10.61	1.82	84850.61
21	10.01	2.87	57.64	2.22	16.73	10.58	1.81	84476.80
22	9.48	1.94	62.81	2.30	15.72	11.00	1.82	82419.30
23	11.68	2.92	59.78	2.34	16.82	10.71	1.82	82797.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.15	3.60	59.10	2.37	16.44	10.76	1.82	83987.77
最大值	13.52	9.52	67.33	2.97	18.74	11.28	1.85	89844.60
發生時間	8	2	4	3	2	17		2
最小值	6.55	1.80	45.92	2.01	14.97	10.13	1.79	78027.85
發生時間	0	13	0	1	3	2		7
零點偏移(率)	-0.04 %	-0.08 %	-0.03 %	-0.01 %		0.04	0.00	0.00 %
全幅偏移(率)	0.00 %	0.17 %	-0.78 %	-0.00 %		0.00	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								