

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月31日

報表日期: 114年03月31日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.04	7.55	61.40	1.75	15.71	10.95	1.27	82322.42
1	5.81	4.20	55.72	1.42	17.52	11.03	1.29	82632.00
2	5.27	4.60	52.24	1.62	15.73	11.26	1.29	77647.65
3	9.09	3.93	51.17	1.92	15.73	11.06	1.29	81695.85
4	8.88	6.71	44.59	2.67	15.33	10.87	1.29	82055.26
5	6.57	4.75	64.31	1.84	15.73	11.70	1.28	81520.24
6	7.12	2.86	50.03	1.57	15.33	10.68	1.29	79792.11
7	8.25	6.56	42.78	1.43	16.99	10.36	1.27	82326.79
8	8.31	7.16	35.16	0.90	17.69	9.65	1.27	82550.68
9	11.90	3.08	42.06	1.73	16.83	10.14	1.26	77973.38
10	9.94	3.74	45.18	2.08	17.94	8.84	1.24	82035.99
11	9.60	1.39	52.72	1.81	15.84	10.34	1.23	80477.01
12	6.16	2.26	62.32	0.82	17.08	10.94	1.23	75582.18
13	4.66	2.52	55.99	1.31	16.30	10.54	1.23	80741.36
14	5.39	2.81	54.27	1.46	16.90	10.73	1.23	79186.61
15	1.38	2.86	54.95	1.15	16.19	10.85	1.23	79699.44
16	7.71	2.73	52.69	0.99	18.75	10.42	1.23	83934.29
17	9.46	7.74	48.35	1.15	18.38	9.69	1.23	85227.54
18	7.95	3.08	49.09	0.91	18.75	10.08	1.24	84956.28
19	8.96	2.89	47.98	1.10	17.27	10.16	1.27	84212.07
20	8.48	2.63	54.82	0.79	18.09	10.30	1.29	81391.89
21	8.09	2.97	55.16	0.79	18.58	9.99	1.29	83979.45
22	9.70	2.96	58.31	0.75	18.97	9.86	1.29	83110.54
23	9.50	3.37	43.60	1.27	17.32	10.29	1.29	82522.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.84	3.97	51.45	1.38	17.04	10.45	1.26	81565.55
最 大 值	11.90	7.74	64.31	2.67	18.97	11.70	1.29	85227.54
發生時間	9	17	5	4	22	5		17
最 小 值	1.38	1.39	35.16	0.75	15.33	8.84	1.23	75582.18
發生時間	15	11	8	22	4	10		12
零點偏移(率)	0.00 %	-0.04 %	-0.02 %	-0.00 %		0.00		0.20 %
全幅偏移(率)	0.00 %	0.10 %	-0.28 %	0.08 %		0.22		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月31日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.77	2.43	53.31	3.21	14.90	11.06	1.06	82931.93
1	11.99	3.35	57.40	3.60	14.81	11.18	1.06	81130.51
2	14.08	2.42	52.91	3.64	13.90	11.17	1.06	81247.52
3	9.85	3.26	62.76	2.52	15.65	10.88	1.06	83839.33
4	14.47	2.37	48.56	3.76	14.01	11.06	1.06	85765.59
5	15.29	2.71	56.52	4.51	13.06	11.34	1.06	83032.34
6	13.19	2.84	53.95	2.46	14.77	11.16	1.06	84685.04
7	15.65	2.25	54.13	2.76	14.70	11.10	1.05	84303.23
8	6.07	2.50	57.14	1.49	15.49	10.86	1.06	83667.93
9	2.84	2.95	61.82	0.50	16.49	10.20	1.06	81318.03
10	2.88	3.07	55.26	0.31	16.88	10.22	1.05	82810.78
11	1.77	3.14	49.33	0.26	16.49	10.57	1.04	82892.60
12	0.99	3.09	60.60	0.89	17.72	10.56	1.05	84035.22
13	0.58	5.62	48.14	1.97	15.97	10.56	1.06	84268.96
14	4.10	1.57	52.31	1.64	16.41	10.51	1.06	84743.36
15	2.22	3.85	46.49	2.05	16.17	10.73	1.06	84007.70
16	1.91	3.31	52.58	2.36	15.81	10.64	1.05	87062.29
17	0.40	1.21	60.99	1.81	15.53	10.81	1.04	85227.54
18	1.53	1.83	62.43	0.96	17.89	10.21	1.04	85369.45
19	9.37	2.92	57.17	1.87	17.09	10.34	1.05	87417.39
20	16.93	2.65	51.19	3.28	15.87	10.68	1.05	85153.11
21	4.40	2.14	61.15	1.33	16.76	10.79	1.06	83272.26
22	14.34	2.57	57.66	2.77	16.69	10.63	1.06	84646.70
23	5.69	6.91	55.64	2.86	15.99	11.12	1.06	80924.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.76	2.96	55.39	2.20	15.79	10.77	1.05	83906.38
最 大 值	16.93	6.91	62.76	4.51	17.89	11.34	1.07	87417.39
發生時間	20	23	3	5	18	5		19
最 小 值	0.40	1.21	46.49	0.26	13.06	10.20	1.04	80924.30
發生時間	17	17	15	11	5	9		23
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	-0.00 %		0.01		0.10 %
全幅偏移(率)	0.14 %	0.28 %	-0.06 %	0.08 %		0.20		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月31日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.97	2.68	62.98	1.37	15.68	10.31	1.52	81933.35
1	6.83	9.52	60.89	1.06	17.66	10.21	1.52	82343.08
2	9.13	5.27	62.78	1.93	15.38	10.27	1.52	79823.69
3	9.61	7.98	60.18	1.69	15.81	10.07	1.52	79517.25
4	10.76	6.58	58.48	1.83	15.82	10.05	1.52	78572.81
5	9.43	7.39	56.92	1.42	16.24	9.91	1.51	80156.55
6	6.81	3.05	59.90	1.74	15.04	10.00	1.52	77998.00
7	0.54	6.40	56.43	0.75	15.54	9.72	1.48	80715.94
8	4.67	2.83	49.81	1.31	14.89	9.65	1.48	77896.52
9	5.20	3.92	41.16	1.33	15.76	9.28	1.48	77258.72
10	7.52	3.00	58.78	1.25	15.62	10.08	1.49	80519.60
11	7.25	2.87	56.01	1.13	16.81	9.76	1.49	80927.20
12	1.73	3.71	69.47	0.42	17.85	9.49	1.49	79201.48
13	1.75	4.90	50.18	1.00	15.55	10.37	1.50	75485.07
14	6.19	5.98	54.68	0.96	16.47	9.65	1.50	79870.38
15	5.40	4.17	61.34	0.75	17.64	9.30	1.48	79961.60
16	4.54	3.99	56.36	0.60	16.48	9.83	1.50	81383.06
17	2.30	5.47	44.02	0.37	18.17	9.16	1.48	79937.51
18	7.37	11.69	49.54	1.39	18.78	8.86	1.48	82651.32
19	10.62	2.18	55.52	1.22	16.81	9.71	1.50	83554.98
20	8.33	3.21	56.11	0.80	17.37	9.60	1.50	84332.82
21	3.47	1.49	61.87	0.57	16.90	9.99	1.50	82191.35
22	3.98	1.73	62.66	0.53	17.64	9.72	1.48	83791.93
23	5.49	4.85	58.59	0.73	17.46	9.71	1.49	85126.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.20	4.79	56.86	1.09	16.56	9.78	1.50	80631.30
最 大 值	10.76	11.69	69.47	1.93	18.78	10.37	1.53	85126.88
發生時間	4	18	12	2	18	13		23
最 小 值	0.54	1.49	41.16	0.37	14.89	8.86	1.48	75485.07
發生時間	7	21	9	17	8	18		13
零點偏移(率)	-0.01 %	0.01 %	-0.03 %	0.00 %		0.03		0.20 %
全幅偏移(率)	0.01 %	0.13 %	0.03 %	0.04 %		0.43		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								