

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.56	6.19	49.31	0.27	20.43	10.33	1.01	87859.66
1	6.67	10.13	63.89	0.48	19.04	11.13	0.99	83261.19
2	7.27	10.16	49.51	0.86	17.41	11.04	0.99	84345.07
3	10.29	10.50	47.09	2.11	16.36	11.40	0.99	80180.43
4	10.30	8.47	49.20	1.47	16.46	11.32	0.98	80476.28
5	9.55	13.72	58.75	0.81	17.52	11.49	1.02	79283.71
6	10.27	13.57	54.03	0.75	17.88	11.17	1.05	82973.91
7	9.64	13.52	49.37	1.05	17.05	11.37	1.05	80602.39
8	9.36	8.32	49.50	1.21	16.43	11.54	1.04	79841.33
9	7.38	6.58	55.97	0.77	17.08	11.43	1.06	81044.10
10	8.32	7.34	48.05	0.87	17.59	11.07	1.05	81268.13
11	5.42	11.59	49.03	0.51	17.85	11.03	1.05	79901.10
12	6.92	5.05	49.58	0.45	17.58	11.33	1.06	76337.99
13	9.39	4.99	54.91	0.48	19.77	10.75	1.05	78973.67
14	11.11	15.19	45.34	1.14	16.59	11.02	1.06	78016.73
15	7.68	3.83	56.86	1.06	16.61	11.87	1.06	75880.56
16	6.87	3.04	54.80	0.61	17.66	11.25	1.03	82294.24
17	8.96	3.51	56.82	0.95	16.22	11.73	1.05	80037.16
18	9.47	3.55	58.57	0.47	18.31	11.02	1.07	84008.00
19	9.47	6.71	55.02	0.75	17.53	11.19	1.08	83279.75
20	9.38	8.01	55.16	0.88	16.53	11.52	1.06	81831.33
21	10.00	9.00	51.24	1.25	15.99	11.47	1.05	82090.93
22	10.24	8.02	49.87	1.08	16.40	11.31	1.05	83076.94
23	8.03	7.88	50.81	1.80	14.63	11.89	1.07	78137.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.69	8.29	52.61	0.92	17.29	11.28	1.04	81041.76
最大值	11.11	15.19	63.89	2.11	20.43	11.89	1.09	87859.66
發生時間	14	14	1	3	0	23		0
最小值	5.42	3.04	45.34	0.27	14.63	10.33	0.98	75880.56
發生時間	11	16	14	0	23	0		15
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	-0.00 %		0.05		0.00 %
全幅偏移(率)	0.02 %	1.71 %	0.47 %	0.70 %		-0.02		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.15	5.04	40.79	0.33	19.87	9.08	1.12	79166.68
1	4.61	7.71	43.36	0.23	20.80	8.98	1.12	82856.41
2	9.16	9.67	49.82	0.50	18.31	9.49	1.12	82190.18
3	5.14	7.80	28.65	0.43	18.44	9.25	1.12	79202.41
4	9.55	10.51	38.55	0.70	18.78	9.20	1.13	81659.41
5	9.57	8.29	51.82	0.75	18.18	9.77	1.15	84827.28
6	3.56	7.77	37.84	0.60	17.87	9.68	1.16	85061.01
7	7.43	8.54	45.78	0.75	17.28	10.26	1.16	77843.49
8	6.52	4.69	50.77	0.57	17.98	10.59	1.15	79673.60
9	9.71	3.83	55.73	0.43	18.46	10.22	1.15	82880.75
10	8.48	4.01	44.99	0.47	18.07	10.19	1.16	83068.32
11	7.92	5.75	50.29	0.28	18.88	9.86	1.18	85024.92
12	9.28	5.21	51.26	0.30	18.90	10.02	1.18	84156.32
13	17.21	7.30	56.59	1.98	18.34	10.02	1.16	82437.70
14	12.71	6.52	52.09	1.27	19.19	9.55	1.16	86240.00
15	9.34	3.51	52.33	0.73	17.64	9.95	1.15	82979.40
16	8.85	3.60	52.63	0.79	17.53	10.46	1.16	76581.55
17	8.72	1.70	41.17	0.52	18.96	9.76	1.14	82810.62
18	10.02	6.44	45.26	0.57	18.58	9.98	1.15	85508.90
19	11.74	6.13	50.16	0.57	18.27	9.88	1.15	84432.04
20	9.01	4.71	49.91	0.75	17.26	10.27	1.15	81911.80
21	10.32	5.03	45.02	0.44	17.86	10.04	1.15	82793.94
22	9.66	5.87	55.11	0.32	18.86	9.88	1.16	83986.70
23	9.64	7.78	54.72	0.24	19.57	9.50	1.16	86333.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.97	6.14	47.69	0.60	18.49	9.83	1.15	82651.11
最大值	17.21	10.51	56.59	1.98	20.80	10.59	1.18	86333.28
發生時間	13	4	13	13	1	8		23
最小值	3.56	1.70	28.65	0.23	17.26	8.98	1.12	76581.55
發生時間	6	17	3	1	20	1		16
零點偏移(率)	-0.04 %	-0.00 %	-0.02 %	-0.01 %		-0.02		-0.10 %
全幅偏移(率)	0.04 %	0.34 %	-0.18 %	0.01 %		0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.81	7.41	54.39	1.65	16.40	10.76	0.94	79425.91
1	0.84	3.44	53.10	1.63	17.62	10.72	0.94	79938.86
2	1.08	8.92	55.02	2.17	15.23	10.67	0.94	77370.47
3	0.67	5.32	48.10	1.99	14.90	10.77	0.94	75180.54
4	1.19	6.65	50.85	2.10	15.04	10.75	0.95	77540.70
5	7.56	7.21	59.57	2.49	15.50	10.99	0.97	78594.61
6	11.90	10.71	58.07	2.68	14.99	11.04	0.97	77553.98
7	5.69	9.99	56.32	2.19	16.34	10.55	0.99	72982.63
8	0.76	4.61	57.33	1.67	16.27	11.20	0.99	79737.28
9	0.01	13.91	53.50	1.71	16.76	11.15	1.00	84366.11
10	0.00	4.91	53.34	1.58	16.89	11.05	0.99	83943.27
11	0.00	5.09	58.25	1.84	15.53	11.61	0.98	82988.66
12	0.00	12.17	61.88	1.71	17.06	11.15	0.96	85878.89
13	0.66	4.67	50.52	2.06	15.68	11.42	0.97	84274.85
14	1.83	4.52	50.10	2.54	14.97	11.40	0.97	82557.75
15	1.05	5.89	55.66	1.91	16.72	11.04	0.98	84792.12
16	1.89	4.00	48.51	1.98	15.81	11.34	0.95	81201.31
17	1.83	3.32	48.68	2.05	16.06	11.22	0.94	81048.49
18	2.02	3.45	52.54	1.84	16.11	10.85	0.95	77459.35
19	6.09	9.49	48.06	2.18	14.82	10.66	0.95	77413.01
20	7.80	4.42	49.60	2.38	15.44	10.50	0.95	76960.23
21	10.93	6.37	52.19	2.83	14.83	10.92	0.98	75343.62
22	9.65	9.36	52.69	2.73	15.13	10.78	0.97	76199.07
23	11.07	5.96	47.52	4.30	15.94	10.54	0.97	77057.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.56	6.74	53.16	2.18	15.83	10.96	0.96	79575.40
最大值	11.90	13.91	61.88	4.30	17.62	11.61	1.02	85878.89
發生時間	6	9	12	23	1	11		12
最小值	0.00	3.32	47.52	1.58	14.82	10.50	0.91	72982.63
發生時間	10	17	23	10	19	20		7
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	0.00 %		0.08		0.00 %
全幅偏移(率)	-1.65 %	0.74 %	-1.34 %	-0.00 %		0.41		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								