

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.95	1.84	55.21	0.47	21.35	10.87	1.41	78648.18
1	7.85	2.77	63.10	0.55	21.12	11.33	1.41	75421.77
2	9.88	3.24	51.65	0.85	19.95	11.03	1.41	78459.60
3	9.86	3.90	59.52	1.09	19.23	11.24	1.41	77207.81
4	9.84	4.59	54.53	1.26	18.12	11.46	1.42	75823.73
5	9.21	7.71	58.02	1.42	17.88	11.62	1.43	87772.75
6	7.56	3.77	64.44	1.10	19.09	11.76	1.43	72830.31
7	9.52	5.03	57.84	1.17	19.52	11.45	1.43	74982.87
8	7.25	2.65	58.87	1.02	19.58	12.06	1.44	70009.97
9	10.63	1.29	52.40	1.06	19.64	11.05	1.42	76981.12
10	9.54	2.63	64.24	1.35	18.28	11.69	1.40	73711.24
11	9.97	6.40	50.89	1.49	17.80	11.49	1.39	75800.69
12	9.41	1.85	58.85	1.34	18.11	11.56	1.38	74331.88
13	8.59	1.14	59.52	1.19	19.34	11.89	1.39	71093.59
14	8.14	2.04	63.44	1.31	18.31	12.22	1.39	69484.80
15	8.33	2.46	61.50	1.27	18.48	11.87	1.39	71724.27
16	10.12	2.39	63.70	0.86	19.81	11.28	1.40	74974.56
17	9.55	2.25	58.10	0.89	19.89	11.45	1.39	73825.58
18	9.20	1.72	54.24	0.58	20.84	11.36	1.39	74146.62
19	4.72	1.82	61.28	0.86	19.86	12.06	1.39	69874.66
20	5.59	1.96	59.25	0.98	20.11	11.75	1.39	71731.62
21	5.71	1.35	53.98	0.58	21.04	11.27	1.40	74842.42
22	4.64	1.57	58.84	0.51	20.65	10.94	1.42	77144.65
23	1.66	1.08	68.09	0.23	21.28	11.29	1.46	74294.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.20	2.81	58.81	0.98	19.55	11.50	1.41	74796.63
最大值	10.63	7.71	68.09	1.49	21.35	12.22	1.46	87772.75
發生時間	9	5	23	11	0	14		5
最小值	1.66	1.08	50.89	0.23	17.80	10.87	1.38	69484.80
發生時間	23	23	11	23	11	0		14
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.17 %	0.03 %		0.12	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.27	4.35	61.13	2.07	18.31	10.56	1.46	67355.16
1	13.03	2.82	66.83	4.79	18.60	10.56	1.46	66984.74
2	18.30	3.55	68.86	3.79	17.35	10.72	1.46	66031.59
3	9.03	3.41	63.17	4.73	15.45	11.34	1.47	63764.62
4	10.08	5.62	63.13	3.50	16.13	11.08	1.46	64488.76
5	10.57	4.24	60.75	3.34	16.61	10.91	1.46	64201.94
6	12.70	4.79	60.96	3.73	15.79	10.83	1.49	66237.45
7	10.86	3.88	57.83	3.59	16.34	10.49	1.49	62991.39
8	10.78	3.61	60.55	3.34	15.74	11.17	1.50	63447.42
9	11.16	2.70	62.97	2.90	16.35	10.77	1.51	65708.75
10	9.03	2.66	62.75	2.56	16.54	10.80	1.52	64719.42
11	11.28	2.30	70.39	2.60	16.65	10.62	1.53	65201.79
12	8.01	3.39	65.03	2.44	16.94	10.74	1.54	63431.08
13	9.94	1.33	66.30	2.58	16.71	10.99	1.54	64111.75
14	11.42	3.56	64.18	2.54	17.03	10.82	1.54	65086.35
15	11.31	4.66	65.97	2.60	16.03	10.99	1.55	64100.74
16	10.00	5.99	59.10	2.65	15.88	10.99	1.54	63073.80
17	9.71	3.68	64.97	2.16	17.64	10.53	1.55	66716.02
18	9.13	1.91	61.06	2.37	17.12	10.88	1.54	62660.42
19	10.81	7.08	56.33	2.19	18.08	10.44	1.54	65908.68
20	9.69	6.51	60.80	2.63	16.79	10.85	1.53	64990.22
21	9.53	7.42	47.57	3.27	17.49	10.36	1.51	62194.52
22	9.18	0.95	49.07	2.02	19.20	9.77	1.50	64991.69
23	6.87	1.61	63.03	1.51	18.92	10.65	1.51	65527.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.45	3.83	61.78	2.91	16.99	10.74	1.51	64746.91
最大值	18.30	7.42	70.39	4.79	19.20	11.34	1.56	67355.16
發生時間	2	21	11	1	22	3		0
最小值	6.87	0.95	47.57	1.51	15.45	9.77	1.45	62194.52
發生時間	23	22	21	23	3	22		21
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.01 %		-0.05	0.00	0.00 %
全幅偏移(率)	1.23 %	0.23 %	-0.44 %	0.07 %		0.01	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.02	1.61	62.73	2.20	16.32	11.53	1.29	81932.26
1	11.38	2.47	56.03	2.66	17.99	10.62	1.29	87019.47
2	10.74	4.13	54.20	3.24	15.34	11.08	1.30	82937.41
3	10.71	9.11	56.53	3.00	15.13	11.09	1.30	82444.29
4	11.72	6.10	57.06	2.92	15.66	10.94	1.30	83993.66
5	10.38	8.39	51.39	2.46	16.80	10.53	1.30	84021.51
6	11.47	9.40	56.02	2.61	17.25	10.50	1.30	85588.57
7	6.58	7.33	57.60	2.34	15.38	11.03	1.25	77510.25
8	15.65	8.55	57.52	3.46	15.91	10.78	1.27	85642.86
9	9.21	3.44	57.03	2.58	15.40	11.08	1.29	87853.19
10	11.21	2.28	56.45	2.68	15.75	11.03	1.26	85850.23
11	9.68	7.55	47.53	3.80	15.02	10.46	1.25	78687.51
12	12.58	1.13	57.13	2.65	17.46	9.95	1.25	86013.04
13	13.16	2.06	58.95	2.44	16.54	10.92	1.27	86564.10
14	18.40	5.82	56.41	3.15	14.80	11.17	1.26	84264.62
15	13.24	4.99	58.35	2.93	15.55	11.01	1.25	80894.83
16	11.59	2.73	59.24	2.77	15.78	10.92	1.25	83312.42
17	7.90	1.95	58.40	2.39	16.00	10.80	1.25	86897.99
18	8.25	7.20	65.23	2.21	16.99	10.45	1.25	85479.70
19	11.08	14.45	53.57	4.50	14.71	10.75	1.25	82594.20
20	7.94	2.98	58.72	2.97	15.42	10.91	1.25	82565.21
21	9.27	2.07	56.36	2.86	15.12	10.96	1.25	81633.67
22	10.27	1.79	58.70	2.65	15.61	10.74	1.25	84186.30
23	9.84	7.78	60.10	2.17	17.68	10.37	1.26	87146.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.84	5.22	57.14	2.82	15.98	10.82	1.27	83959.73
最大值	18.40	14.45	65.23	4.50	17.99	11.53	1.31	87853.19
發生時間	14	19	18	19	1	0		9
最小值	6.58	1.13	47.53	2.17	14.71	9.95	1.23	77510.25
發生時間	7	12	11	23	19	12		7
零點偏移(率)	-0.01 %	-0.03 %	-0.11 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.64 %	0.21 %	-0.16 %	0.11 %		0.33	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								