

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年05月05日

報表日期: 113年05月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.98	10.91	57.97	1.10	15.58	12.75	1.01	73730.21
1	3.03	7.01	56.59	0.92	18.39	11.62	0.99	80682.15
2	9.14	7.11	41.74	1.63	16.72	11.57	0.97	82709.79
3	11.91	12.17	39.54	2.28	15.40	11.64	0.98	83776.83
4	9.76	6.02	41.85	0.88	16.39	11.79	1.02	81642.71
5	9.85	5.84	55.74	2.02	15.60	12.00	1.02	81634.11
6	8.60	4.43	62.88	0.49	17.45	11.49	1.02	83035.50
7	9.96	4.05	52.62	0.75	17.35	11.17	1.02	85427.62
8	7.76	4.56	64.54	0.72	18.14	11.35	1.02	82630.59
9	5.41	9.56	60.31	0.30	18.96	10.98	1.03	85309.25
10	6.35	3.53	61.47	0.28	19.36	11.22	1.02	83897.27
11	7.80	4.33	56.39	0.54	18.91	11.19	1.02	84437.22
12	7.91	3.33	61.02	0.69	18.96	11.69	1.02	79684.75
13	7.10	7.96	63.56	0.47	18.73	11.97	1.02	77294.11
14	2.19	8.17	57.97	0.38	18.85	11.88	0.99	78169.70
15	7.32	7.11	59.51	0.37	19.93	11.06	1.01	83587.38
16	2.23	6.62	53.46	0.19	19.48	10.87	1.02	85977.42
17	7.44	6.77	46.86	0.54	19.64	10.46	1.02	88747.50
18	6.97	8.11	43.71	0.58	19.06	10.94	1.02	85568.13
19	6.82	7.38	65.61	0.29	19.30	11.14	1.02	83854.00
20	7.87	6.99	44.65	0.49	18.48	11.07	0.99	85115.89
21	4.69	8.09	56.39	0.29	17.98	11.91	0.98	78611.16
22	7.83	7.26	58.84	0.61	18.18	11.46	0.99	81958.80
23	9.30	6.61	59.56	0.45	18.23	11.43	1.02	82716.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.01	6.83	55.12	0.72	18.13	11.44	1.01	82508.28
最 大 值	11.91	12.17	65.61	2.28	19.93	12.75	1.04	88747.50
發生時間	3	3	19	3	15	0		17
最 小 值	0.98	3.33	39.54	0.19	15.40	10.46	0.97	73730.21
發生時間	0	12	3	16	3	17		0
零點偏移(率)	-0.06 %	0.01 %	-0.09 %	-0.03 %		-0.10		0.20 %
全幅偏移(率)	-2.26 %	1.82 %	0.05 %	0.63 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月05日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月05日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.81	4.47	41.97	0.74	18.60	10.21	1.02	83166.30
1	2.13	5.25	41.82	0.66	18.21	10.62	1.02	80607.77
2	7.71	8.06	41.78	1.93	15.16	10.58	1.02	81075.24
3	6.44	5.67	53.21	1.30	17.78	10.16	1.03	83367.02
4	4.60	1.97	46.01	1.23	17.85	10.11	1.04	80358.85
5	5.91	1.76	49.02	1.08	17.20	10.15	1.04	81161.81
6	3.39	10.16	61.06	0.74	17.70	10.20	1.04	78866.30
7	5.52	4.96	47.83	1.44	16.32	10.20	1.01	81744.60
8	2.71	4.20	52.79	0.79	18.15	10.03	1.03	79384.10
9	5.36	5.07	50.33	1.20	17.53	9.86	1.02	80337.85
10	2.97	3.94	55.35	0.77	18.88	9.87	1.02	80955.06
11	5.58	4.20	52.80	1.25	17.60	9.97	1.01	81081.22
12	3.87	3.93	53.63	0.86	18.16	9.98	1.02	78923.28
13	3.60	4.48	51.47	1.02	18.93	9.70	1.01	81737.82
14	2.84	5.12	54.55	0.79	18.81	10.16	1.06	80996.74
15	1.02	5.20	53.81	0.66	18.97	9.95	1.05	83143.08
16	2.29	3.58	56.91	0.85	19.33	9.60	1.01	83548.21
17	2.62	6.08	43.94	0.67	18.15	9.71	1.00	81303.52
18	1.53	2.49	54.49	0.56	19.81	9.56	1.04	81649.12
19	2.09	4.73	46.52	0.67	18.23	9.78	1.04	80367.59
20	2.08	4.47	50.92	0.73	18.67	9.70	1.02	80785.82
21	1.18	5.36	54.26	0.56	18.63	10.03	1.00	75797.79
22	1.10	3.53	59.73	0.62	19.12	9.65	1.00	79417.70
23	2.38	3.22	41.75	0.71	17.33	9.88	1.02	79931.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.41	4.66	50.66	0.91	18.13	9.99	1.02	80821.19
最 大 值	7.71	10.16	61.06	1.93	19.81	10.62	1.11	83548.21
發生時間	2	6	6	2	18	1		16
最 小 值	1.02	1.76	41.75	0.56	15.16	9.56	0.99	75797.79
發生時間	15	5	23	18	2	18		21
零點偏移(率)	-0.05 %	-0.02 %	-0.19 %	-0.00 %		-0.05		0.20 %
全幅偏移(率)	-0.20 %	0.03 %	-0.03 %	0.00 %		0.41		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								