

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	15.43	58.04	2.21	18.48	11.22	1.06	68024.71
1	9.74	17.84	48.63	1.84	20.00	10.40	1.06	74441.17
2	6.29	16.25	56.07	1.42	20.93	10.44	1.07	73634.34
3	8.72	19.51	41.70	2.03	19.44	10.48	1.06	74455.37
4	10.53	16.19	53.53	2.15	18.69	11.14	1.06	70618.77
5	13.08	17.54	41.25	2.39	19.49	10.53	1.07	71817.15
6	8.60	18.65	46.74	1.98	18.83	10.66	1.07	73042.59
7	10.12	19.47	52.40	1.81	19.63	10.74	1.09	72318.07
8	9.99	無效	56.11	1.60	21.27	9.92	1.11	75767.10
9	9.64	19.60	57.24	1.85	19.36	10.36	1.10	74459.64
10	9.84	無效	36.97	1.95	19.39	10.62	1.10	73193.70
11	9.27	19.69	46.44	2.34	18.08	11.14	1.11	70367.47
12	9.53	17.33	53.61	2.08	19.35	11.06	1.11	70165.80
13	8.94	16.61	51.08	1.95	19.84	10.54	1.11	73485.92
14	9.48	16.60	42.69	2.40	18.06	11.10	1.11	70800.37
15	11.84	17.60	49.93	2.42	17.65	11.36	1.11	69130.96
16	8.75	18.85	48.77	2.22	17.90	11.26	1.10	69820.36
17	8.52	13.04	52.54	1.55	20.40	10.52	1.10	73683.02
18	11.41	12.79	41.92	1.82	20.28	10.25	1.10	74393.37
19	8.36	16.50	44.62	1.74	19.53	10.29	1.09	75072.96
20	8.72	15.70	56.44	1.83	19.20	10.88	1.10	72129.72
21	7.40	15.36	43.73	1.59	20.03	10.40	1.10	74487.84
22	7.57	15.29	51.20	1.61	19.94	10.54	1.10	73181.68
23	9.39	15.70	46.58	1.14	21.43	9.73	1.11	77165.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	9.36	16.89	49.09	1.91	19.47	10.65	1.09	72735.74
最大值	13.08	19.69	58.04	2.42	21.43	11.36	1.11	77165.69
發生時間	5	11	0	15	23	15		23
最小值	6.29	12.79	36.97	1.14	17.65	9.73	1.06	68024.71
發生時間	2	18	10	23	15	23		0
零點偏移(率)	-0.05 %	0.00 %	-0.01 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.02 %	0.00 %	0.02 %		-0.04		0.30 %
有效比率	100.00 %	91.67 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.07	16.11	44.44	0.65	19.55	9.49	1.20	78179.49
1	1.76	18.99	55.53	0.97	18.17	9.81	1.20	81578.00
2	2.47	16.09	49.30	1.17	18.47	9.59	1.20	80802.74
3	5.96	15.29	54.66	1.71	16.99	9.91	1.20	79360.75
4	8.73	14.01	60.33	1.89	17.23	9.84	1.20	81705.00
5	7.48	15.38	56.24	1.64	17.50	10.15	1.20	78922.17
6	5.74	15.40	64.09	0.88	19.64	9.32	1.18	81400.39
7	10.79	16.96	53.86	2.00	16.50	9.95	1.18	80741.22
8	7.93	17.51	53.79	1.44	18.62	9.84	1.19	76887.76
9	4.24	無效	64.75	0.69	19.90	9.32	1.20	78201.08
10	2.89	無效	57.66	1.02	18.81	9.42	1.18	76891.35
11	8.89	16.19	50.81	2.11	17.33	9.68	1.18	75199.90
12	8.69	16.88	59.59	1.30	19.53	9.26	1.18	78634.56
13	9.72	無效	56.86	1.99	17.77	9.41	1.18	79625.93
14	9.72	14.19	45.42	2.31	16.24	9.91	1.18	74819.30
15	9.27	15.92	50.25	1.89	16.60	9.87	1.18	75960.20
16	5.61	16.93	56.06	1.26	18.76	9.42	1.19	77978.55
17	8.83	無效	50.09	1.85	17.78	9.44	1.19	77832.74
18	2.53	無效	61.23	0.90	19.24	9.29	1.19	73467.20
19	4.07	17.26	61.66	1.45	16.97	9.37	1.21	78062.12
20	7.12	12.05	49.02	1.63	16.70	9.81	1.20	77941.76
21	3.05	14.91	50.41	1.02	18.00	9.80	1.19	73088.64
22	1.83	18.48	60.45	0.88	18.33	9.60	1.18	72015.60
23	2.56	14.82	47.64	0.87	19.07	8.94	1.17	76391.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	19	24	24	24	24	24	24
平均值	5.87	15.97	54.76	1.40	18.07	9.60	1.19	77737.01
最大值	10.79	18.99	64.75	2.31	19.90	10.15	1.21	81705.00
發生時間	7	1	9	14	9	5		4
最小值	1.07	12.05	44.44	0.65	16.24	8.94	1.17	72015.60
發生時間	0	20	0	0	14	23		22
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.02 %		-0.09		-0.10 %
全幅偏移(率)	0.04 %	0.03 %	-0.09 %	0.76 %		-0.04		0.00 %
有效比率	100.00 %	79.17 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.94	無效	66.26	2.77	15.30	10.57	1.09	83511.36
1	11.00	18.05	56.40	2.46	17.48	10.65	1.10	81916.57
2	8.92	15.38	69.26	2.54	16.51	10.92	1.10	77370.64
3	11.37	19.31	61.75	2.97	15.83	10.79	1.10	81890.01
4	8.62	17.11	63.72	2.62	16.41	10.64	1.10	82942.33
5	7.12	無效	58.35	2.89	14.83	11.03	1.10	80138.79
6	11.33	15.27	64.67	2.85	16.06	10.88	1.10	81847.85
7	8.06	16.35	69.55	2.52	18.31	9.92	1.07	80483.75
8	13.27	無效	67.28	2.90	15.79	10.66	1.10	80176.48
9	18.12	19.62	60.87	3.73	13.97	11.70	1.06	79370.82
10	7.32	16.59	67.48	2.41	17.24	10.72	1.07	83303.93
11	11.45	無效	55.26	3.27	16.10	10.35	1.08	81836.92
12	10.43	15.30	53.88	3.72	15.83	10.55	1.07	74193.68
13	8.00	14.46	66.43	2.56	16.31	10.34	1.07	75103.68
14	7.78	16.17	58.50	2.55	15.91	10.41	1.07	75684.72
15	10.14	18.26	62.29	2.79	16.28	10.11	1.07	78198.06
16	9.04	19.28	58.11	3.13	15.08	11.20	1.05	77409.62
17	5.80	16.93	70.89	2.91	15.93	10.61	1.05	82216.21
18	8.91	19.71	無效	3.81	13.60	11.39	1.05	79321.05
19	3.69	16.51	60.41	2.70	15.54	11.46	1.07	77830.84
20	8.10	無效	59.21	3.44	14.32	11.18	1.10	80128.49
21	8.68	8.92	60.98	3.60	14.09	11.76	1.10	78337.24
22	9.95	9.32	64.85	3.06	15.01	11.36	1.10	81945.31
23	8.52	15.30	56.53	2.99	14.76	11.41	1.06	80954.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	19	23	24	24	24	24	24
平均值	9.40	16.20	62.30	2.97	15.69	10.86	1.08	79838.06
最大值	18.12	19.71	70.89	3.81	18.31	11.76	1.10	83511.36
發生時間	9	18	17	18	7	21		0
最小值	3.69	8.92	53.88	2.41	13.60	9.92	1.05	74193.68
發生時間	19	21	12	10	18	7		12
零點偏移(率)	-0.04 %	0.00 %	-0.08 %	-0.05 %		-0.03		0.00 %
全幅偏移(率)	0.04 %	0.25 %	-0.44 %	0.60 %		0.30		0.00 %
有效比率	100.00 %	79.17 %	95.83 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								