

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月24日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.40	3.32	68.52	4.47	15.39	12.23	1.31	70021.02
1	8.38	3.28	56.75	4.21	15.84	12.07	1.34	70886.94
2	11.96	3.64	55.38	5.00	14.89	12.34	1.35	68883.05
3	12.14	3.55	65.58	6.16	13.22	12.79	1.35	68064.93
4	8.87	7.29	58.15	5.94	13.07	12.76	1.33	67225.26
5	10.88	4.02	63.37	4.07	15.10	12.19	1.29	66334.26
6	11.04	3.91	52.64	4.79	13.62	12.68	1.28	67735.61
7	10.43	5.67	56.79	4.55	13.97	12.56	1.28	68279.06
8	11.25	3.62	57.63	4.80	14.30	12.47	1.28	68278.79
9	8.77	3.56	70.45	4.07	14.52	12.90	1.31	64917.63
10	10.23	3.95	48.84	3.77	15.21	12.21	1.33	70441.22
11	9.00	3.87	64.78	3.46	15.39	12.53	1.35	67351.35
12	7.71	3.50	65.13	3.18	15.43	12.23	1.34	69743.08
13	9.27	6.16	40.29	4.45	13.58	12.84	1.29	65762.12
14	6.41	6.72	58.13	6.08	12.25	14.24	1.29	59760.55
15	9.95	11.47	47.40	5.60	12.68	12.94	1.30	66674.38
16	7.45	4.98	62.64	4.45	13.52	13.06	1.34	64355.34
17	3.74	7.92	59.79	4.33	13.71	13.59	1.38	59797.04
18	7.18	3.37	49.45	3.62	14.62	12.33	1.36	69450.71
19	9.20	7.75	55.07	4.96	12.52	12.78	1.33	66972.72
20	8.66	7.02	65.22	4.65	13.20	12.82	1.36	66360.84
21	10.64	2.01	57.91	4.73	13.43	12.76	1.36	69129.72
22	9.89	2.16	50.27	6.07	11.99	13.25	1.30	67328.26
23	9.17	3.04	66.55	4.11	13.85	12.71	1.30	67518.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.28	4.82	58.20	4.65	13.97	12.72	1.32	67136.35
最大值	12.14	11.47	70.45	6.16	15.84	14.24	1.39	70886.94
發生時間	3	15	9	3	1	14		1
最小值	3.74	2.01	40.29	3.18	11.99	12.07	1.28	59760.55
發生時間	17	21	13	12	22	1		14
零點偏移(率)	-0.69 %	-0.01 %	-0.50 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	-2.48 %	0.64 %	0.96 %	-0.41 %		-0.12	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月24日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.21	4.38	56.01	3.12	15.49	10.72	1.46	82745.40
1	11.03	4.61	68.62	3.08	15.69	10.82	1.45	80734.46
2	9.39	4.26	65.19	2.85	18.17	10.26	1.46	84064.86
3	10.39	5.29	47.95	3.54	15.76	10.62	1.46	81097.24
4	11.38	3.91	62.47	3.86	16.32	10.48	1.49	82466.91
5	9.51	5.73	58.44	3.50	15.86	10.55	1.50	83182.41
6	0.75	6.39	58.01	1.94	17.32	10.69	1.46	78143.24
7	7.09	3.85	50.03	2.47	18.06	10.33	1.45	83017.41
8	11.00	3.37	61.45	2.95	17.44	10.55	1.47	82736.89
9	9.43	4.76	52.88	3.50	16.44	10.57	1.49	81430.87
10	9.39	6.02	52.92	2.72	17.38	10.58	1.46	79206.55
11	9.28	3.63	62.21	2.43	18.43	10.19	1.44	82771.43
12	8.54	3.64	45.56	2.77	16.52	10.60	1.43	80985.68
13	11.11	3.62	57.89	2.80	16.96	10.74	1.44	83262.38
14	9.75	3.71	55.14	2.89	16.47	10.87	1.46	77559.49
15	9.34	4.29	63.33	2.53	16.93	10.80	1.49	79615.51
16	8.40	4.12	54.00	2.71	16.54	11.19	1.49	78944.15
17	4.46	3.80	60.70	1.95	17.82	10.69	1.45	82776.28
18	7.23	3.88	50.88	2.51	17.13	10.76	1.45	82402.05
19	11.11	7.70	50.73	5.75	16.06	10.27	1.43	76642.05
20	10.74	1.64	48.85	3.63	16.96	9.77	1.41	79095.49
21	10.18	1.57	44.71	3.79	16.25	9.94	1.46	82115.95
22	10.22	2.29	44.15	3.08	17.27	9.82	1.45	81498.37
23	10.26	4.62	58.37	2.91	16.81	9.92	1.43	80746.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.17	4.21	55.44	3.05	16.84	10.49	1.46	81135.08
最大值	11.38	7.70	68.62	5.75	18.43	11.19	1.50	84064.86
發生時間	4	19	1	19	11	16		2
最小值	0.75	1.57	44.15	1.94	15.49	9.77	1.40	76642.05
發生時間	6	21	22	6	0	20		19
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.07 %	0.45 %	0.51 %	0.23 %		-0.26	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月24日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.67	3.99	67.13	4.04	15.45	11.21	1.35	78401.95
1	6.11	4.27	69.24	3.79	15.95	11.37	1.37	79136.92
2	8.33	5.53	64.85	4.34	16.18	10.92	1.38	84117.55
3	11.23	7.03	61.75	5.70	13.97	11.07	1.38	80663.31
4	9.84	4.58	64.66	4.99	14.72	11.20	1.37	82722.40
5	11.11	5.23	62.37	5.10	15.48	10.81	1.37	85467.66
6	10.30	6.32	61.66	4.76	14.47	11.34	1.38	83294.84
7	3.55	5.19	60.71	2.76	15.11	11.11	1.35	80202.62
8	9.84	3.91	64.73	3.17	16.22	10.93	1.37	83458.65
9	9.40	5.28	58.61	3.19	16.50	10.65	1.35	81654.13
10	10.65	5.25	68.15	2.93	16.35	11.06	1.37	84346.89
11	9.59	7.27	60.65	3.66	14.82	10.84	1.37	82924.50
12	7.87	4.63	65.71	2.98	16.48	10.84	1.36	83334.77
13	8.48	4.19	59.79	2.83	16.93	10.75	1.37	84780.61
14	7.49	5.57	47.68	2.86	15.56	10.75	1.36	82976.61
15	9.29	5.39	54.22	3.23	15.49	10.75	1.36	83395.67
16	7.34	5.92	58.30	2.59	17.32	10.20	1.36	82893.71
17	4.78	3.72	68.65	2.53	17.21	10.84	1.36	81549.88
18	3.17	4.97	62.13	2.38	16.94	10.37	1.36	84090.43
19	8.88	7.44	51.51	3.66	15.51	10.40	1.35	82919.36
20	10.90	3.79	50.58	3.91	15.34	10.62	1.35	80372.41
21	9.54	3.01	53.02	3.61	14.87	10.80	1.33	76745.62
22	10.78	1.50	63.02	3.67	14.80	10.87	1.35	80476.90
23	9.44	4.03	53.57	3.75	14.44	10.92	1.36	77407.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.57	4.92	60.53	3.60	15.67	10.86	1.36	81972.30
最大值	11.23	7.44	69.24	5.70	17.32	11.37	1.40	85467.66
發生時間	3	19	1	3	16	1		5
最小值	3.17	1.50	47.68	2.38	13.97	10.20	1.33	76745.62
發生時間	18	22	14	18	3	16		21
零點偏移(率)	-0.06 %	-0.00 %	-0.02 %	-0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	0.07 %	-1.13 %	-0.50 %	-0.18 %		-0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								